Results of Proficiency Test Brominated Flame retardants September 2010

Organised by: Institute for Interlaboratory Studies Spijkenisse, the Netherlands

Author:Ing. R.J. StarinkCorrectors:Dr. R.G. Visser & Ing. N. BoelhouwerReport:iis10P03

October 2010

# CONTENTS

1		3
2	SET-UP	3
2.1	QUALITY SYSTEM	3
2.2	PROTOCOL	3
2.3	CONFIDIENTIALITY STATEMENT	4
2.4	SAMPLES	4
2.5	ANALYSES	5
3	RESULTS	
3.1	STATISTICS	5
3.2	GRAPHICS	6
3.3	Z-SCORES	6
4	EVALUATION	7
4.1	PERFORMANCE EVALUATION OF THE GROUP OF LABORATORIES	7
4.2	EVALUATION PER COMPONENT	8
4.3	EVALUATION OF THE METHODS USED	9
4.3	COMPARISON WITH PREVIOUS PROFICIENCY TESTS	9
5	CONCLUSIONS	9

# Appendices:

1.	Data, statistical results and graphical results	10
2.	Analytical details	16
3.	Number of participating laboratories per country	17
4.	Abbreviations and literature	18

### 1 INTRODUCTION

Worldwide, many consumer products with plastic parts are produced that contain brominated compounds as flame retardants. These brominated compounds are exceptionally effective at fire prevention.

Since the 1990s scientists have questioned the safety of the Poly Brominated Biphenyls (PBB) and Poly Brominated Diphenyls Ethers (PBDE), that bioaccumulate in blood, breast milk and fat tissues. As of June 1, 2006 the State of California began prohibiting the manufacture, distribution, and processing of flame retardant products containing pentabromodiphenyl ether (penta-BDE) and octabromodiphenyl ether (octa-BDE). The European Union decided to ban the use of both PBB and PBDE in electric and electronic devices. This ban was formalised in the RoHS Directive, and an upper limit of 1000 mg/kg for the sum of PBB and PBDE was set.

In February 2009, the Institute for Reference Materials and Measurements (IRMM) released the first certified reference materials (CRMs) to help analytical laboratories better detect these two classes of flame retardants.

As an alternative, participation in a proficiency test may enable the laboratories to check their performance and thus to increase this comparability. Therefore, a proficiency testing scheme (laboratory-evaluating interlaboratory study) for the determination of PBB and PBDE was started by the Institute for Interlaboratory Studies in 2009.

On request of several participants, the Institute for Interlaboratory Studies decided to continue the interlaboratory study for the determination of PBB and PBDE in the 2010/2011 PT program. In the interlaboratory study of September 2010, 46 laboratories from 18 different countries participated (See appendix 3). In this report, the results of the proficiency test are presented and discussed.

### 2 SET-UP

The Institute for Interlaboratory Studies (iis) in Spijkenisse, The Netherlands, was the organiser of this proficiency test. It was decided to send 2 different plastic samples (approximately 5 gram each), both positive on a number of brominated flame retardants and labelled #1050 and #1051 respectively. Participants were also requested to report some details of the methods used.

### 2.1 QUALITY SYSTEM

The Institute for Interlaboratory Studies in Spijkenisse, the Netherlands, has implemented a quality system based on ISO guide 43 and ILAC-G13:2007. This ensures 100% confidentially of participant's data. Also, customer's satisfaction is measured on a regular basis by sending out questionnaires.

### 2.2 PROTOCOL

The protocol followed in the organisation was the one as described for proficiency testing in the report 'iis Interlaboratory Studies: Protocol for the Organisation, Statistics and Evaluation' of January 2010 (iis-protocol, version 3.2). This protocol can be downloaded from the iis website http://www.iisnl.com.

#### 2.3 CONFIDENTIALITY STATEMENT

All data present in this report must be regarded as confidential and for use by the participating companies only. Disclosure of the information in this report is only allowed by means of the entire report. Use of the contents of this report for third parties is only allowed by written permission of the Institute for Interlaboratory Studies. Disclosure of the identity of one or more of the participating companies will be done only after receipt of a written agreement of the companies involved.

### 2.4 SAMPLES

Two different samples, positive for several brominated flame retardants, were selected. The first material (#1050) was a black coloured granulate. The second material (#1051) was also a black coloured granulate. Both materials were divided over plastic bags, approx. 5 grams for each sample.

The homogeneity of the subsamples was checked by determination of PBDE content on 4 stratified random selected subsamples.

	Deca-BDE in #1050	Deca-BDE in #1051
Sample 1	9998 mg/kg	1084 mg/kg
Sample 2	9953 mg/kg	1048mg/kg
Sample 3	10326 mg/kg	1063 mg/kg
Sample 4	10092 mg/kg	1065 mg/kg

Table 1: results of the homogeneity test on the subsamples #1050 and #1051

From the above results of the homogeneity test, the relative between sample standard deviations  $RSD_r$  were calculated and compared with 0.3 times the relative proficiency target standard deviations  $RSD_R$  in agreement with the procedure of ISO 13528, Annex B2 in the next table:

	Deca-BDE in #1050	Deca-BDE in #1051
RSD <sub>r</sub> (observed)	1.7%	1.4%
reference method	Horwitz	Horwitz
$0.3 \times RSD_R$ (reference method)	4.0%	5.6%

Table 2: relative repeatability standard deviations of Octa-BDE contents of the subsamples #1050 and #1051

The calculated variation coefficients RSDr are both in good agreement with the estimated targets, calculated using the Horwitz equation. Therefore, homogeneity of all subsamples was assumed.

To each of the participating laboratories one set of samples, (1\* sample #1050 and 1\* sample #1051) was sent on August 18, 2010.

### 2.5 ANALYSIS

The participants were requested to determine on both samples: Octa-BB, nona-BB, deca-BB, octa-BDE, nona-BDE and deca-BDE. It was explicitly requested to treat the samples as if it were routine samples and to report the analytical results using the indicated units on the report form and not to round the results, but report as much significant figures as possible. It was also requested not to report 'less than' results, which are above the detection limit, because such results can not be used for meaningful statistical calculations.

To get comparable results a detailed report form, on which the units were prescribed, was sent together with each set of samples. Also, a letter of instructions was added to the package. The laboratories were requested to complete the report form with some details of the methods used.

### 3 RESULTS

During four weeks after sample despatch, the results of the individual laboratories were received. The original data are tabulated per sample in the appendix 1 of this report. The laboratories are represented by the code numbers.

Directly after the deadline, a reminder fax was sent to those laboratories that did not report results at that moment.

Shortly after the deadline, the available results were screened for suspect data. A result was called suspect in case the Huber Elimination Rule (a robust outlier test) found it to be an outlier. The laboratories that produced these suspect data were asked to check the results. Additional or corrected results are used for the data analysis and the original results are placed under 'Remarks' in the result tables in appendix 1.

### 3.1 STATISTICS

The statistical calculations were performed as described in the procedures in the report 'iis Interlaboratory Studies, Protocol for the Organisation, Statistics and Evaluation' of January 2010 (iis-protocol, version 3.2).

First, the normality of the distribution of the various data sets per determination was checked by means of the Lilliefors-test. After removal of outliers this check was repeated. All data sets proved to have a normal distribution.

In accordance to ISO 5725 (1986 and 1994) the original results per determination were submitted subsequently to Dixon and Grubbs outlier tests. Outliers are marked by D(0.01) for the Dixon test, by G(0.01) or DG(0.01) for the Grubbs test. Stragglers are marked by D(0.05) for the Dixon test, by G(0.05) or DG(0.05) for the Grubbs test. Both outliers and stragglers were not included in the calculations of averages and standard deviations.

Finally, the reproducibilities were calculated from the standard deviations by multiplying them with a factor of 2.8.

### 3.2 **GRAPHICS**

In order to visualise the data against the reproducibilities from literature, Gauss plots were made, using the sorted data for one determination (see appendix 1). On the Y-axis the reported analysis results are plotted. The corresponding laboratory numbers are under the X-axis. The straight horizontal line presents the consensus value (a trimmed mean). The four striped lines, parallel to the consensus value line, are the +3s, +2s, -2s and -3s target reproducibility limits of the selected standard. Outliers and other data, which were excluded from the calculations, are represented as a cross. Accepted data are represented as a triangle. Furthermore, Kernel Density Graphs were made. This is a method for producing a smooth density approximation to a set of data that avoids some problems associated with histograms (see appendix 4; nr.14 and 15).

# 3.3 Z-SCORES

To evaluate the performance of the participating laboratories the z-scores were calculated. As it was decided to evaluate the performance of the participants in this proficiency test (PT) against the literature requirements, the z-scores were calculated using a target standard deviation. This results in an evaluation independent of the spread of this interlaboratory study.

The target standard deviation was calculated from the target reproducibility (preferably taken from a standardized test method) by division with 2.8.

The z-scores were calculated in accordance with:

z<sub>(target)</sub> = (result - average of PT) / target standard deviation

The z (target) scores are listed in the result tables in appendix 1.

Absolute values for z < 2 are very common and absolute values for z > 3 are very rare. Therefore the usual interpretation of z-scores is as follows:

z   < 1	good
1 <   z   < 2	satisfactory
2 <   z   < 3	questionable
3 <   z	unsatisfactory

### 4 EVALUATION

In this interlaboratory study, no problems were encountered with despatch of the samples. Four participants reported results after the final reporting date and three participants did not report any results at all. Not all laboratories were able to report all analytes requested.

Finally, 43 of the 46 participants submitted analysis results. The 43 reporting laboratories reported 219 numerical results. Observed were 28 outlying results, which is 11.3%. In proficiency studies, outlier percentages of 3% - 7.5% are quite normal.

For the determination of PBB and PBDE, the IEC62321 method is considered to be the official EC test method. Regretfully this method does not yet mention reproducibility requirements. Therefore, the target requirements in this study were estimated using the Horwitz equation.

### 4.1 PERFORMANCE EVALUATION OF THE GROUP OF LABORATORIES

A comparison has been made between the reproducibility as declared by the relevant standard and the reproducibility as found for the group of participating laboratories. The calculated reproducibilities and the target reproducibilities derived from the literature standards are compared in the next tables.

Analytes	unit	n	Average	2.8 * sd	R (lit)
Octa-BDE #1050	mg/kg	29	35.0	37.8	27.5
Nona-BDE #1050	mg/kg	37	530.1	548.8	160.0
Deca-BDE #1050	mg/kg	35	9679	2791	1089

Table 3: performance overview for sample #1050

Parameter	unit	n	Average	2.8 * sd	R (lit)
Octa-BDE #1051	mg/kg	11	5.37	5.19	5.61
Nona-BDE #1051	mg/kg	35	78.9	87.9	31.7
Deca-BDE #1051	mg/kg	36	1171.8	456.7	181.2

Table 4: performance overview for sample #1051

Without further statistical calculations, it can be concluded that there is not a good compliance of the group of participating laboratories with the relevant target reproducibility.

The analytes that were problematic are discussed in paragraph 4.2.

#### 4.2 EVALUATION PER COMPONENT

In this section the results are discussed per analyte.

Several participants reported a significant number of test results, that were not at all in agreement with the consensus value for the respective component. Therefore, it was decided that all results reported by these participants (2199, 2312, 3163, 3213 and 3225) were excluded from the statistical evaluations.

- <u>PBB</u>: In the samples #1050 and #1051 no PBB's were detected by the participating laboratories. Therefore, no conclusions can be drawn about the determination of these components.
- <u>Octa-BDE</u>: Analytical problems were observed for a number of individual laboratories at the low concentration levels 5-35 mg/kg in the evaluated materials. For sample #1050 the calculated reproducibility after rejection of the statistical outliers, is not in full agreement with the target requirement estimated from the Horwitz equation. Two participants reported a false negative result. Also, two test results were excluded from the statistical evaluation. The Octa-BDE concentration in sample #1051 was very low and no significant conclusions were drawn. Several laboratories may have reported false positive test results.
- <u>Nona-BDE</u>: Analytical problems were observed for a number of individual laboratories.
   For sample #1050, the calculated reproducibility after rejection of the statistical outliers is not at all in agreement with the target requirement estimated from the Horwitz equation. The reported test results vary over a large range (48 4797 mg/kg). One result was excluded from the statistical evaluation.
   Also for sample #1051, the calculated reproducibility after rejection of the statistical outliers is not at all in agreement with the target requirement estimated from the Horwitz equation. Also for sample #1051, the calculated reproducibility after rejection of the statistical outliers is not at all in agreement with the target requirement estimated from the Horwitz equation. Again the reported test results vary over a large range (10 631 mg/kg). Two participants may have reported a false negative test result. Also, one test result was excluded from the statistical evaluation.
- <u>Deca-BDE</u>: Analytical problems were observed for a number of individual laboratories.
   For sample #1050, the calculated reproducibility after rejection of the statistical outliers is not at all in agreement with the target requirement estimated from the Horwitz equation. The reported test results vary over a large range (0 15828 mg/kg). Two results were excluded from the statistical evaluation.
   Also, for sample #1051, the calculated reproducibility after rejection of the statistical outlier is not at all in agreement with the target requirement estimated from the Horwitz equation. The reported test results vary over a large range (0 3100 mg/kg). One test result was excluded from the statistical evaluation.

#### 4.3 EVALUATION OF THE METHODS USED

The reported details of the methods that were used by the participants are listed in appendix 2.

For the determination of PBB and PBDE, the IEC62321 method is considered to be the official EC test method. In this proficiency test the majority of the participants used a version of IEC62321 and almost all laboratories used GC/MS for separation, detection and quantification (none used HPLC). Surprisingly not all laboratories that reported to have performed IEC62321 may have followed the guidelines for the sample preparation of this method. Several laboratories that reported to have performed IEC62321 did answer the question "To what particle size was the sample reduced prior to analysis?" with "as received", "1mm" or "2mm", while the correct procedure should be dissolution or when the samples cannot be dissolved, cooling and milling. A number of participants used ultrasonification instead of Soxhlet extraction to release the components from the plastic matrix. These results were not significantly different from the other results, although several very low results are reported by these participants.

### 4.4 COMPARISON WITH PREVIOUS PROFICIENCY TESTS

The number of participants was the same to last year's proficiency test. The percentage of outliers increased from 6.2% last year to 11.3% of the numerical results in 2010.

The evolution of the relative reproducibilities for PBDE as observed in this proficiency scheme and the comparison with the findings in the previous round is visualized in the next table.

Range	Octa-BDE	None-BDE	Deca-BDE
2009	60 – 102%	60 – 110%	36 – 103%
2010	97 – 108%	104 - 112%	29 – 39%

Table 5: comparison of the relative PBDE reproducibilities in the previous round and in the present round


### 5 CONCLUSIONS

Most of the observed reproducibilities are larger than the target reproducibility requirements and therefore it had to be concluded that the determination of the PBDE in the evaluated materials obviously is rather problematic.

Each laboratory has to evaluate its performance in this study and make decisions about necessary corrective actions. Therefore, participation on a regular basis in this scheme could be helpful to improve the performance and the quality of the analytical results.

Determination of Octabromo diphenyl ether on sample #1050; results in mg/kg

324         EC62321         <5         < < 3.05         fails negative?           339         EC62321         36.2         0.12           551	lab	method	value	mark	z(targ)	imple #1050; results in mg/kg remarks
651						false negative?
607       EPA3540C/3590C       45.2       1.04         2129       Inhouse       n.d.          2156       IFC02321       5       -3.05         2156       IFC02321       14.1446       -2.12         2171       IEC02321       14.1446       -2.12         2121       IFC02321       13.17       -0.39         2120       Inhouse       20       -1.52         2215       Inhouse       31.93       -0.31         2237       EFC62321       34          2236       IEC62321       1.46       D(0.05)       -5.41         2237       EFC62321       1.46       D(0.05)       -5.41         2341       IEC62321       n.d.          2352       IEC62321       n.d.          2361       IEC62321       n.d.          2375       IEC62321       n.d.          2361       IEC62321       n.d.          2376       IEC62321       3.7       0.07         2381       IEC62321       35.0       0.00         2384       IEC62321       35.7       0.07         2		IEC62321				
826       IECG2321       24,76       -1.04         2129       IN buse       n.d.						
2129       EN62321       -40						
2121     in house     n.d.						
2166       ECC8221       5       -3.05         2166       ECC8221       14,1446       -2.12         2172       ECC8221       11,17       -0.39         2199       ECR321       54						
2165       IEC62321       49       1.42         2172       IEC62321       31.17       -0.39         2199       IEC63321       31.17       -0.39         2201       inbuse       31.93       -0.31         2201       inbuse       31.93       -0.31         2203       IEC62321       54.4       197         2231       IEC62321       33       -0.20         22321       IEC62321       33       -0.20         2312       IEC62321       n.d.          2312       IEC62321       n.d.          2325       Inbuse       0       ex       -3.56         2312       IEC62321       n.d.          2326       IEC62321       31.00       -0.20         2335       IEC62321       35.7       0.07         2356       IEC62321       35.60       0.00         2376       IEC62321       34.0       -0.10         2375       IEC62321       35.60       0.06         2376       IEC62321       35.60       0.06         3159       IEC62321       54.3       1.96         3159       IEC62321						
2169       IEC62321       14.1446       -2.12         2172       IEC62321       31.17       -0.39         2189       Inhouse       20       -1.52         2201       inhouse       20       -1.52         2215       inhouse       31.93       -0.31         2216            2217       Inkose       31.93       -0.31         2218       IEC62321       54.4       1.97         2230       IEC62321       1.46       D(0.05)       -3.41         2241       IEC62321       1.46       D(0.05)       -3.41         2255       Incose       0       ex       -3.56       Result excluded, zero is not a real result         2351       IEC62321       1.07       0.62           2356       IEC62321       35.0       0.00          2366       IEC62321       45.7       1.09         2376       IEC62321       35.6       0.06          2376       IEC62321       44.6       0.98          2376       IEC62321       45.6       0.06          2376       IEC62321						
2172       IEC62321       31.17       -0.39         2189       EFAS40C/GCMS       <5						
2220     in house     20     -1.52       2216     in house     31.93     -0.31       2230     IEC62321     54.4     1.97       2241     in Keil     0.05)     -3.41       2245     in house     0     ex       2350     IEC62321     33     -0.20       2351     IEC62321     n.d.		IEC62321				
2216         2230     IEC62321     54.4     1.97       2231     IEC62321     3.4        2241     IEC62321     3.4        2255     IEC62321     3.4        2216     IEC62321     3.4        2217     IEC62321     3.3     -0.20       2225     in house     0     ex     -3.56       2216     IEC62321     27.70     -0.74       2350     IEC62321     35.0     0.00       2351     IEC62321     35.0     0.00       2355     IEC62321     35.7     0.07       2366     IEC62321     44.6     0.98       2370     IEC62321     44.6     0.98       2370     IEC62321     35.60     0.00       2376     IEC62321     44.6     0.98       3100     IEC62321     35.60     0.06       3100     IEC62321     35.60     0.06       3100     IEC62321     56.60     1.66       3116          3153     GCMS     608     G(0.01)     7.13       3164     IEC62321     7.15     -2.83       3172     in house <td>2199</td> <td>EPA3540C/GCMS</td> <td>&lt;5</td> <td></td> <td>&lt;-3.05</td> <td>false negative?</td>	2199	EPA3540C/GCMS	<5		<-3.05	false negative?
2216       EC62321       54.4       1.97         2237       EC62321       3.3          2241       EC62321       3.3          2255       in house       0       ex          2310       EC62321       n.d.          2311       EC62321       n.d.          2350       EC62321       7.70       -0.74         2352       EC62321       31.00       -0.22         2353       EC62321       33.00       -0.20         2354       EC62321       35.7       0.07         2365       EC62321       35.7       0.07         2366       EC62321       45.7       1.09         2366       EC62321       34.0       -0.10         2378       EC62321       35.7       0.00         2379       EC62321       35.7       0.00         2370       EC62321       35.7       0.00         2370       EC62321       35.7       0.00         2370       EC62321       35.0       0.00         3172       in C62321       35.0       0.00         3180       EC62321       7.15		in house				
2230       EC62321       54.4       1.97         2237       EN62321       1.46       D(0.05)       3.41         2241       IEC62321       33       -0.20         2255       in house       0       ex       -3.56         2212       IEC62321       27.70       -0.74         2350       IEC62321       27.70       -0.74         2355       IEC62321       35.0       0.00         2355       IEC62321       35.0       0.00         2365       IEC62321       35.0       0.00         2366       IEC62321       45.7       1.09         2366       IEC62321       44.6       0.98         2370       IEC62321       35.60       0.00         2375       IEC62321       35.60       0.06         2376       IEC62321       54.3       1.96         3116           3153       IEC62321       7.15       -2.283         3163       GCMS       608       G(0.01)       58.25         3154            3154       IEC62321       7.1.8          3154 <t< td=""><td></td><td>in house</td><td>31.93</td><td></td><td>-0.31</td><td></td></t<>		in house	31.93		-0.31	
2237       EN62321       1.46       D(0.05)       -3.41         2241       EC62321       33       -0.20         2312       IEC62321       n.d.          2350       IEC62321       27.70       -0.74         2352       EP62321       33.00       -0.20         2353       IEC62321       33.00       -0.20         2354       IEC62321       35.7       0.07         2366       IEC62321       45.7       1.09         2375       IEC62321       35.7       0.07         2366       IEC62321       44.6       0.98         2370       IEC62321       35.60       0.00         2371       IEC62321       35.60       0.00         2372       IEC62321       35.60       0.00         2373       IEC62321       56.60       0.06         31100       IEC62321       56.60       0.06         31131       IEC62321       56.6       1.58         3153       IEC62321       50.56       1.58         3154						
2241       IEC62321       33       -0.20         2295       in house       0       ex       -3.56       Result excluded, zero is not a real result         2310       IEC62321       n.d.           2360       IEC62321       n.d.          2361       IEC62321       33.00       -0.20         2353       IEC62321       35.0       -0.00         2363       IEC62321       35.7       0.07         2365       IEC62321       45.7       1.09         2366       IEC62321       44.6       0.98         2370       IEC62321       35.60       0.00         2377       IEC62321       35.60       0.06         2378       IEC62321       35.60       0.06         3100       IEC62321       35.60       0.06         3116           3151       IEC62321       55.6       1.27         3153       IEC62321       7.15       -2.83         3163       GC/MS       608       G(0.01)         3172       in house       n.d.          3181       IEC62321       51.3       ex       1.6						
2295       in house       0       ex       -3.56       Result excluded, zero is not a real result         2312       IEC62321       27.70       -0.74         2353       IEC62321       31.12       0.22         2354       IEC62321       33.00       -0.20         2355       IEC62321       35.0       0.00         2365       IEC62321       35.7       0.07         2366       IEC62321       45.7       1.09         2370       IEC62321       44.6       0.98         2371       IEC62321       35.7       0.00         2372       IEC62321       34.0       -0.10         2373       IEC62321       35.7       0.00         3160           3172       In house       0.00         3161           3153       IEC62321       7.15       -2.83         3163       GCMS       608       G(0.01)       58.25         3172       in house       n.d.          3185       IEC62321       51.3       ex       1.66         3225       IEC62321       51.32       1.66 <t< td=""><td></td><td></td><td></td><td>D(0.05)</td><td></td><td></td></t<>				D(0.05)		
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$				07		Reput evaluated acrea is not a real reput
2350       ECG2321       27.70       -0.74         2352       EPA3540C/8270D       37.12       0.22         2355       ECG2321       41.07       0.62         2355       ECG2321       35.0       0.00         2363       ECG2321       35.7       0.07         2365       ECG2321       45.7       1.09         2366       ECG2321       44.6       0.98         2370       ECG2321       34.0       -0.10         2371       ECG2321       34.0       -0.10         2372       ECG2321       35.60       0.06         2379       ECG2321       35.60       0.06         2379       ECG2321       35.60       0.06         2379       ECG2321       35.60       0.06         3100       ECG2321       35.60       0.06         3100       ECG2321       56.6       1.27         3153       ECG24521       50.56       1.58         3172       in house       r.1.6       result excluded, see paragraph 4.2         3225       ECG2321       51.3       ex       1.66         3243       EN62321       51.32       1.66 <t< td=""><td></td><td></td><td></td><td>ex</td><td></td><td>Result excluded, zero is not a real result</td></t<>				ex		Result excluded, zero is not a real result
2352       EPA3540C/8270D       37.12       0.22         2353       IEC62321       41.07       0.62         2355       IEC62321       33.00       -0.20         2363       IEC62321       35.7       0.07         2366       IEC62321       45.7       1.09         2376       IEC62321       44.6       0.98         2377       IEC62321       34.0       -0.10         2375       IEC62321       35.60       0.00         2376       IEC62321       34.0       -0.10         2377       IEC62321       35.60       0.00         3100       IEC62321       35.60       0.00         3101       IEC62321       54.3       1.96         3116           3153       IEC62321       7.15       -2.83         3163       GC/MS       608       G(0.01)       58.25         3172       in house       n.d          3181       IEC62321       51.3       ex       1.66         3225       IEC62321       51.3       G(0.01)       71.35         3233       IEC62321       51.3       (+2 excl.) <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>						
2353       IEC62321       41.07       0.62         2355       IEC62321       33.00       -0.20         2365       IEC62321       35.0       0.00         2365       IEC62321       45.7       1.09         2366       IEC62321       44.6       0.98         2370       IEC62321       44.6       0.98         2370       IEC62321       34.0       -0.10         2372       IEC62321       35.60       0.06         3175       IEC62321       35.60       0.06         3100       IEC62321       54.3       1.96         3116						
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
2359       IEC62321       35.0       0.00         2363       IEC62321       35.7       0.07         2366       IEC62321       45.7       1.09         2366       IEC62321       44.6       0.98         2370       IEC62321       34.0       -0.10         2372       IEC62321       35.60       0.06         3100       IEC62321       35.60       0.06         3101						
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$						
2366       IEC62321       44.6       0.98         2370       IEC62321       34.0       -0.10         2372       IEC62321       35       0.00         2379       IEC62321       35.60       0.06         3100       IEC62321       54.3       1.96         3116           3153       IEC62321       74.5       1.27         3154           3155       IEC62321       7.15       -2.83         3163       GC/MS       608       G(0.01)       58.25         3172       in house       <100	2363					
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	2365		45.7		1.09	
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
$\begin{array}{cccccccccccccccccccccccccccccccccccc$		IEC02321				
$\begin{array}{cccccccccccccccccccccccccccccccccccc$		IEC62321				
$\begin{array}{cccccccccccccccccccccccccccccccccccc$						
3163       GC/MS       608       G(0.01)       58.25         3172       in house       <100		IEC62321				
3172       in house       <100				G(0.01)		
3185       IEC62321       50.56       1.58         3191       IEC62321       43       0.81         3209       in house       n.d.          3213       IEC62321       51.3       ex       1.66         3225       IEC62321       736.85       G(0.01)       71.35         3239       IEC62321       51.32       1.66         3243       EN62321       n.d.          normality       OK          normality       OK          st.dev. (n)       34.99       (+2 excl.)         st.dev. (n)       13.493       R(calc.)         R(Horwitz)       27.54				· - /		
3209       in house       n.d.          3213       IEC62321       51.3       ex       1.66         3225       IEC62321       736.85       G(0.01)       71.35         3239       IEC62321       51.32       1.66         3243       EN62321       n.d.          normality       OK          normality       OK          mean (n)       34.99       (+2 excl.)         st.dev. (n)       13.493         R(calc.)       37.78         R(Horwitz)       27.54	3185		50.56			
3213       IEC62321       51.3       ex       1.66       Result excluded, see paragraph 4.2         3225       IEC62321       736.85       G(0.01)       71.35         3239       IEC62321       51.32       1.66         3243       EN62321       n.d.          normality       OK          normality       OK          mean (n)       34.99         st.dev. (n)       13.493         R(calc.)       37.78         R(Horwitz)       27.54						
3225       IEC62321       736.85       G(0.01)       71.35         3239       IEC62321       51.32       1.66         3243       EN62321       n.d.          normality       OK          normality       OK          nean (n)       34.99       (+2 excl.)         st.dev. (n)       13.493         R(calc.)       37.78         R(Horwitz)       27.54						
3239       IEC62321       51.32       1.66         3243       EN62321       n.d.          normality       OK          n       29       29         outliers       3       (+2 excl.)         mean (n)       34.99         st.dev. (n)       13.493         R(calc.)       37.78         R(Horwitz)       27.54						Result excluded, see paragraph 4.2
3243       EN62321       n.d.          normality       OK          n       29          outliers       3       (+2 excl.)         mean (n)       34.99         st.dev. (n)       13.493         R(calc.)       37.78         R(Horwitz)       27.54				G(0.01)		
normality         OK           n         29           outliers         3         (+2 excl.)           mean (n)         34.99           st.dev. (n)         13.493           R(calc.)         37.78           R(Horwitz)         27.54						
n 29 outliers 3 (+2 excl.) mean (n) 34.99 st.dev. (n) 13.493 R(calc.) 37.78 R(Horwitz) 27.54	3243	EN62321	n.a.			
n 29 outliers 3 (+2 excl.) mean (n) 34.99 st.dev. (n) 13.493 R(calc.) 37.78 R(Horwitz) 27.54		normality	ОК			
outliers         3         (+2 excl.)           mean (n)         34.99           st.dev. (n)         13.493           R(calc.)         37.78           R(Horwitz)         27.54			29			
mean (n)34.99st.dev. (n)13.493R(calc.)37.78R(Horwitz)27.54				(+2 excl.)		
st.dev. (n) 13.493 R(calc.) 37.78 R(Horwitz) 27.54				()		
R(calc.) 37.78 R(Horwitz) 27.54						
		R(Horwitz)	27.54			
	100 <sub>T</sub>					0.03



# Determination of Nonabromo diphenyl ether on sample #1050; results in mg/kg

	method	value	mark	z(targ)	remarks
324	IEC62321	277		-4.43	
339	IEC62321	588		1.01	
551					
607	EPA3540C/3550C	699.5		2.96	
826	IEC62321	651.11		2.12	
2129	EN62321	48	D(0.05)	-8.44	
2132	in house	447.9		-1.44	
2156	IEC62321	197	С	-5.83	First reported 97
2165	IEC62321	559		0.51	
2169	IEC62321	766.7183		4.14	
2172	IEC62321	633.5		1.81	
2199	EPA3540C/GCMS	3190	G(0.01)	46.54	
2202	in house	557		0.47	
2215	in house	605.7		1.32	
2216	15000004				
2230	IEC62321	950		7.35	
2237	EN62321	213		-5.55	
2241	IEC62321	581		0.89	
2295	in house	151		-6.63	Deput evoluted and reserve to 10
2312	IEC62321	572.1	ex	0.73	Result excluded, see paragraph 4.2
2350	IEC62321 EPA3540C/8270D	572.0		0.73	
2352		623.94		1.64	
2353	IEC62321	648.29		2.07	
2355	IEC62321	588.00		1.01	
2359	IEC62321	652.3		2.14	
2363 2365	IEC62321 IEC62321	609.6 639.7		1.39 1.92	
	IEC62321				
2366 2370		625.9		1.68 1.84	
2370	IEC62321 IEC62321	635 511		-0.33	
2372	IEC62321	558		0.49	
2375	IEC62321	603		1.28	
3100	IEC62321	495.2		-0.61	
3116	IEC62321	650		2.10	
3153	IEC62321	250		-4.90	
3154	12002021			-4.00	
3159	IEC62321	279.3		-4.39	
3163	GC/MS	1467	G(0.01)	16.39	
3172	in house	134	0(0.01)	-6.93	
3185	IEC62321	538.2		0.14	
3191	IEC62321	477		-0.93	
3209	in house	486.8		-0.76	
3213	IEC62321	1662.9	G(0.01)	19.82	
3225	IEC62321	4796.6	G(0.01)	74.66	
3239	IEC62321	930.71	- ( /	7.01	
3243	EN62321	229		-5.27	
-					
	normality	not OK			
	n	37			
	outliers	5	(+1 excl.)		
	mean (n)	530.12	. ,		
	st.dev. (n)	196.011			
	R(calc.)	548.83			
	R(Horwitz)	160.01			
2000 T					
1800					0.0035 Kemel Density
					x 0.003 -
1600 -					
1400 -					x 0.0025 -
1200 -					0.002 -
1000 -					
					A A 0.0015

-

2128
 2128
 2128
 21595
 21555
 21555
 21555
 3153
 3122
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3132
 3133
 3145
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146
 3146

- -

===

800

600

400

200

1000

1500

2000

0.0015

0.001

0.0005

0

-500

500


≁

-

\_\_\_\_\_\_

# Determination of Decabromo diphenyl ether on sample #1050; results in mg/kg

lab	method	value	mark	z(targ)	remarks
324	IEC62321	9721		0.11	
339	IEC62321	9070		-1.57	
551					
607	EPA3540C/3550C	10493.0		2.09	
826	IEC62321	8373.47		-3.36	
2129	EN62321	11750		5.32	
2132	in house	7476.4		-5.66	
2156	IEC62321	9799		0.31	
2165	IEC62321	9540		-0.36	
2169	IEC62321	8185.974		-3.84	
2172	IEC62321	9285		-1.01	
2199	EPA3540C/GCMS	15500	G(0.01)	14.96	
2202	in house	6992	G(0.05)	-6.91	
2215	in house	9083		-1.53	
2216	15000004				
2230	IEC62321	11485		4.64	
2237	EN62321	3820	G(0.05)	-15.06	
2241	IEC62321	9861		0.47	
2295 2312	in house IEC62321	11760 15827.8	G(0.05)	5.35 15.80	
2350	IEC62321	9097	G(0.05)	-1.50	
2352	EPA3540C/8270D	9566.36		-0.29	
2353	IEC62321	9828.82		0.38	
2355	IEC62321	10576.07		2.31	
2359	IEC62321	10195.9		1.33	
2363	IEC62321	9464.1		-0.55	
2365	IEC62321	9525.4		-0.40	
2366	IEC62321	10126.4		1.15	
2370	IEC62321	9056		-1.60	
2372	IEC62321	8870		-2.08	
2375	IEC62321	11898		5.70	
2379	IEC62321	9283		-1.02	
3100	IEC62321	10117.6		1.13	
3116	IEC62321	10000		0.82	
3153	IEC62321	10300		1.60	
3154					
3159	IEC62321	8574		-2.84	
3163	GC/MS	0	G(0.01)	-24.88	
3172	in house	9011		-1.72	
3185	IEC62321	9784		0.27	
3191	IEC62321	9611		-0.18	
3209 3213	in house IEC62321	8566.8 11288.4	<b>0</b> Y	-2.86 4.14	Result excluded, see paragraph 4.2
3225	IEC62321	12386.9	ex ex	6.96	Result excluded, see paragraph 4.2
3239	IEC62321	9434.01	CX.	-0.63	Result excluded, see paragraph 4.2
3243	EN62321	12708	C, G(0.05)	7.79	First reported 20063
0240		12100	0, 0(0.00)	1.10	
	normality	OK			
	n	35			
	outliers	6	(+2 excl.)		
	mean (n)	9679.1			
	st.dev. (n)	996.74			
	R(calc.)	2790.9			
	R(Horwitz)	1089.4			
<sup>18000</sup> T					0.0004
16000 -					x x 0.00035 - Kernel Density
14000 -					
					x X 0.0003 -
12000 -					
10000			_ = = = = = = = = = = = = = = = = = = =		
1  ==	: = = = = = = = = = = = = = = = = =	• _4_ <u> </u>			



# Determination of Octabromo diphenyl ether on sample #1051; results in mg/kg

				-(1	·
	method	value	mark	z(targ)	remarks
324 339	IEC62321 IEC62321	<5 <25			
551		~25			
607	EPA3540C/3550C	5.1		-0.14	
826	IEC62321	6.02		0.32	
2129	EN62321	<40			
2132 2156	in house IEC62321	n.d. 5		-0.19	
2150	IEC62321	n.d.		-0.19	
2169	IEC62321	<5			
2172	IEC62321	<5.00			
2199	EPA3540C/GCMS	<5			
2202 2215	in house	n.d.			
2215	in house	n.d. 			
2230	IEC62321	<50			
2237	EN62321	0.327		-2.52	
2241	IEC62321	n.d.			
2295 2312	in house IEC62321	0 n d	ex	-2.68	Result excluded, zero is not a real result
2312	IEC62321	n.d. 5.30		-0.04	
2352	EPA3540C/8270D	<5		-0.04	
2353	IEC62321	6.42		0.52	
2355	IEC62321	n.d.			
2359 2363	IEC62321 IEC62321	6.3 <5		0.46	
2365	IEC62321	<o n.d.</o 			
2366	IEC62321	n.d.			
2370	IEC62321	5.93		0.28	
2372	IEC62321	7.79		1.21	
2375 2379	IEC62321 IEC62321	5.2 5.70		-0.09 0.16	
3100	IEC62321	n.d.			
3116					
3153	IEC62321	<20			
3154	15000004				
3159 3163	IEC62321 GC/MS	<5.0 100	G(0.01)	47.27	
3172	in house	<100	G(0.01)	47.27	
3185	IEC62321	n.d.			
3191	IEC62321	<10			
3209	in house	n.d.	0(0.04)		
3213 3225	IEC62321 IEC62321	32.9 180.7	G(0.01) G(0.01)	13.75 87.58	
3239	IEC62321	12.41	D(0.01)	3.52	
3243	EN62321	n.d.	()		
	normality n	not OK 11			
	outliers	4	(+1 excl.)		
	mean (n)	5.37			
	st.dev. (n)	1.853			
	R(calc.)	5.19			
	R(Horwitz)	5.61			
<sup>100</sup> T					x 0.12
90 -					0.1 - (
80 -					
70 -					0.08 -
60 -					
50 -					0.06 -
40 -					x 0.04 -
30 -					
20 -					x 0.02

= = =

= = =


= = = =

= = =

-50


# Determination of Nonabromo diphenyl ether on sample #1051; results in mg/kg

lab	method	value	mark	z(targ)	remarks
324	IEC62321	14.4		-5.69	
339	IEC62321	48.4		-2.69	
551		40.4		-2.09	
607	EPA3540C/3550C	78.5		-0.03	
826	IEC62321	74.27		-0.40	
2129	EN62321	<40			folgo nogativo?
				<-3.43	false negative?
2132	in house	113.9		3.09	
2156	IEC62321	10		-6.08	
2165	IEC62321	80		0.10	
2169	IEC62321	65.5700		-1.17	
2172	IEC62321	88.90		0.89	
2199	EPA3540C/GCMS	630	G(0.01)	48.67	
2202	in house	109		2.66	
2215	in house	84.42		0.49	
2216					
2230	IEC62321	112		2.93	
2237	EN62321	21.1		-5.10	
2241	IEC62321	82		0.28	
2295	in house	13		-5.82	
2312	IEC62321	146.2	D(0.05)	5.95	
2350	IEC62321	78.70		-0.01	
2352	EPA3540C/8270D	74.30		-0.40	
2353	IEC62321	103.56		2.18	
2355	IEC62321	96.39		1.55	
2359	IEC62321	102.5		2.09	
2363	IEC62321	74.6		-0.38	
2365	IEC62321	85.8		0.61	
2366	IEC62321	99.8		1.85	
2370	IEC62321	83.4		0.40	
2372	IEC62321	107		2.49	
2375	IEC62321	130.9		4.60	
2379	IEC62321	96.20		1.53	
3100	IEC62321	60.3		-1.64	
3116	IEC62321	100		1.87	
		45.6		-2.94	
3153	IEC62321				
3154 3159	IEC62321	 49.44		-2.60	
					Desult such ded, ees nemericants 4.0
3163	GC/MS	30	ex	-4.31	Result excluded, see paragraph 4.2
3172	in house	<100			
3185	IEC62321	68.92		-0.88	
3191	IEC62321	65		-1.22	
3209	in house	117.6		3.42	
3213	IEC62321	265.3	G(0.01)	16.46	
3225	IEC62321	631.2	G(0.01)	48.78	
3239	IEC62321	124.40		4.02	
3243	EN62321	n.d.			false negative?
	normality	OK			
	n	35			
	outliers	4	(+1 excl.)		
	mean (n)	78.85	. ,		
	st.dev. (n)	31.401			
	R(calc.)	87.92			
	R(Horwitz)	31.71			
	( ······/	· · · ·			
<sup>300</sup> T					
					x Kernel Density
250 -					0.01 -
200 -					0.008 -



# Determination of Decabromo diphenyl ether on sample #1051; results in mg/kg

lab	method	value	mark	z(targ)	remarks
324	IEC62321	1097		-1.16	
339	IEC62321	1310		2.13	
551					
607	EPA3540C/3550C	1545.5		5.77	
826	IEC62321	1162.26		-0.15	
2129	EN62321	1209		0.57	
2132	in house	971.0		-3.10	
2156	IEC62321	1196		0.37	
2165	IEC62321	1200		0.44	
2169	IEC62321	1254.638		1.28	
2172	IEC62321	1128		-0.68	
2199	EPA3540C/GCMS	3100	G(0.01)	29.79	
2202	in house	962		-3.24	
2215	in house	1204		0.50	
2216 2230	IEC62321	 1508		 5.19	
2230	EN62321		DG(0.05)	-7.29	
2237	IEC62321	699.9 1197	DG(0.05)	0.39	
2295	in house	35	G(0.01)	-17.56	
2312	IEC62321	650.4	DG(0.01)	-8.06	
2350	IEC62321	939.0	20(0.00)	-3.60	
2352	EPA3540C/8270D	1156.02		-0.24	
2353	IEC62321	1100.96		-1.10	
2355	IEC62321	1110.00		-0.96	
2359	IEC62321	1139.2		-0.50	
2363	IEC62321	1180.6		0.14	
2365	IEC62321	1224.9		0.82	
2366	IEC62321	1099.6		-1.12	
2370	IEC62321	1102		-1.08	
2372	IEC62321	824		-5.37	
2375	IEC62321	1386		3.31	
2379	IEC62321	1288		1.79	
3100 3116	IEC62321 IEC62321	1186.7 1100		0.23 -1.11	
3153	IEC62321	1540		5.69	
3154	12002021				
3159	IEC62321	1273		1.56	
3163	GC/MS	0	G(0.05)	-18.10	
3172	in house	1005	-()	-2.58	
3185	IEC62321	1156		-0.24	
3191	IEC62321	1139		-0.51	
3209	in house	1041.1		-2.02	
3213	IEC62321	1597.1	ex	6.57	Result excluded, see paragraph 4.2
3225	IEC62321	2262.45	G(0.05)	16.85	
3239	IEC62321	905.68	-	-4.11	
3243	EN62321	1345	С	2.68	First reported 2166
	normality	OK			
	n	36			
	outliers	6	(+1 excl.)		
	mean (n)	1171.8	(		
	st.dev. (n)	163.09			
	R(calc.)	456.7			
	R(Horwitz)	181.2			
3000					0.0025 Kernel Density
2500 -					
					x 0.002 -
2000 -					
1500					0.0015 -
1500 -					



#### Analytical details

Lab	Max. particle size	Extraction	Detection	Corrected for rec.
324	<2mm	SOXHLET	GC-MS	NO
339	2mm	Extraction+ ultrawave 60°C 1hr	GC-MS	NO
551				
607	<0.5mm	Ultrasonic+SOXHLET	GC-MS	NO
826	Crushed by using LN2	IEC 32321	GC-MS	NO
2129	<100µm	Ultrasonic	GC-MS	NO
2132	Fine powder using cryogenic mill	Ultrasonic 50°C using Toluene 1 hr	GC-MSD	NO
2156	500µm	SOXHLET	GC-MS	NO
2165	Powder	Extract with organic solution	GC-MS	NO
2169	<500µm	SOXHLET	GC-MS	NO
2172	≤1x1x1mm	SOXHLET/Toluene	GC-MSD	NO
2199		SOXHLET	GC-MS	NO
2202	No pre-treatment	Dissolution + precipitation	GC-MS	NO
2215	1x1x1mm	Ultrasonic	GC-MS	NO
2216				
2230	Grinding into powder <5mm	SOXHLET 2 hr Toluene	GC-MSD	
2237	<0.5mm	Ultrasonic	GC-MS	NO
2241	Powder	SOXHLET	GC-MS	NO
2295	Used as it is	Ultrasonic 50°C 1 hr Toluene	GC analysis	NO
2312	<0.5mm	SOXHLET	SIM	
2350	Freezing grinding <500µm	SOXHLET	GC-MS	NO
2352	<0.5x0.5x0.5mm	SOXHLET 16 hr, 6 circles/hr	SIM	NO
2353	1x1x1mm	SOXHLET	GC-MS	NO
2355	1x1x1mm	SOXHLET	GC-MS	NO
2359	Powder	SOXHLET	GC-MS	NO
2363	0.5x0.5x0.5mm	SOXHLET	GC-MS	NO
2365	<0.5x0.5x0.5mm	SOXHLET	GC-MS	NO
2366	<500µm	SOXHLET	GC-MS	NO
2370	Powder	SOXHLET	GC-MS	NO
2372	<0.5mm	SOXHLET	GC-MS	NO
2375	0.5x0.5x0.5mm	SOXHLET	GC-MS	NO
2379	1x1x1mm	SOXHLET	GC-MS	NO
3100	<500µm	SOXHLET Toluene	SIM	NO
3116	500µm	SOXHLET	GC-MS	
3153	<500µm	SOXHLET	GC-MS	NO
3154				
	<1x1x1mm	SOXHLET	GC-MS	NO
3163		Dissolve in THF	GC-MS	NO
3172	<3mm	Extraction in Toluene, ultrasonic bath	GC-MS/MS	NO
3185	<500µm	SOXHLET	GC-MS/HPLC	NO
3191	<500µm	SOXHLET Toluene	GC-MS	NO
3209	<1mm	Extraction in Toluene, ultrasonic bath	GC-MS	NO
3213	Freeze mill	SOXHLET	GC-MS	NO
3225	~500µm	SOXHLET	GC-MSD	NO
3239	<500µm	SOXHLET	GC-MS	NO
3243	cooling and milling	SOXHLET	GC-MS	NO

#### Number of participating laboratories per country

1 lab in BELGIUM 1 lab in BRASIL 1 lab in FRANCE 4 labs in GERMANY 6 labs in HONG KONG 1 lab in INDIA 1 lab in ITALY 1 lab in JAPAN 4 labs in KOREA 2 labs in MALAYSIA 14 labs in P.R. of CHINA 2 labs in SINGAPORE 3 labs in TAIWAN R.O.C. 1 lab in THAILAND 1 lab in THE NETHERLANDS 2 labs in TURKEY 1 lab in U.S.A.

#### Abbreviations:

- C = final result after checking of first reported suspect result
- D(0.01) = outlier in Dixon's outlier test
- D(0.05) = straggler in Dixon's outlier test
- G(0.01) = outlier in Grubbs' outlier test
- G(0.05) = straggler in Grubbs' outlier test
- DG(0.01) = outlier in Double Grubbs' outlier test
- DG(0.05) = straggler in Double Grubbs' outlier test
- n.a. = not applicable

#### Literature:

- 1 iis Interlaboratory Studies, Protocol for the Organisation, Statistics & Evaluation, January 2010
- 2 EN 1122:2001, "Determination of Cadmium in plastics with the method of the wet decomposition".
- 3 ASTM D4004:98, "Determination of Metal Content by Flame Atomic Absorption (AAS) analysis"
- 4 ASTM E178-02
- 5 ASTM E1301-03
- 6 ISO 5725-86
- 7 ISO 5725, parts 1-6, 1994
- 8 M. Thompson and R. Wood, J. AOAC Int, <u>76</u>, 926, (1993)
- 9 W.J. Youden and E.H. Steiner, Statistical Manual of the AOAC, (1975)
- 10 IP 367/96
- 11 DIN 38402 T41/42
- 12 P.L. Davies, Fr. Z. Anal. Chem, <u>331</u>, 513, (1988)
- 13 J.N. Miller, Analyst, <u>118</u>, 455, (1993)
- 14 Analytical Methods Committee Technical Brief, No4 January 2001
- 15 The Royal Society of Chemistry 2002, Analyst 2002, 127 page1359-1364, P.J. Lowthian and M. Thompson. (see http://www.rsc.org/suppdata/an/b2/b205600n/)
- 16 R.G. Visser, Reliability of proficiency test results for metals and phthalates in plastics, Accred Qual Assur, 14:29-34 (2009)