

Results of Proficiency Test
Gasoil (ASTM Spec)
September 2014

Organised by: Institute for Interlaboratory Studies
Spijkenisse, the Netherlands

Authors: ing. R.J. Starink
Correctors: dr. R.G. Visser & ing. L. Sweere
Report: iis14G04ASTM

November 2014

CONTENTS

1 INTRODUCTION 3

2 SET UP 3

2.1 ACCREDITATION 3

2.2 PROTOCOL..... 3

2.3 CONFIDENTIALITY STATEMENT 4

2.4 SAMPLES 4

2.5 STABILITY OF THE SAMPLES 6

2.6 ANALYSES 6

3 RESULTS..... 7

3.1 STATISTICS 7

3.2 GRAPHICS 8

3.3 Z-SCORES..... 8

4 EVALUATION 8

4.1 EVALUATION PER TEST 9

4.2 PERFORMANCE EVALUATION FOR THE GROUP OF LABORATORIES..... 12

4.3 COMPARISON OF THE PROFICIENCY TEST OF SEPTEMBER 2014 WITH PREVIOUS PTS..... 14

Appendices:

1. Data, statistical results and graphic results 16

2. z-Scores for the distillation 88

3. Number of participants per country 91

4. Abbreviations and literature 92

1 INTRODUCTION

Since 1994, the institute for Interlaboratory Studies organizes every year proficiency tests for Gasoil. In the annual proficiency testing program of 2014-2015, it was decided to continue the proficiency test for the analysis of Gasoil in accordance with the latest applicable version of ASTM D975 specification.

In the main PT, 173 laboratories in 72 different countries have participated. In the PT for Cetane Number, 57 laboratories in 31 different countries participated. In the PT for the Total Contamination on Gasoil, 64 laboratories in 27 different countries and in the PT for the Oxidation Stability on Gasoil, 55 laboratories in 26 different countries participated. See appendix 3 for the number of participants per country. In this report, the results of the 2014 proficiency test are presented and discussed. This report is also electronically available through the iis internet site www.iisnl.com.

2 SET UP

The Institute for Interlaboratory Studies (iis) in Spijkenisse, the Netherlands, was the organiser of this proficiency test. In this Gasoil round robin dedicated to the ASTM specification, it was decided to send low sulphur gasoil samples for the regular round robin (1*1 L glass bottle and 1*0.5 L glass bottle, both labelled #14175), for the Cetane Number round robin (4*1L glass bottle, all labelled #14176) and for the Total Contamination round robin (1*1L, 85% filled glass bottle, labelled #14177). For the Oxidation stability round robin (1*0.5L glass bottle labelled #14178), it was decided to send a gasoil from a batch of retained Gasoil samples. Sample analyses for fit-for-use and homogeneity testing were subcontracted. Participants were requested to report rounded and unrounded results. The unrounded results were preferably used for statistical evaluation.

2.1 ACCREDITATION

The Institute for Interlaboratory Studies in Spijkenisse, the Netherlands, is accredited in agreement with ISO/IEC 17043:2010 (R007), since January 2000, by the Dutch Accreditation Council (Raad voor Accreditatie). This ensures strict adherence to protocols for sample preparation and statistical evaluation and 100% confidentiality of participant's data. Feedback from the participants on the reported data is encouraged and customer's satisfaction is measured on regular basis by sending out questionnaires.

2.2 PROTOCOL

The protocol followed in the organisation of this proficiency test was the one as described for proficiency testing in the report 'iis Interlaboratory Studies: Protocol for the Organisation, Statistics and Evaluation' of April 2014 (iis-protocol, version 3.3). The protocol can be downloaded from the iis internet site: <http://www.iisnl.com>.

2.3 CONFIDENTIALITY STATEMENT

All data presented in this report must be regarded as confidential and for use by the participating companies only. Disclosure of the information in this report is only allowed by means of the entire report. Use of the contents of this report for third parties is only allowed by written permission of the Institute for Interlaboratory Studies. Disclosure of the identity of one or more of the participating companies will be done only after receipt of a written agreement of the companies involved.

2.4 SAMPLES

2.4.1 regular low sulphur winter Gasoil

From the 800 litre low sulphur Gasoil (automotive diesel), which was purchased from the local market, approx. 400 litre was homogenized. For the regular Gasoil samples, from a 400 litre batch 220 amber glass bottles of 1L and 220 amber glass bottles of 0.5L, with inner and outer caps were filled and labelled #14175. The homogeneity of the subsamples was checked by the determination of Density in accordance with ASTM D4052:11 on 8 stratified randomly selected samples.

	Density @ 15 °C in kg/m ³		Density @ 15 °C in kg/m ³
sample #14175-1	835.76	sample #14175-5	835.74
sample #14175-2	835.74	sample #14175-6	835.75
sample #14175-3	835.72	sample #14175-7	835.75
sample #14175-4	835.75	sample #14175-8	835.76

Table 1: homogeneity test results of subsamples #14175

From the above test results, the repeatabilities were calculated and compared with 0.3 times the corresponding reproducibilities in agreement with the procedure of ISO 13528, Annex B2 in the next table:

	Density @ 15°C in kg/m ³
r (sample #14175)	0.04
reference test	ASTM D4052:11
0.3*R (reference test)	0.15

Table 2: precision data of the subsamples #14175

The calculated repeatability was less than 0.3 times the reproducibility of the reference method. Therefore, homogeneity of the subsamples #14175 was assumed.

2.4.2 Gasoil for Cetane Number

From the starting batch of 800 litre, another 400 litre was homogenized for the Gasoil Cetane Number samples. From the 400 litre batch, 320 amber glass bottles of 1L, with inner and outer caps were filled and labelled #14176. The homogeneity of the subsamples was checked by the determination of Density in accordance with ASTM D4052:11 on 10 stratified randomly selected samples.

	Density @ 15 °C in kg/m ³		Density @ 15 °C in kg/m ³
sample #14176-1	835.00	sample #14176-6	835.00
sample #14176-2	835.00	sample #14176-7	834.97
sample #14176-3	835.00	sample #14176-8	834.98
sample #14176-4	834.98	sample #14176-9	834.96
sample #14176-5	834.97	sample #14176-10	834.98

Table 3: homogeneity test results of subsamples #14176

From the above test results, the repeatabilities were calculated and compared with 0.3 times the corresponding reproducibilities in agreement with the procedure of ISO 13528, Annex B2 in the next table:

	Density @ 15°C in kg/m ³
r (sample #14176)	0.04
reference test	ASTM D4052:11
0.3*R (reference test)	0.15

Table 4: precision data of the subsamples #14165

The calculated repeatability was less than 0.3 times the reproducibility of the reference method. Therefore, homogeneity of the subsamples #14176 was assumed.

2.4.3 Total contamination

The remaining material (approx. 150 liter) of the low sulphur Gasoil batch was homogenized. From this batch, 95 amber glass bottles of 1L with inner and outer caps were filled and labelled #14177.

For the Total Contamination determination, each of the 95 filled bottles was spiked with 1 ml of a fresh prepared and ultrasonically homogenized, 10 g/kg particulate quartz material BCR-070 (ø 1.2-20 µm) in oil suspension. The addition was checked by weighting each bottle before and after addition of the spike.

2.4.4 Oxidation Stability

For the Oxidation Stability determination, 50 liter of Gasoil from a batch of retained Gasoil, was homogenised and subsequently divided over 85 amber glass bottles of 0.5L, with inner and outer caps and labelled #14178. The homogeneity of the subsamples was checked by the determination of Density in accordance with ASTM D4052:11 on 8 stratified randomly selected samples.

	Density @ 15 °C in kg/m ³		Density @ 15 °C in kg/m ³
sample #14178-1	844.21	sample #14178-5	844.22
sample #14178-2	844.21	sample #14178-6	844.21
sample #14178-3	844.22	sample #14178-7	844.21
sample #14178-4	844.20	sample #14178-8	844.21

Table 5: homogeneity test results of subsamples #14178

From the above test results, the repeatabilities were calculated and compared with 0.3 times the corresponding reproducibilities in agreement with the procedure of ISO 13528, Annex B2 in the next table:

	Density @ 15°C in kg/m ³
r (sample #14178)	0.02
reference test	ASTM D4052:11
0.3*R (reference test)	0.15

Table 6: precision data of the subsamples #14178

The calculated repeatability was less than 0.3 times the reproducibility of the reference method. Therefore, homogeneity of the subsamples #14178 was assumed.

Depending on the registration of the participant: one bottle of 1L and one bottle of 0.5L, labelled #14175, four bottles of 1L #14176, one bottle of 1L #14177 and/or 1 bottle of 0.5L labelled #14178 were sent to the participating laboratories on September 3, 2014.

2.5 STABILITY OF THE SAMPLES

The stability of the low sulphur gasoil, packed in the brown glass bottles, was checked. The material was found sufficiently stable for the period of the proficiency test.

2.6 ANALYSIS

The participants were asked to determine on the samples #14175: Acid number (TAN), Aromatics by FIA, Ash Content, Cetane Index (D979 and D4737), Cold Filter Plugging Point, Cloudpoint, Color ASTM, Copper Corrosion, Density @ 15°C, Distillation (IBP, 5%, 10%, 50%, 90%, 95% recovered, FBP and %V/V at 250°C and 350°C), FAME content, Flash Point PMcc, Kinematic Viscosity @ 40°C, Lubricity by HFRR, Nitrogen, Pour Point, Ramsbottom Carbon Residue, Sulphur content, Water content and Water & Sediment (D2709 & D1796).

On sample #14176: Cetane number and/or DCN were requested to be determined, on sample #14177 only Total Contamination was requested to be determined and on sample #14178 only Oxidation Stability was requested to be determined. The participants were also requested to report additional information for some determinations.

To get comparable results a detailed report form, on which the units were prescribed as well as the required standards and a letter of instructions were prepared and made available on the data entry portal www.kpmd.co.uk/sgs-iis/. The detailed report form was also made available for download on the iis website www.iisnl.com.

A SDS and a form to confirm receipt of the samples were added to the sample package.

3 RESULTS

During four weeks after sample despatch, the results of the individual laboratories were gathered. The original data are tabulated per determination in the appendix 1 of this report. The laboratories are presented by their code numbers.

Directly after deadline, a reminder fax was sent to those laboratories that had not yet reported. Shortly after the deadline, the available results were screened for suspect data. A result was called suspect in case the Huber Elimination Rule (a robust outlier test) found it to be an outlier. The laboratories that produced these suspect data were asked to check the (raw data of the) reported results. Additional or corrected results have been used for data analysis and the original results are placed under 'Remarks' in the result tables in appendix 1.

3.1 STATISTICS

Statistical calculations were performed as described in the report 'iis Interlaboratory Studies: Protocol for the Organisation, Statistics and Evaluation' (iis-protocol, April 2014 version 3.3). For the statistical evaluation the *unrounded* (when available) figures were used instead of the rounded results. Results reported as '<...>' or '>...>' were not used in the statistical evaluation.

First, the normality of the distribution of the various data sets per determination was checked by means of the Lilliefors-test a variant of the Kolmogorov-Smirnov test and by the calculation of skewness and kurtosis. Evaluation of the three normality indicators in combination with the visual evaluation of the graphic Kernel density plot, lead to judgement of the normality being either 'unknown', 'OK', 'suspect' or 'not OK'. After removal of outliers, this check was repeated. Not all data sets proved to have a normal distribution, in which cases the statistical evaluation of the results should be used with due care.

In accordance to ISO 5725 (1986 and 1994) the original results per determination were submitted subsequently to Dixon, Grubbs and Rosner outlier tests. Outliers are marked by D(0.01) for the Dixon test, by G(0.01) or DG(0.01) for the Grubbs test and by R(0.01) for the Rosner General ESD test (see appendix 4, no.16). Stragglers are marked by D(0.05) for the Dixon test, by G(0.05) or DG(0.05) for the Grubbs test and by R(0.05) for the Rosner's test. Both outliers and stragglers were not included in the calculations of the averages and the standard deviations.

For each assigned value, the uncertainty was determined in accordance with ISO13528. Subsequently the calculated uncertainty was evaluated against the respective requirement based on the target reproducibility in accordance with ISO13528. When the uncertainty passed the evaluation, no remarks are made in the report. However, when the uncertainty failed the evaluation it is mentioned in the report and it will have consequences for the evaluation of the test results.

Finally, the reproducibilities were calculated from the standard deviations by multiplying them with a factor of 2.8.

3.2 GRAPHICS

In order to visualize the data against the reproducibilities from literature, Gauss plots were made, using the sorted data for one determination (see appendix 1). On the Y-axis the reported analysis results are plotted. The corresponding laboratory numbers are under the X-axis. The straight horizontal line presents the consensus value (a trimmed mean). The four striped lines, parallel to the consensus value line, are the +3s, +2s, -2s and -3s target reproducibility limits of the selected standard. Outliers and other data, which were excluded

from the calculations, are represented as a “x”. Accepted data are represented as a triangle. Furthermore, Kernel Density Graphs were made. This is a method for producing a smooth density approximation to a set of data that avoids some problems associated with histograms (see appendix 4; nos.13 and 14). Also a normal Gauss curve was projected over the Kernel Density Graph.

3.3 Z-SCORES

To evaluate the performance of the participating laboratories the z-scores were calculated. As it was decided to evaluate the performance of the participants in this proficiency test (PT) against the literature requirements, e.g. ASTM reproducibilities, the z-scores were calculated using a target standard deviation. This results in an evaluation independent of the spread of this interlaboratory study. The target standard deviation was calculated from the literature reproducibility by division with 2.8.

When a laboratory did use a test method with a reproducibility that is significantly different from the reproducibility of the reference test method used in this report, it is strongly advised to recalculate the z-score, while using the reproducibility of the actual test method used, this in order to evaluate whether the reported test result is fit-for-use.

The z-scores were calculated in accordance with:

$$z_{(\text{target})} = (\text{result} - \text{average of PT}) / \text{target standard deviation}$$

The $z_{(\text{target})}$ scores are listed in the result tables in appendix 1.

Absolute values for $z < 2$ are very common and absolute values for $z > 3$ are very rare.

Therefore the usual interpretation of z-scores maybe as follows:

$ z < 1$	good
$1 < z < 2$	satisfactory
$2 < z < 3$	questionable
$3 < z $	unsatisfactory

4 EVALUATION

In this interlaboratory study, several problems with customs clearance were encountered during dispatch of the samples to laboratories in Afghanistan, Brazil, Chile, Colombia, Costa Rica, Equatorial Guinea, Malaysia, Morocco, Mozambique, Russia, Sudan, Tanzania, Trinidad and Turkmenistan.

For the regular Gasoil PT: Thirty-one participants reported test results after the final reporting date and ten participants did not report any test results at all.

For the Cetane Number PT: eight participants reported the test results after the final reporting date and six participants did not report any test results at all.

For the Total Contamination PT: ten participants reported the test results after the final reporting date and six participants did not report any test results at all.

For the Oxidation Stability PT: eight participants reported the test results after the final reporting date and eight participants did not report any test results at all.

Finally, 163 participants reported in total 3419 numerical results. Observed were 68 outlying results, which is 2.0%. In proficiency studies, outlier percentages of 3% - 7.5% are quite normal.

4.1 EVALUATION PER TEST

In this section, the results are discussed per sample and per test. The specified test methods and requirements were taken into account for explaining the observed differences when possible and applicable. These methods are also in the tables together with the reported data. The abbreviations, used in these tables, are listed in appendix 3.

In the iis PT reports, ASTM methods are referred to with a number (e.g. D976) and an added designation for the year that the method was adopted or revised (e.g. D976-06). If applicable, a designation in parentheses is added to designate the year of reapproval (e.g. D976-06 (2011)). In the results tables of Appendix 1 only the method number and year of adoption or revision will be used.

Not all original data sets proved to have a normal Gaussian distribution. These are referred to as “not OK” or “suspect”. The statistical evaluation of these data sets should be used with due care.

Acid Number (Total): This determination was problematic for a number of laboratories. Three statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in good agreement with the requirements of ASTM D974:12.

Aromatics (FIA): This determination was problematic. Only one statistical outlier was observed. However, the calculated reproducibility after rejection of the statistical outlier is not in agreement with the requirements of ASTM D1319:13. One should be aware that this Gasoil does not meet the scope of ASTM D1319 (petroleum fractions should be distilling below 315°C).

Ash: Four statistical outliers were observed. Regretfully, the ash content for this sample was below or near the application range of the method. Still, the calculated reproducibility after rejection of the statistical outliers is smaller than the extrapolated reproducibility of ASTM D482:13.

C.I. D976: Regretfully, no reproducibility limits are mentioned in ASTM D976:06 (2011). Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is the same as found in the previous i.i.s. proficiency test (see also iis13G04). Ten participants possibly made calculation errors.

C.I. D4737: Regretfully, no reproducibility limits are mentioned in ASTM D4737:10. Four statistical outliers were observed. In this case, it appeared that not all participants used the same calculation method. Five participants reported results according ASTM D4737 procedure B. All other participants reported test results according procedure A of ISO4264:95/IP380:98/ASTM D4737.

Up to 2003 ISO4264 and ASTM D4737 were equivalent test methods. However since 2003 only in ASTM D4737 two possible calculation methods for Cetane Index are given. The actual calculation method to be used depends on the type of Gasoil that is specified in table 1 of ASTM D975:12. This makes it rather confusing because the latest version of ISO4264 is said to be similar to ASTM D4737:96a(01) and in this version only calculation A is described. Seven participants possibly made a calculation error. One should keep in mind that Biodiesel blends are excluded from this test method, because they were not part of the datasets use to develop both procedures. (see ASTM D4737, chapter 1.6).

- Cloud Point: This determination was not problematic. Three statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in good agreement with the requirements of ASTM D2500:11.
- CFPP: This determination was problematic. Only one statistical outlier was observed. However, the calculated reproducibility after rejection of the statistical outlier is not in agreement with the requirements of ASTM D6371:05 (2010). Rounding to 1°C may explain part of the spread.
- Colour ASTM: This determination was not problematic. Seven statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in agreement with the requirements of ASTM D1500:12.
- Conradson CR: This determination was not problematic. Three statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in agreement with the requirements of ASTM D189:06e1 (2010).
- Ramsbottom CR: This determination was problematic. No statistical outliers were observed. However, the calculated reproducibility is not in agreement with the requirements of ASTM D524:10.
- Copper Corrosion: This determination was not problematic. All participants agreed on a result of 1 (or 1A).
- Density @15°C: This determination was not problematic. Four statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in good agreement with ASTM D4052:11.
- Distillation: The automated method was not problematic. In total ten statistical outliers were observed. One other test result from one laboratory was excluded from statistical evaluation as all other reported test results from this laboratory were marked as statistical outliers. All calculated reproducibilities were, after rejection of the suspect test results, in agreement with the requirements of ASTM D86:12.

The manual method was problematic. No statistical outliers were observed. However, the calculated reproducibilities for Initial Boiling Point, 10% recovered, 95% recovered and Final Boiling Point were after rejection of the statistical outliers not in agreement with the requirements of ASTM D86:12.

FAME: This determination was not problematic. Two statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in good agreement with ASTM D7371:14. It was remarkable to see that most laboratories used EN14078. When the results for EN14078 were evaluated separately the calculated reproducibility was not in agreement with the requirements of the standard.

Flash Point: This determination was not problematic. No statistical outliers were observed and the calculated reproducibility is in full agreement with the requirements of ASTM D93:13e1 (procedure A).

Kinematic. Visc. 40°C: This determination was problematic for a number of laboratories. Seven statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in full agreement with ASTM D445:14e2.

Lubricity: This determination may be problematic. No statistical outliers were observed. However, the calculated reproducibility is not in agreement with ASTM D6079:11. When the calculated reproducibilities for ASTM D6079 and for ISO12156 (equal to ASTM D7688/IP450) are evaluated separately, both observed reproducibilities are not in agreement with the requirements of the respective standards.

Nitrogen: This determination was problematic. Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is not in agreement with ASTM D4629:12.

Pour Point: For the manual mode, the determination was not problematic. No statistical outliers were observed and the calculated reproducibility is in full agreement with ASTM D97:12.
Also for the automated mode, the determination was not problematic. Only one statistical outlier was observed. Four results were excluded as the reported test method is a manual method. However, the calculated reproducibility after rejection of the suspect data is in full agreement with ASTM D5950:14.

Sulphur: This determination was not problematic. Three statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in agreement with the requirements of ASTM D5453:12.

Water: This determination was not problematic. No statistical outliers were observed. The calculated reproducibility is in good agreement with the ASTM D6304:07.

A number of laboratories used ASTM D95, which is not applicable for low water concentrations.

Water&Sediment (D2709): All reporting laboratories reported a “less then” result or zero. Therefore no significant conclusions were drawn.

Water&Sediment (D1796): All reporting laboratories reported a “less then” result or zero. Therefore no significant conclusions were drawn.

CN - D613: This determination was not problematic. Three statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in good agreement with the requirements of ASTM D613:13.

DCN - D6890: This determination may not be problematic. In total, two statistical outliers were observed. The calculated reproducibility for DCN after rejection of the statistical outlier is not in agreement with the ASTM D6890:13be1. Three participants possibly made a calculation error. The spread for DCN after recalculation of the results by iis is in good agreement with the requirements of ASTM D6890:13be1. The calculated reproducibility for “Ignition delay” is not in agreement with the requirements.

DCN - D7668: This determination was very problematic. In total, only one statistical outlier was observed and two results were excluded for several reasons. The calculated reproducibility for DCN after rejection of the suspect data is not at all in agreement with the ASTM D7668:14a. The calculated reproducibility for “Ignition delay” after rejection of the suspect data is also not in agreement with the requirements. The variety of equipment software used may partly explain the large spread.

Total Contamination: This determination was very problematic at the level of 25.9 mg/kg. The samples were spiked with 1 ml of a fresh prepared and ultrasonically homogenized, 10 g/kg particulate quartz material BCR-070 (ϕ 1.2-20 μ m) in oil suspension. Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is not at all in agreement with the requirements of ASTM D6217:11 or EN12662:08. It is unclear whether the laboratories that reported results according EN12662 used 300 mL (as prescribed in the latest EN12662, 2014 version) or 1 Liter as prescribed in ASTM D6217. The correctness of the sample pretreatment is critical for this determination.

Oxidation Stability: This determination may not be problematic at this low level of 0.21 mg/100ml. Four statistical outliers were observed. Two results were excluded as they probably reported in a deviating unit. The calculated reproducibility after rejection of the suspect results is in good agreement with ASTM D2274:10.

4.2 PERFORMANCE EVALUATION FOR THE GROUP OF LABORATORIES

A comparison has been made between the reproducibility as declared by the relevant standard and the reproducibility as found for the group of participating laboratories that participated. The average results of the evaluated parameters, calculated reproducibilities and reproducibilities, derived from literature standards (in casu ASTM standards) are compared in the next tables.

Parameters	unit	n	average	2.8 * sd	R (lit)
Acid Number (TAN)	mgKOH/g	81	0.020	0.026	0.040
Aromatics by FIA	%V/V	36	22.35	7.05	3.70
Ash content	%M/M	73	0.0008	0.0013	(0.0050)
Cetane Index ASTM D976		83	53.20	0.73	unknown
Cetane Index ASTM D4737		97	52.98	1.16	unknown
Cloud Point	°C	132	-7.6	2.3	4.0
Cold Filter Plugging Point	°C	104	-24.7	6.9	5.1
Colour ASTM		82	0.6	0.2	1.0
Conradson Carbon Residue	%M/M	67	0.020	0.023	0.029
Ramsbottom Carbon Residue	%M/M	12	0.066	0.048	0.030
Copper Corrosion 3hrs at 50°C		124	1(1A)	unknown	unknown
Density at 15 °C	kg/m ³	152	835.7	0.3	0.5
IBP (automated)	°C	109	169.3	8.3	9.3
10% recovery (automated)	°C	109	209.8	5.0	4.6
50% recovery (automated)	°C	109	272.8	2.9	3.0
90% recovery (automated)	°C	110	331.5	4.7	5.0
95% recovery (automated)	°C	110	347.3	7.7	8.8
FBP (automated)	°C	110	356.8	5.9	7.1
Volume at 250°C (automated)	%V/V	102	32.7	2.1	2.7
Volume at 350°C (automated)	%V/V	102	95.7	1.8	2.7
IBP (manual)	°C	35	170.6	8.3	6.2
10% recovery (manual)	°C	35	207.6	6.7	4.5
50% recovery (manual)	°C	35	272.3	3.8	3.9
90% recovery (manual)	°C	35	331.5	3.7	4.0
95% recovery (manual)	°C	34	346.5	8.1	5.2
FBP (manual)	°C	35	356.9	6.3	4.0
Volume at 250°C (manual)	%V/V	33	33.2	2.8	2.6
Volume at 350°C (manual)	%V/V	33	95.7	1.5	2.2
FAME	%V/V	61	2.64	0.34	0.84
Flash Point PMcc	°C	155	63.2	4.0	4.5
Kinematic Viscosity at 40°C	mm ² /s	132	2.767	0.029	0.031
Lubricity by HFRR	µm	78	287	140	80
Nitrogen	mg/kg	39	59.3	8.9	6.6
Pour Point, manual	°C	81	-26.3	5.9	6.6
Pour Point, automated	°C	45	-25.7	4.0	6.1
Total Sulphur	mg/kg	113	8.73	2.33	2.95
Water	mg/kg	124	47.1	31.3	170.4
Water and Sediment (D2709)	%V/V	25	<0.05	unknown	unknown
Water and Sediment (D1796)	%V/V	19	<0.05	unknown	unknown

Table 7: summary of tests results of Gasoil #14175
NB results between brackets may be near or below the limit of detection

Parameters	unit	n	average	2.8 * sd	R (lit)
Cetane Number		29	55.0	2.9	4.7
DCN (ASTM D6890)		14	57.7	3.2	2.9
Ignition delay (ASTM D6890)		12	3.55	0.29	0.19
DCN (ASTM D7668)		11	57.3	4.4	1.7
Ignition delay (ASTM D7668)		9	2.74	0.16	0.12

Table 8: summary of tests results of Gasoil #14176

Parameters	unit	n	average	2.8 * sd	R (lit)
Total Contamination	mg/kg	54	25.9	12.0	5.7

Table 9: summary of tests results of Gasoil #14177

Parameters	unit	n	average	2.8 * sd	R (lit)
Oxidation Stability	mg/100mL	37	0.21	0.36	0.72

Table 10: summary of tests results of Gasoil #14178

Without further statistical calculations, it can be concluded that for several tests there is a good compliance of the group of participating laboratories with the relevant standards. The problematic tests have been discussed in paragraph 4.1.

4.3 COMPARISON OF THE INTERLABORATORY STUDY OF SEPTEMBER 2014 WITH PREVIOUS PTS.

	<i>September 2014</i>	<i>September 2013</i>	<i>October 2012</i>	<i>October 2011</i>
Number of reporting labs	163	160	158	163
Number of results reported	3419	3123	3086	2882
Statistical outliers	68	67	97	84
Percentage outliers	2.0%	2.1%	3.1%	2.9%

Table 11: comparison with previous proficiency tests.

In proficiency tests, outlier percentages of 3% - 7.5% are quite normal. The performance of the determinations of the proficiency tests was compared against the requirements of the respective standards. The conclusions are given the following table:

	<i>September 2014</i>	<i>September 2013</i>	<i>October 2012</i>	<i>October 2011</i>
Acid Number (Total)	++	++	++	++
Aromatics (FIA)	--	--	--	--
Ash content	(++)	(++)	(++)	(++)
Cloud Point	++	++	++	++
Cold Filter Plugging Point	-	-	--	--
Colour ASTM	++	++	++	++
Conradson Carbon Residue	+	+	+/-	n.e.
Ramsbottom Carbon Residue	--	--	--	--
Density @ 15 °C	++	++	++	++
Distillation – automated mode	++	++	+	++
Distillation – manual mode	-	--	--	--
FAME	++	++	(++)	(++)
Flash Point PMcc	+	+	++	++
Kinematic Viscosity @ 40 °C	+	-	-	--
Lubricity by HFRR	--	-	-	--
Nitrogen content	--	--	--	--
Pour Point	++	+	++	++
Sulphur	++	+/-	+	+
Water content	++	++	++	++

Table 12: comparison determinations against the standard
result between brackets was out of application range

	<i>September 2014</i>	<i>September 2013</i>	<i>October 2012</i>	<i>October 2011</i>
Cetane Number	++	++	++	+
DCN (ASTM D6890)	-	++	++	--
Ignition Delay (D6890)	--	++	++	--
DCN (ASTM D7170)	n.e.	--	+	n.e.
Ignition Delay (D7170)	n.e.	n.e.	+/-	n.e.
DCN (ASTM D7668)	--	n.e.	n.e.	n.e.
Ignition Delay (D7668)	--	n.e.	n.e.	n.e.
Total Contamination	--	--	n.e.	n.e.
Oxidation Stability	++	+	++	--

Table 13: comparison determinations against the standard

The performance of the determinations against the requirements of the respective standards is listed in the above table. The following performance categories were used:

- ++: group performed much better than the standard
- + : group performed better than the standard
- +/-: group performance similar to the standard
- : group performed worse than the standard
- : group performed much worse than the standard
- n.e.: not evaluated

APPENDIX 1

Determination of Acid Number (TAN) on sample #14175; result in mgKOH/g

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D664	0.02		-0.01	825	D664	0.015		-0.36
53		----		----	854	D664	0.03		0.69
92		----		----	862	D664	0.0170		-0.22
120	D664	0.017		-0.22	863	D664	0.019		-0.08
132	D664	0.01		-0.71	873		----		----
140	D664	0.011		-0.64	874	D664	0.017		-0.22
150	D664	<0.05		----	875	D664	0.0238		0.26
158	D664	0.0257		0.39	887	D664	0.016		-0.29
159	D664	0.01645		-0.26	902	D664	<0.1		----
169		----		----	922	D664	0.0181		-0.14
171	D664	0.02		-0.01	951		----		----
175		----		----	962		----		----
186		----		----	963	D974	0.024		0.27
193		----		----	970		----		----
194		----		----	971	D664	0.017		-0.22
212	D664	0.03		0.69	974	D974	0.021		0.06
217		----		----	994	D664	0.0247		0.32
221		----		----	995	D664	0.024		0.27
224		----		----	996		----		----
225	D974	<0.02	C	----	997	D974	0.015		-0.36
228		----		----	998		----		----
230	D664	0.007		-0.92	1006	D664	0.018		-0.15
238	D974	0.025		0.34	1011	D664	0.022	C	0.13
240		----		----	1017		----		----
242		----		----	1033		----		----
252		----		----	1059	ISO6619	0.032		0.83
253	D664	0.022		0.13	1067	D974	0.016		-0.29
254		----		----	1080		----		----
256	D974	0.0183		-0.13	1081	D664	0.03		0.69
258		----		----	1082		----		----
273		----		----	1095		----		----
311	D664	<0.10		----	1107	D664	<0.001	U	----
312	D974	0.018		-0.15	1109	D974	0.018		-0.15
323	D664	<0.02		----	1121	D664	0.038		1.25
332		----		----	1124		----		----
334	D664	0.01		-0.71	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161	D664	0.012		-0.57
338		----		----	1167		----		----
340	D664	0.02		-0.01	1171		----		----
343	D664	<0.05		----	1182		----		----
344		----		----	1191		----		----
349		----		----	1201	D974	0.02		-0.01
350		----		----	1227	D664	0.01		-0.71
353	IP177	0.0172		-0.21	1229		----		----
356	D974	0.009		-0.78	1259	D664	0.0410		1.46
360	D974	0.010		-0.71	1297	D664	0.03		0.69
430		----		----	1299	D664	0.060	R(0.01)	2.79
431		----		----	1340		----		----
445	D664	0.044		1.67	1379		----		----
447	D664	0.02		-0.01	1382	GB/T7304	0.014		-0.43
463	D664	0.024		0.27	1395	D664	0.0007		-1.36
485		----		----	1409	D664	0.02		-0.01
491		----		----	1417	IP177	0.018		-0.15
493		----		----	1428	D664	0.016		-0.29
494	D664	0.015		-0.36	1430	D664	0.01		-0.71
496	D664	0.024		0.27	1431		----		----
507	D664	0.032		0.83	1457	D974	0.012		-0.57
511		----		----	1459		----		----
541	D664	<0.1		----	1498		----		----
557		----		----	1510	D974	0.022		0.13
562	D664	0.0443		1.69	1521		----		----
575		----		----	1556	D664	0.11	R(0.01)	6.29
603		----		----	1564	D664	0.015		-0.36
604		----		----	1575		----		----
607		----		----	1586	D664	0.016		-0.29
608	D664	0.008		-0.85	1616	D974	0.026		0.41
631	D664	0.029		0.62	1629		----		----
657	D664	0.01		-0.71	1634		----		----
671		----		----	1635	D664	0.09	R(0.01)	4.89
732		----		----	1643	D664	0.022		0.13
759		----		----	1654		----		----
781	D664	0.034		0.97	1677	D664	0.01		-0.71
823	D664	0.014		-0.43	1709		----		----
824	D974	0.013		-0.50	1710	D664	0.025		0.34

1720	D974	0.035		1.04	1872	----	----
1724	D664	0.013		-0.50	1884	D664	0.012
1730	D974	0.014		-0.43	1896	D664	<0.05
1776	D664	0.00	ex	-1.41	1906		----
1792	D664	0.009		-0.78	1938		----
1807		----		----	1944	D664	0.043
1810		----		----	1948	D664	0.0424
1811		----		----	1951	IP139	0.01499
1833	D664	0.0153		-0.34	2129	D664	0.02
1842		----		----	7012		----
1849		----		----			----



normality	OK	
n	81	
outliers	3	+ 1 excl
mean (n)	0.0201	
st.dev. (n)	0.00921	
R(calc.)	0.0258	
R(D974:12)	0.0400	

Lab 1776: result excluded, zero is not a real result

Lab 225: First reported 0.05

Lab 1011: First reported 0.05

Lab 1107: probably a unit error





Determination of Aromatics by FIA on sample #14175; result in %V/V

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854	D1319	24.8		1.85
92	D1319	26.0		2.76	862	EN12916	24.21		1.41
120	D1319	22.4		0.04	863		----		----
132	D1319	24.65		1.74	873		----		----
140		----		----	874		----		----
150	D1319	24.6		1.70	875	D1319	22.8		0.34
158		----		----	887		----		----
159	D1319	25.2		2.16	902		----		----
169		----		----	922	D1319	22.26		-0.07
171	D1319	22.9		0.41	951		----		----
175		----		----	962		----		----
186		----		----	963		----		----
193	D1319	19.2		-2.39	970		----		----
194		----		----	971		----		----
212		----		----	974		----		----
217		----		----	994		----		----
221		----		----	995		----		----
224		----		----	996		----		----
225	D1319	22.7	C	0.26	997		----		----
228		----		----	998		----		----
230	D1319	23.74		1.05	1006		----		----
238		----		----	1011		----		----
240		----		----	1017	D1319	25.16		2.13
242		----		----	1033		----		----
252		----		----	1059	D1319	17.0		-4.05
253	D1319	22.17		-0.14	1067	D1319	26.51		3.15
254		----		----	1080		----		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311		----		----	1107		----		----
312		----		----	1109	D1319	20.81		-1.17
323		----		----	1121		----		----
332		----		----	1124		----		----
334		----		----	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161		----		----
338		----		----	1167		----		----
340		----		----	1171	D1319	17.27		-3.85
343		----		----	1182		----		----
344		----		----	1191		----		----
349		----		----	1201		----		----
350		----		----	1227		----		----
353		----		----	1229		----		----
356		----		----	1259	D1319	23.509075		0.88
360		----		----	1297		----		----
430		----		----	1299	EN12916	24.4		1.55
431		----		----	1340	D1319	22.25		-0.08
445	D1319	26.75		3.33	1379		----		----
447	D1319	19.3		-2.31	1382		----		----
463		----		----	1395		----		----
485		----		----	1409		----		----
491		----		----	1417		----		----
493		----		----	1428		----		----
494		----		----	1430		----		----
496	D1319	12.75	R(0.05)	-7.27	1431		----		----
507		----		----	1457	D1319	21.11		-0.94
511		----		----	1459		----		----
541		----		----	1498		----		----
557		----		----	1510		----		----
562		----		----	1521		----		----
575		----		----	1556		----		----
603		----		----	1564		----		----
604		----		----	1575		----		----
607		----		----	1586	D1319	17.9		-3.37
608		----		----	1616	D1319	23.2		0.64
631	D1319	19.35		-2.27	1629		----		----
657	D1319	23.17		0.62	1634		----		----
671		----		----	1635		----		----
732		----		----	1643		----		----
759		----		----	1654		----		----
781		----		----	1677		----		----
823	D1319	20.94		-1.07	1709		----		----
824	D1319	20.1		-1.70	1710		----		----

1720	----		----	1872	----	----		
1724	----		----	1884	----	----		
1730	----		----	1896	D1319	21.6	-0.57	
1776	----		----	1906	----	----		
1792	----		----	1938	----	----		
1807	----		----	1944	D1319	21	C	-1.02
1810	----		----	1948	----	----		
1811	----		----	1951	D1319	19.3	----	-2.31
1833	----		W	2129	D1319	23.4	----	0.79
1842	D1319	23.0		7012	----	----	----	----
1849	----	----		----	----	----	----	----

normality	OK			<u>Only ASTM D1319</u>				
n	36			OK				
outliers	1			34				
mean (n)	22.352			1				
st.dev. (n)	2.5185			22.237				
R(calc.)	7.052			2.5460				
R(D1319:13)	3.700			7.129				
				3.700				

Lab 225: First reported 48.2
 Lab 1833: Result withdrawn, reported 2.49
 Lab 1944: First reported 71





Determination of Ash on sample #14175; result in %M/M

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D482	0		----	825	D482	0.001		----
53		----		----	854	D482	0.0012		----
92	D482	<0.001		----	862	D482	<0.001		----
120	D482	0.001		----	863	D482	<0.001		----
132	D482	<0.001		----	873	D482	0.0007		----
140		----		----	874	D482	0.001		----
150	D482	<0.001		----	875	D482	0.0010		----
158		----		----	887		----		----
159	D482	0.0005		----	902	D482	0.0007		----
169	D482	0.0000		----	922	D482	<0.001		----
171	D482	0.000		----	951	D482	0.00078		----
175		----		----	962		----		----
186		----		----	963	D482	0.0008		----
193	D482	0.001		----	970		----		----
194		----		----	971	D482	0.0008		----
212	ISO6245	0.002		----	974	D482	0.0010		----
217	D482	0.0009		----	994	D482	0.0008		----
221	D482	<0.001		----	995	D482	0.0008		----
224	D482	0.00013		----	996		----		----
225	D482	0.0005		----	997	D482	0.0009		----
228		----		----	998	D482	0.001		----
230	D482	0.00021		----	1006		----		----
238		----		----	1011	D482	<0.001		----
240		----		----	1017		----		----
242	D482	<0.001		----	1033		----		----
252	D482	<0.001		----	1059	ISO6245	0.0005		----
253	D482	0.0009		----	1067		----		----
254		----		----	1080		----		----
256	D482	<0.001		----	1081	D482	<0.0001		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311	D482	0.001		----	1107		----		----
312		----		----	1109	D482	<0.001		----
323	D482	<0.001		----	1121	IP4	0.0012		----
332		----		----	1124	ISO6245	<0.001		----
334		----		----	1134		----		----
335		----		----	1146	D482	0.00025		----
336		----		----	1159		----		----
337		----		----	1161	ISO6245	0.0001		----
338		----		----	1167	ISO6245	0.0006		----
340	D482	0.0001		----	1171	ISO6245	0.0015		----
343	D482	<0.001		----	1182		----		----
344	D482	0.00093		----	1191		----		----
349		----		----	1201		----		----
350		----		----	1227		----		----
353	ISO6245	0.0017		----	1229		----		----
356	D482	0.0005		----	1259	ISO6245	0.0005955		----
360	D482	0.0009		----	1297		----		----
430		----		----	1299	D482	0.001		----
431		----		----	1340	ISO6245	0.00041		----
445	D482	<0.001		----	1379	INH-1461	0.0002		----
447	D482	0.003	R(0.01)	----	1382	GB/T508	0.0004		----
463	D482	0.0003		----	1395	D482	0.0001		----
485		----		----	1409	D482	0.05	R(0.01)	----
491		----		----	1417		----		----
493		----		----	1428	ISO6245	0.0008		----
494	D482	<0.001		----	1430		----		----
496	D482	0.0000		----	1431		----		----
507	D482	0.0008		----	1457	D482	<0.001		----
511	D482	0.00092		----	1459		----		----
541	D482	<0.001		----	1498		----		----
557		----		----	1510	D482	0.0004		----
562	D482	0.0014		----	1521		----		----
575		----		----	1556	ISO6245	0.0001		----
603	D482	0.0012		----	1564		----	W	----
604		----		----	1575		----		----
607	D482	<0.001		----	1586	D482	0.0002		----
608	D482	<0.001		----	1616	D482	0.0002		----
631	D482	0.0017		----	1629		----		----
657	D482	0.0009		----	1634		----		----
671	D482	0.001		----	1635	D482	0.001		----
732	D482	0.0011		----	1643	D482	<0.001		----
759		----		----	1654		----		----
781	D482	0.0008		----	1677	D482	< 0.001		----
823	D482	0.0008		----	1709		----		----
824	D482	<0.001		----	1710	ISO6245	0.001		----

1720		----		----	1872		----		----
1724	D482	0.0004		----	1884	D482	0.001		----
1730	ISO6245	0.003	R(0.01)	----	1896	D482	0.008	R(0.01)	----
1776		----		----	1906		----		----
1792	D482	0.0007		----	1938		----		----
1807	D482	0.0005		----	1944	D482	0.0015		----
1810		----		----	1948	D482	0.0008		----
1811		----		----	1951	D482	<0.005		----
1833	D482	0.0004		----	2129	D482	0.0004		----
1842	IP4	<0.001		----	7012	D482	0.0018		----
1849	ISO6245	0.0009		----					

normality	OK
n	73
outliers	4
mean (n)	0.00075
st.dev. (n)	0.000454
R(calc.)	0.00127
R(D482:13)	(0.00500)

Lab 1564: Result withdrawn, reported 0.004



Determination of Cetane Index ASTM D976 on sample #14175

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D976	53.3		----	825	D976	53.2		----
53		----		----	854	D976	53.5		----
92	D976	52.98		----	862	D976	53.15		----
120	D976	52.8		----	863	D976	53.5		----
132	D976	53.1		----	873	D976	53.2		----
140	D976	52.8		----	874	D976	53.3		----
150	D976	52.94		----	875		----		----
158		----		----	887	D976	52.9		----
159	D976	53.27		----	902		----		----
169	D976	52.88	E	----	922	D976	53.0		----
171	D976	53.3		----	951	D976	53.40		----
175	D976	53.7		----	962		----		----
186		----		----	963	D976	53.4		----
193	D976	53.18	E	----	970	D976	53.4		----
194		----		----	971	D976	53.3		----
212		----		----	974	D976	53.3		----
217	D976	53.34		----	994	D976	53.3		----
221	D976	52.84		----	995	D976	53.291		----
224	D976	53.05		----	996		----		----
225	D976	53.02		----	997	D976	53.15		----
228	D976	52.8		----	998	D976	53.29		----
230	D976	53.23		----	1006		----		----
238		----		----	1011		----		----
240	D976	53.82	E	----	1017		----		----
242		----		----	1033	D976	53.6		----
252	D976	52.8		----	1059		----		----
253	D976	53.1		----	1067	D976	53.4		----
254	D976	53.1		----	1080		----		----
256	D976	53.1		----	1081	D976	53.5		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311	D976	53.0		----	1107	D976	53.2		----
312	D976	53.4		----	1109		----		----
323	D976	53.5		----	1121	D976	53	E	----
332		----		----	1124		----		----
334		----		----	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161		----		----
338		----		----	1167	D976	52.6	E	----
340		----		----	1171		----		----
343		----		----	1182		----		----
344		----		----	1191		----		----
349		----		----	1201	D976	54.8	R(0.01)	----
350		----		----	1227	D976	52.9	E	----
353		----		----	1229		----		----
356	D976	53.29	E	----	1259		----		----
360	D976	53.07		----	1297	D976	53.2		----
430		----		----	1299		----		----
431		----		----	1340		----		----
445	D976	53.2		----	1379		----		----
447	D976	53.4		----	1382	GB/T11139	52	E,R(0.01)	----
463	D976	53.4		----	1395		----		----
485		----		----	1409		----		----
491		----		----	1417		----		----
493		----		----	1428		----		----
494		----		----	1430		----		----
496		----		----	1431		----		----
507	D976	53.91	E	----	1457	D976	53.2		----
511	D976	52.7		----	1459		----		----
541	D976	53.3		----	1498	D976	53.5		----
557		----		----	1510		----		----
562	D976	53.2		----	1521		----		----
575		----		----	1556		----		----
603		----		----	1564		----		----
604	D976	53.36		----	1575	D976	53.38		----
607		----		----	1586	D976	52.9		----
608		----		----	1616	D976	52.88		----
631	D976	52.60		----	1629		----		----
657	D976	52.9		----	1634		----		----
671		----		----	1635		----		----
732	D976	53.15		----	1643		----		----
759	D976	53.2		----	1654		----		----
781	D976	53.4		----	1677		----		----
823	D976	53.2		----	1709	D976	53.15		----
824	D976	53.5		----	1710	D976	53.4		----

1720		----
1724	D976	53.04
1730		----
1776		----
1792	D976	53.15
1807	D976	53.2
1810		----
1811	D976	53.2
1833		----
1842		----
1849		----

----	1872	----	----
----	1884	D976	52.86
----	1896	D976	53.2
----	1906		----
----	1938		----
----	1944	D976	53.82
----	1948		----
----	1951	D976	53.4
----	2129	D976	53.3
----	7012		----

normality	OK
n	83
outliers	2
mean (n)	53.201
st.dev. (n)	0.2617
R(calc.)	0.733
R(D976:06)	unknown



Recalculated by iis:

OK
84
1
53.225
0.2465
0.690
unknown

Compare R(iis13G04) = 0.776

Recalculated values (= E)

Lab 169:	53.09
Lab 193:	53.54
Lab 240:	53.02
Lab 356:	53.56
Lab 507:	53.567
Lab 1121:	53.63
Lab 1167:	53.16
Lab 1227:	53.51
Lab 1382:	53.43
Lab 1951:	53.70



Determination of Calculated Cetane Index D4737 on sample #14175

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854	D4737	53.6		----
92	D4737	53.14		----	862	D4737-A	52.87		----
120	D4737-A	52.7		----	863	D4737	53.4		----
132	D4737	53.0		----	873	D4737-A	53.1		----
140	D4737-A	52.8		----	874	D4737-A	53.2		----
150	D4737	52.74		----	875		----		----
158		----		----	887	D4737	52.6		----
159	D4737-A	53.51		----	902		----		----
169	D4737	52.04		----	922		----		----
171	D4737	53.4		----	951		----		----
175	D4737	53.6		----	962		----		----
186		----		----	963	D4737	53.4		----
193	D4737	51.3	R(0.05), E	----	970	D4737	53.1		----
194		----		----	971	D4737-A	53.0		----
212	ISO4264	53.4		----	974	D4737-A	53.4		----
217	D4737-A	53.08		----	994	D4737-A	53.0		----
221	D4737-A	52.43		----	995	D4737-A	53.038		----
224		----		----	996		----		----
225	D4737	52.77		----	997	D4737-A	52.86		----
228	D4737-A	52.68		----	998	D4737-A	53.08		----
230	ISO4264	53.12		----	1006		----		----
238		----		----	1011	ISO4264	53.3		----
240	D4737-A	52.49		----	1017		----		----
242		----		----	1033		----		----
252		----		----	1059	ISO4264	52.6		----
253		----		----	1067	D4737-B	54.5	R(0.05), E	----
254	D4737-B	51.6		----	1080	D4737	52.7		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273	D4737	52.91		----	1095		----		----
311		----		----	1107	D4737	53.3		----
312	D4737-A	53.3		----	1109	D4737	53.2		----
323	D4737	53.5		----	1121	IP380	53		----
332		----		----	1124	ISO4264	53.46		----
334		----		----	1134		----		----
335	D4737	53		----	1146		----		----
336	D4737	53.0		----	1159		----		----
337	D4737	53.3		----	1161		----		----
338	ISO4264	53.4		----	1167		----		----
340	ISO4264	53.0		----	1171	ISO4264	52.56	E	----
343		----		----	1182		----		----
344	D4737-A	53.03		----	1191		----		----
349		----		----	1201	D4737	54.9	R(0.05)	----
350		----		----	1227		----		----
353	IP380	52.33		----	1229		----		----
356	D4737-B	51.17	C,R(0.05), E	----	1259	D4737-A	52.47		----
360	D4737-A	52.91		----	1297	D4737-A	53.0	C	----
430		----		----	1299	D4737	52.6		----
431		----		----	1340	ISO4264	53.27	C	----
445	D4737	53.0		----	1379		----		----
447	D4737	53.2		----	1382		----		----
463	D4737-A	53.2		----	1395	D4737	53.2		----
485	D4737-A	53.2		----	1409	D4737	53.5		----
491		----		----	1417		----		----
493		----		----	1428	ISO4264	52.9		----
494	D4737	51.95		----	1430	D4737	51.7	E	----
496	D4737-A	52.83		----	1431		----		----
507	D4737	53.95	E	----	1457	D4737-A	53.0		----
511	D4737-A	52.4		----	1459	D4737	53.2		----
541	D4737	53.1		----	1498		----		----
557		----		----	1510	IP380	52.6		----
562	D4737	52.9		----	1521		----		----
575		----		----	1556	ISO4264-A	52.5		----
603		----		----	1564		----		----
604		----		----	1575	D4737-A	53.32		----
607		----		----	1586	D4737	52.6		----
608		----		----	1616	D4737	52.4		----
631		----		----	1629		----		----
657	D4737	52.7		----	1634		----		----
671		----		----	1635	D4737-A	52.4		----
732		----		----	1643		----		----
759	D4737-A	53.1		----	1654		----		----
781	D4737-A	53.4		----	1677	D4737	53.6		----
823	D4737-A	53.0	E	----	1709	D4737-A	52.88		----
824	D4737-A	53.4		----	1710	ISO4264	53.3		----

1720		----
1724	D4737	52.8
1730	D4737	53.6
1776	ISO4264	52.9
1792	D4737	53.0
1807	D4737	53.0
1810		----
1811		----
1833	D4737	53.10
1842		----
1849	ISO4264	52.91

----	1872	----	----
----	1884	D4737-A	52.48
----	1896	D4737	53.1
----	1906		----
----	1938	ISO4264	52.84
----	1944	D4737-A	53.74
----	1948	D4737	52.97
----	1951		----
----	2129	IP380	53.2
----	7012		----

normality	suspect
n	97
outliers	4
mean (n)	52.983
st.dev. (n)	0.4144
R(calc.)	1.160
R(D4737:10)	unknown

Recalculated by iis



OK
99
2
52.997
0.3922
1.098
unknown

Compare R(iis13G04) = 0.951

Lab 356: First reported 50.63
 Lab 1297: First reported 50.5
 Lab 1340: Result was reported under D976

Recalculated values (= E)

Lab 193:	53.72
Lab 356:	52.97
Lab 507:	53.51
Lab 823:	53.27
Lab 1067:	52.76
Lab 1171:	52.34
Lab 1430:	54.85





Determination of Cloud Point on sample #14175; result in °C,

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825	D2500	-7		0.44
53	D2500	-8		-0.26	854	D2500	-6		1.14
92	D2500	-8		-0.26	862	D2500	-7		0.44
120	D2500	-7		0.44	863	D2500	-7		0.44
132	D2500	-8		-0.26	873	D2500	-7		0.44
140	D5773	-7.7		-0.05	874	D2500	-7		0.44
150	D2500	-9	C	-0.96	875	D2500	-7		0.44
158	D2500	-5		1.84	887	D2500	-8		-0.26
159	D2500	-9.0		-0.96	902	D2500	-7		0.44
169	D2500	-4	R(0.01)	2.54	922	D2500	-8.0		-0.26
171	D2500	-9.0		-0.96	951	D2500	-9		-0.96
175	D2500	-8		-0.26	962		----		----
186		----		----	963	D2500	-7		0.44
193	D2500	-6.0		1.14	970		----		----
194		----		----	971	D2500	-8		-0.26
212	ISO3015	-10		-1.66	974	D2500	-8		-0.26
217	D2500	-8		-0.26	994	D2500	-7		0.44
221	D2500	-6		1.14	995	D2500	-7		0.44
224	D2500	-9	C	-0.96	996		----		----
225	D2500	-7		0.44	997	D2500	-7		0.44
228	D2500	-7		0.44	998	D2500	-7.0		0.44
230	D2500	-7.0		0.44	1006		----		----
238	D2500	-8		-0.26	1011	D2500	-7	C	0.44
240	D2500	-8		-0.26	1017	D5771	-8		-0.26
242		----		----	1033	IP219	-8.4		-0.54
252	D2500	-7.0		0.44	1059	EN23015	-8		-0.26
253	D2500	-6		1.14	1067	D5771	-8.0		-0.26
254	D2500	-5.0		1.84	1080	D2500	-7.7		-0.05
256	D2500	-8.0		-0.26	1081	D5771	-7.7		-0.05
258		----		----	1082	D7689	-7.5		0.09
273	D2500	-8		-0.26	1095		----		----
311	D5771	-8		-0.26	1107	D2500	-8		-0.26
312	D2500	-8		-0.26	1109	D5773	-7.0		0.44
323	D2500	-8		-0.26	1121	IP219	-8		-0.26
332		----		----	1124	ISO3015	-6.0		1.14
334	D2500	-8.0		-0.26	1134		----		----
335	D2500	-8		-0.26	1146	D2500	-7.6		0.02
336	D2500	-8		-0.26	1159		----		----
337	D2500	-7.5		0.09	1161	D2500	-8		-0.26
338	EN23015	-7.7		-0.05	1167	EN23015	-7		0.44
340	EN23015	-7.4		0.16	1171	ISO3015	-8.0		-0.26
343	D2500	-7		0.44	1182	D5773	-7.1		0.37
344	D2500	-7.1		0.37	1191	D5773	-7.6		0.02
349		----		----	1201	D2500	-7		0.44
350		----		----	1227	D2500	-8		-0.26
353	IP219	-7		0.44	1229	D7689	-8.3		-0.47
356	D2500	-8		-0.26	1259	D2500	-7		0.44
360	D2500	-8		-0.26	1297	D5771	-7.7		-0.05
430		----		----	1299	D2500	-7.3		0.23
431		----		----	1340	D2500	-7.2		0.30
445	D2500	-8		-0.26	1379	INH-5066	-9		-0.96
447		----		----	1382		----		----
463	D2500	-8.0		-0.26	1395	D2500	-8		-0.26
485		----		----	1409	D2500	-8		-0.26
491		----		----	1417	IP444	-7		0.44
493		----		----	1428	EN23015	-8		-0.26
494	D2500	-8		-0.26	1430	D5771	-7.4		0.16
496	D2500	-8.0		-0.26	1431		----		----
507	D2500	-8	C	-0.26	1457	D2500	-8.11		-0.34
511		----		----	1459	EN23015	-9		-0.96
541	D2500	-8		-0.26	1498	D2500	-8		-0.26
557		----		----	1510	D2500	-8		-0.26
562	D2500	-7.0		0.44	1521		----		----
575		----		----	1556	ISO3015	-9		-0.96
603		----		----	1564	D5772	-7.0		0.44
604	D2500	-10		-1.66	1575		----		----
607		----		----	1586	D2500	-8		-0.26
608	D2500	-2	R(0.01)	3.94	1616	D2500	-9		-0.96
631	D2500	-8		-0.26	1629		----		----
657	D2500	-7		0.44	1634		----		----
671	D2500	-6		1.14	1635	D2500	-8.6		-0.68
732	D2500	-8		-0.26	1643	D2500	-7		0.44
759	D2500	-7		0.44	1654		----		----
781	D2500	-7		0.44	1677	D2500	-8		-0.26
823	D2500	-7		0.44	1709	D2500	-8		-0.26
824	D2500	-8		-0.26	1710	EN23015	-8		-0.26

1720	D5773	-8.4	-0.54	1872	-----	-----
1724	D2500	-7	0.44	1884	D2500	-7.8
1730	D2500	-8	-0.26	1896	D5771	-7.5
1776	EN23015	-7.8	-0.12	1906	-----	-----
1792	D2500	-7	0.44	1938	-----	-----
1807	D2500	-6	1.14	1944	D2500	-9
1810	D2500	-8	-0.26	1948	D2500	-7
1811	D2500	-7	0.44	1951	D2500	-3.1
1833	D2500	-7	0.44	2129	IP444	-9
1842	D2500	-8	-0.26	7012	-----	-----
1849	-----	-----	-----			

normality	suspect
n	132
outliers	3
mean (n)	-7.63
st.dev. (n)	0.828
R(calc.)	2.33
R(D2500:11)	4.00

Lab 150: first reported -10
 Lab 224: first reported -15
 Lab 507: first reported -3
 Lab 1011: first reported -2





Determination of Cold Filter Plugging Point on sample #14175; result in °C

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825	D6371	-25		-0.20
53		----		----	854		----		----
92		----		----	862		----		----
120		----		----	863	D6371	-22		1.46
132		----		----	873	D6371	-22		1.46
140		----		----	874	D6371	-21		2.02
150	D6371	-24.0		0.36	875	IP309	-23		0.91
158		----		----	887		----		----
159		----		----	902		----		----
169		----		----	922	D6371	-23.0		0.91
171	D6371	-23.0		0.91	951		----		----
175		----		----	962		----		----
186		----		----	963	IP309	-22		1.46
193		----		----	970		----		----
194		----		----	971		----		----
212		----		----	974		----		----
217	D6371	-22		1.46	994	D6371	-23		0.91
221		----		----	995	D6371	-22		1.46
224		----		----	996		----		----
225		----		----	997	D6371	-21		2.02
228		----		----	998	D6371	-21.0		2.02
230	IP309	-23.0		0.91	1006	D6371	-27		-1.30
238		----		----	1011		----		----
240		----		----	1017	EN116	-24		0.36
242		----		----	1033	IP309	-28		-1.85
252	IP309	-23.0		0.91	1059	EN116	-25		-0.20
253		----		----	1067	EN116	-27.0		-1.30
254		----		----	1080	D6371	-26.7		-1.14
256	IP309	-22.0		1.46	1081	EN116	-28		-1.85
258		----		----	1082	EN116	-24		0.36
273	IP309	-18	C	3.67	1095		----		----
311	EN116	-25		-0.20	1107	IP309	-21		2.02
312	D6371	-24		0.36	1109	IP309	-28.0		-1.85
323	D6371	-27		-1.30	1121	IP309	-22		1.46
332		----		----	1124	EN116	-24		0.36
334	EN116	-26.0		-0.75	1134		----		----
335	EN116	-27		-1.30	1146		----		----
336	EN116	-25		-0.20	1159		----		----
337	D6371	-24		0.36	1161	EN116	-22		1.46
338	EN116	-22		1.46	1167	EN116	-22		1.46
340	EN116	-27.0		-1.30	1171	EN116	-21.0		2.02
343	D6371	-30		-2.96	1182	EN116	-26		-0.75
344	EN116	-26		-0.75	1191	EN116	-28		-1.85
349		----		----	1201	EN116	-25		-0.20
350	EN116	-25.0		-0.20	1227	EN116	-22		1.46
353	IP309	-26		-0.75	1229	EN116	-24.5		0.08
356	D6371	-25		-0.20	1259	D6371	-28		-1.85
360	D6371	-25		-0.20	1297	D6371	-26		-0.75
430		----		----	1299	IP309	-24		0.36
431	EN116	-26		-0.75	1340	EN116	-26		-0.75
445	D6371	-27		-1.30	1379		----		----
447	IP309	-24		0.36	1382	SH/T0248	-21		2.02
463	EN116	-26		-0.75	1395	D6371	-28		-1.85
485		----		----	1409	EN116	-29		-2.41
491		----		----	1417		----		----
493		----		----	1428	EN116	-20		2.57
494	EN116	-27		-1.30	1430	EN116	-28		-1.85
496	D6371	-29.0		-2.41	1431	D6371	-29		-2.41
507		----		----	1457	D6371	-27		-1.30
511		----		----	1459	EN116	-24		0.36
541	D6371	-26		-0.75	1498	D6371	-21		2.02
557		----		----	1510		----		----
562	D6371	-22		1.46	1521	EN116	-28		-1.85
575		----		----	1556	EN116	-26		-0.75
603		----		----	1564	IP309	-28.0		-1.85
604		----		----	1575		----		----
607		----		----	1586	D6371	-26		-0.75
608		----		----	1616	D6371	-21		2.02
631		----		----	1629		----		----
657	D6371	-27		-1.30	1634		----		----
671		----		----	1635	D6371	-26		-0.75
732	D6371	-22		1.46	1643		----		----
759	D6371	-21		2.02	1654		----		----
781	D6371	-22		1.46	1677	EN116	-26.5		-1.03
823	D6371	-26		-0.75	1709	D6371	-26		-0.75
824	D6371	-24		0.36	1710	EN116	-27		-1.30

1720		-----		-----	1872		-----		-----
1724	IP309	-25		-0.20	1884		-----		-----
1730	EN116	-23		0.91	1896	EN116	-26		-0.75
1776	EN116	-25		-0.20	1906		-----		-----
1792	EN116	-26		-0.75	1938	EN116	-25		-0.20
1807	D6371	-24		0.36	1944	D6371	-24		0.36
1810	EN116	-23		0.91	1948	D6371	-20		2.57
1811	EN116	-23.5		0.63	1951	D6371	-13.0	R(0.01)	6.44
1833	D6371	-27		-1.30	2129	D6371	-28		-1.85
1842	IP309	-25		-0.20	7012		-----		-----
1849	EN116	-25		-0.20					

normality OK
 n 104
 outliers 1
 mean (n) -24.65
 st.dev. (n) 2.474
 R(calc.) 6.93
 R(D6371:05) 5.06

Lab 273: First reported -11





Determination of Colour ASTM on sample #14175;

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D6045	0.7		0.41	825	D1500	L1.0		----
53		----		----	854	D1500	L1		----
92	D1500	0.5		-0.15	862	D1500	L0.5		----
120	D1500	L1.0		----	863	D1500	0.5		-0.15
132	D1500	0.5		-0.15	873	D1500	0.5		-0.15
140	D1500	L1.0		----	874	D1500	0.5		-0.15
150	D1500	L1.0		----	875	D6045	0.7		0.41
158	D1500	0.5		-0.15	887	D1500	0.5		-0.15
159	D1500	0.6		0.13	902	D1500	0.7		0.41
169	D6045	0.6		0.13	922	D1500	L0.5		----
171	D1500	<1.0		----	951	D1500	0.5		-0.15
175		----		----	962	D1500	0.7		0.41
186		----		----	963	D1500	0.7		0.41
193	D1500	<0.5		----	970	D1500	L0.5		----
194		----		----	971	D1500	0.5		-0.15
212	D1500	0.5		-0.15	974	D1500	0.5		-0.15
217	D1500	0.5		-0.15	994	D1500	0.5		-0.15
221	D1500	L0.5		----	995	D1500	0.5		-0.15
224	D1500	0.5		-0.15	996		----		----
225	D1500	1.0	R(0.01)	1.25	997	D1500	0.5		-0.15
228	D1500	0.5		-0.15	998	D1500	0.5		-0.15
230	D1500	0.5		-0.15	1006		----		----
238	D1500	0.5		-0.15	1011	D1500	L0.5		----
240	D1500	0.5		-0.15	1017		----		----
242		----		----	1033	D1500	1.5	R(0.01)	2.65
252	D1500	0.5		-0.15	1059	D1500	0.5		-0.15
253	D1500	0.5		-0.15	1067	D6045	0.6		0.13
254	D1500	0.5		-0.15	1080	D1500	0.6		0.13
256	D1500	0.5		-0.15	1081	D6045	L1.0		----
258	D6756	0.5		-0.15	1082		----		----
273	D1500	L0.5		----	1095		----		----
311	D1500	L0.5		----	1107	D1500	L1.0		----
312	D1500	<1.0		----	1109	D6045	0.6		0.13
323	D1500	L1.0		----	1121	D1500	L1.0		----
332		----		----	1124		----		----
334		----		----	1134		----		----
335	D1500	1	R(0.01)	1.25	1146		----		----
336	D1500	0.5		-0.15	1159		----		----
337	D1500	0.5		-0.15	1161	D1500	0.6		0.13
338	D1500	0.5		-0.15	1167		----		----
340	D1500	0.5		-0.15	1171	D1500	1.26	R(0.01)	1.98
343	D1500	L1.0		----	1182	D1500	0.7		0.41
344	D1500	0.5		-0.15	1191		----		----
349	D6045	<1.0		----	1201	D1500	0.5		-0.15
350		----		----	1227	D1500	0.5		-0.15
353	D6045	0.7		0.41	1229		----		----
356	D6045	0.7		0.41	1259	D1500	L0.5		----
360	D1500	0.5		-0.15	1297	D1500	0.5		-0.15
430		----		----	1299	D6045	0.7		0.41
431		----		----	1340	D1500	0.6		0.13
445	D1500	L1.0		----	1379	D1500	1	R(0.01)	1.25
447	D6045	0.6		0.13	1382	GB/T6540	0.5		-0.15
463	D1500	0.5		-0.15	1395	D1500	<1.0		----
485		----		----	1409	D1500	<1		----
491		----		----	1417	D6045	0.7		0.41
493		----		----	1428	D6045	0.7		0.41
494	D1500	L0.5		----	1430	D1500	0.5		-0.15
496	D1500	1.0	R(0.01)	1.25	1431	D1500	0.5		-0.15
507	D1500	0.5		-0.15	1457	D1500	L1.0		----
511	D6045	0.5		-0.15	1459	D1500	L0.5		----
541	D1500	L0.5		----	1498		----		----
557		----		----	1510	D1500	L1.0		----
562	D1500	L1.0		----	1521		----		----
575		----		----	1556	ISO2049	0.5		-0.15
603	D1500	0.5		-0.15	1564		----		----
604	D1500	L1.0		----	1575	D1500	0.71		0.44
607		----		----	1586	D1500	0.7		0.41
608	D1500	0.5		-0.15	1616	D6045	0.7		0.41
631	D1500	<1.0		----	1629		----		----
657	D1500	0.5		-0.15	1634		----		----
671	D1500	0.5		-0.15	1635	D1500	0.5		-0.15
732	D1500	0.5		-0.15	1643		----		----
759	D6045	0.7		0.41	1654		----		----
781	D1500	0.5		-0.15	1677	D1500	0.5		-0.15
823	D1500	0.5		-0.15	1709		----		----
824	D1500	L1.0		----	1710	ISO2049	0.5		-0.15

1720		----	----	1872		----	----
1724		----	----	1884	D1500	0.6	0.13
1730	D1500	L1.0	----	1896	D1500	<1.0	----
1776	D1500	0.5	-0.15	1906		----	----
1792	D1500	L0.5	----	1938		----	----
1807	D1500	< 0.5	----	1944	D1500	1	R(0.01) 1.25
1810		----	----	1948	D1500	0.7	0.41
1811		----	----	1951	D1500	<0.5	----
1833	D1500	0.6	0.13	2129	D6045	0.7	0.41
1842	D1500	0.5	-0.15	7012		----	----
1849		----	----				

normality	suspect	Only D6045
n	82	OK
outliers	7	18
mean (n)	0.55	0
st.dev. (n)	0.082	0.63
R(calc.)	0.23	0.084
R(D1500:12)	1.00	0.24
		0.48





Determination of Conradson Carbon Residue on 10% residue on sample #14175; result in %M/M

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854	D4530	0.008		-1.21
92		----		----	862	D4530	0.02		-0.03
120		----		----	863		----		----
132		----		----	873	D189	0.030		0.96
140		----		----	874		----		----
150		----		----	875		----		----
158		----		----	887		----		----
159		----		----	902	D4530	0.01		-1.01
169		----		----	922	D189	0.0151		-0.51
171	D189	0.01676		-0.34	951	D189	0.028		0.76
175		----		----	962		----		----
186		----		----	963	D189	0.019		-0.12
193		----		----	970		----		----
194		----		----	971	D189	0.013		-0.71
212	ISO10370	0.028		0.76	974		----		----
217		----		----	994	D189	0.0185		-0.17
221	D189	0.05	R(0.05)	2.92	995	D189	0.017		-0.32
224	D189	<0.001		----	996		----		----
225		----		----	997	D189	0.018		-0.22
228	D189	0.02		-0.03	998	D189	0.018		-0.22
230	D189	0.049	R(0.05)	2.82	1006		----		----
238		----		----	1011		----		----
240		----		----	1017		----		----
242		----		----	1033		----		----
252	D4530	0.0278		0.74	1059	ISO10370	0.018		-0.22
253		----		----	1067		----		----
254	D189	0.029		0.86	1080		----		----
256		----		----	1081	ISO10370	0.02		-0.03
258		----		----	1082		----		----
273	D4530	0.03		0.96	1095		----		----
311		----		----	1107	D4530	0.02		-0.03
312		----		----	1109	D4530	<0.1		----
323		----		----	1121	IP398	0.01		-1.01
332		----		----	1124	ISO10370	0.035		1.45
334		----		----	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161	ISO10370	0.02		-0.03
338		----		----	1167	ISO10370	0.035		1.45
340	ISO10370	0.03		0.96	1171	ISO6615	0.013		-0.71
343		----		----	1182		----	W	----
344	D4530	0.01969		-0.06	1191		----		----
349		----		----	1201	D4530	0	ex	-1.99
350		----		----	1227	D4530	0.00	ex	-1.99
353	IP13	0.003		-1.70	1229		----		----
356	D189	0.024		0.37	1259	ISO10370	0.0098305		-1.03
360	D189	0.020		-0.03	1297		----		----
430		----		----	1299	D4530	0.03		0.96
431		----		----	1340	ISO10370	0.0214		0.11
445		----		----	1379		----		----
447	IP398	0.02		-0.03	1382	GB/T268	0.018		-0.22
463		----		----	1395		----		----
485		----		----	1409	D189	0.02		-0.03
491		----		----	1417		----		----
493		----		----	1428	ISO10370	0.030		0.96
494	D4530	0.03		0.96	1430	D189	0.035		1.45
496		----		----	1431		----		----
507	D189	0.012		-0.81	1457	D4530	0.017		-0.32
511	D189	0.0187		-0.15	1459		----		----
541	D189	0.009		-1.11	1498		----		----
557		----		----	1510	D189	0.014		-0.62
562	D189	0.0164		-0.38	1521		----		----
575		----		----	1556	ISO10370	0.001		-1.89
603		----		----	1564		----		----
604		----		----	1575	D4530	0.020		-0.03
607		----		----	1586	D189	0.02		-0.03
608		----		----	1616	D4530	0.009		-1.11
631	D4530	0.03		0.96	1629		----		----
657	D189	0.03		0.96	1634		----		----
671	D4530	0.007		-1.30	1635	D189	0.05	R(0.05)	2.92
732		----		----	1643		----		----
759		----		----	1654		----		----
781	D4530	0.027		0.66	1677	D4530	0.015		-0.52
823	D189	0.019		-0.12	1709		----		----
824		----		----	1710	ISO10370	0.012		-0.81

1720		----			1872	----		
1724	D4530	0.01		-1.01	1884	D189	0.019	-0.12
1730	ISO10370	0.03		0.96	1896	ISO10370	<0.10	----
1776		----		----	1906		----	----
1792	D4530	0.020		-0.03	1938		----	----
1807		----		----	1944	D189	0.0332	1.27
1810		----		----	1948	D189	0.0319	1.14
1811		----		----	1951	D189	<0.01	----
1833	D4530	0.03		0.96	2129	IP398	0.007	-1.30
1842	D189	0.0	ex	-1.99	7012	D189	0.02	C -0.03
1849	ISO10370	0.032		1.15				

normality OK
 n 67
 outliers 3 + 3 excl.
 mean (n) 0.0203
 st.dev. (n) 0.00837
 R(calc.) 0.0234
 R(D189:06e1) 0.0285

Lab 1182: Result withdrawn, reported 0.087
 Lab 1201: result excluded, zero is not a real result
 Lab 1227: result excluded, zero is not a real result
 Lab 1842: result excluded, zero is not a real result





Determination of Ramsbottom Carbon Residue on 10% residue on sample #14175; result in %M/M

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854		----		----
92		----		----	862		----		----
120	D524	0.08		1.34	863		----		----
132	D524	0.0354		-2.80	873		----		----
140	D524	0.0485		-1.58	874		----		----
150	D524	0.08		1.34	875		----		----
158		----		----	887		----		----
159		----		----	902		----		----
169	D524	0.0666		0.10	922		----		----
171	D524	0.07383		0.77	951		----		----
175	D524	0.08		1.34	962		----		----
186		----		----	963		----		----
193		----		----	970		----		----
194		----		----	971	D524	0.06		-0.51
212		----		----	974		----		----
217		----		----	994		----		----
221		----		----	995		----		----
224		----		----	996		----		----
225		----		----	997		----		----
228		----		----	998		----		----
230		----		----	1006	D524	0.072		0.60
238		----		----	1011	D524	<0.04		----
240		----		----	1017		----		----
242		----		----	1033		----		----
252		----		----	1059		----		----
253		----		----	1067		----		----
254		----		----	1080		----		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311		----		----	1107		----		----
312		----		----	1109		----		----
323		----		----	1121		----		----
332		----		----	1124		----		----
334		----		----	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161		----		----
338		----		----	1167		----		----
340		----		----	1171		----		----
343	D4530	<0.1	ex	----	1182		----		----
344		----		----	1191		----		----
349		----		----	1201		----		----
350		----		----	1227		----		----
353		----		----	1229		----		----
356		----		----	1259		----		----
360		----		----	1297		----		----
430		----		----	1299		----		----
431		----		----	1340		----		----
445	D524	0.09		2.27	1379		----		----
447		----		----	1382		----		----
463		----		----	1395		----		----
485		----		----	1409		----		----
491		----		----	1417		----		----
493		----		----	1428		----		----
494		----		----	1430		----		----
496		----		----	1431		----		----
507		----		----	1457		----		----
511	D524	0.06		-0.51	1459		----		----
541		----		----	1498		----		----
557		----		----	1510		----		----
562		----		----	1521		----		----
575		----		----	1556		----		----
603		----		----	1564		----		----
604		----		----	1575		----		----
607		----		----	1586		----		----
608		----		----	1616		----		----
631		----		----	1629		----		----
657	D524	0.04		-2.37	1634		----		----
671		----		----	1635		----		----
732		----		----	1643		----		----
759		----		----	1654		----		----
781		----		----	1677		----		----
823		----		----	1709		----		----
824		----		----	1710		----		----

1720	----	----	1872	----	----
1724	----	----	1884	----	----
1730	----	----	1896	D524	<0.1
1776	----	----	1906	----	----
1792	----	----	1938	----	----
1807	----	----	1944	----	----
1810	----	----	1948	----	----
1811	----	----	1951	----	----
1833	----	----	2129	----	----
1842	----	----	7012	----	----
1849	----	----			

normality OK
n 12
outliers 0
mean (n) 0.0655
st.dev. (n) 0.01719
R(calc.) 0.0481
R(D524:10) 0.0301

Lab 343: result excluded, the used test method is not equivalent with ASTM D524



Determination of Copper Corrosion (3 hrs @ 50°C) on sample #14175;

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D130	1A		----	825	D130	1A		----
53		----		----	854	D130	1A		----
92	D130	1A		----	862	D130	1A		----
120	D130	1A		----	863	D130	1A		----
132	D130	1A		----	873	D130	1A		----
140	D130	1A		----	874	D130	1A		----
150	D130	1A		----	875	D130	1A		----
158	D130	1A		----	887	D130	<1A		----
159	D130	1A		----	902		----		----
169	D130	1A		----	922	D130	1A		----
171	D130	1A		----	951	D130	1		----
175	D130	1A		----	962	D130	1A		----
186		----		----	963	D130	1A		----
193	D130	1B		----	970	D130	1A		----
194		----		----	971	D130	1A		----
212	D130	1A		----	974	D130	1A		----
217	D130	1A		----	994	D130	1A		----
221	D130	1A		----	995	D130	1A		----
224	D130	1A		----	996		----		----
225	D130	1A		----	997		----		----
228	D130	1A		----	998		----		----
230	D130	1A		----	1006	D130	1A		----
238	D130	1A		----	1011	D130	1B		----
240	D130	1A		----	1017	D130	1A		----
242		----		----	1033	IP154	1A		----
252	D130	1A		----	1059	ISO2160	1A		----
253	D130	1A		----	1067	D130	1A		----
254	D130	1A		----	1080		----		----
256	D130	1A		----	1081	D130	1B		----
258	D130	1A		----	1082		----		----
273	D130	1A		----	1095		----		----
311	D130	1A		----	1107	D130	1B		----
312	D130	1A		----	1109	D130	1A		----
323	D130	1A		----	1121	IP154	1A		----
332		----		----	1124	ISO2160	1A		----
334		----		----	1134		----		----
335	D130	1A		----	1146		----		----
336	D130	1A		----	1159		----		----
337		----		----	1161	ISO2160	1A		----
338		----		----	1167	D130	1A		----
340	D130	1A		----	1171	ISO2160	1A		----
343	D130	1A		----	1182	D130	1A		----
344	D130	1A		----	1191		----		----
349		----		----	1201	D130	1A		----
350		----		----	1227	D130	1A		----
353	IP154	1A		----	1229		----		----
356	D130	1A		----	1259	D130	1A		----
360	D130	1A		----	1297	D130	1A		----
430		----		----	1299	D130	1A		----
431		----		----	1340	ISO2160	1A		----
445	D130	1A		----	1379		----		----
447	D130	1A		----	1382	GB/T5096	1A		----
463	D130	1A		----	1395	D130	1A		----
485		----		----	1409	D130	1A		----
491		----		----	1417	D130	1A		----
493		----		----	1428	ISO2160	1A		----
494		----		----	1430	D130	1B		----
496	D130	1A		----	1431	D130	1A		----
507	D130	1A		----	1457	D130	1A		----
511	D130	1A		----	1459		----		----
541		1A		----	1498		----		----
557		----		----	1510	D130	1A		----
562	D130	1A		----	1521		----		----
575		----		----	1556	ISO2160	1		----
603	D130	1A		----	1564		----		----
604		----		----	1575	D130	1A		----
607		----		----	1586	D130	1A		----
608	D130	1A		----	1616	D130	1A		----
631	D130	1A		----	1629		----		----
657	D130	1A		----	1634	D130	1A		----
671	D130	1A		----	1635		----		----
732		----		----	1643		----		----
759		----		----	1654		----		----
781	D130	1A		----	1677	D130	1A		----
823	D130	1A		----	1709		----		----
824	D130	1A		----	1710	ISO2160	1A		----

1720		----	----	1872	ISO2160	1	----
1724	D130	1A	----	1884	D130	1A	----
1730	D130	1A	----	1896	ISO2160	1	----
1776	ISO2160	1A	----	1906		----	----
1792	D130	1A	----	1938		----	----
1807	D130	1A	----	1944	D130	1A	----
1810		----	----	1948	D130	1A	----
1811		----	----	1951	D130	1A	----
1833	D130	1A	----	2129	D130	1A	----
1842	IP154	1A	----	7012	D130	1A	----
1849	ISO2160	1A	----				

normality	unknown
n	124
outliers	0
mean (n)	1(1A)
st.dev. (n)	n.a.
R(calc.)	n.a.
R(D130:12)	n.a.



Determination of Density @15 °C on sample #14175; result in kg/m³

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D4052	835.7		-0.16	825	D4052	835.7		-0.16
53	D4052	835.6		-0.72	854	D4052	835.8		0.40
92	D4052	835.8		0.40	862	D4052	835.71		-0.11
120	D4052	835.9		0.96	863	D4052	835.8		0.40
132	D4052	835.72		-0.05	873	D4052	835.9		0.96
140	D4052	835.8		0.40	874	D4052	835.6		-0.72
150	D4052	835.9		0.96	875	D4052	835.8		0.40
158	D4052	834.9	R(0.01)	-4.64	887	D4052	835.7		-0.16
159	D4052	835.8		0.40	902	D4052	835.9		0.96
169	D4052	835.7		-0.16	922	D4052	835.7		-0.16
171	D4052	835.70		-0.16	951	D1298	835.7		-0.16
175	D4052	835.7		-0.16	962	D4052	835.7		-0.16
186		-----		-----	963	D4052	835.7		-0.16
193	D4052	835.4		-1.84	970	D4052	835.9		0.96
194		-----		-----	971	D4052	835.8		0.40
212	ISO12185	835.7		-0.16	974	D4052	835.7		-0.16
217	D4052	835.5		-1.28	994	D4052	835.7		-0.16
221	D4052	835.8		0.40	995	D4052	835.72		-0.05
224	D1298	835.8		0.40	996		-----		-----
225	D4052	835.6		-0.72	997	D4052	835.8		0.40
228	D1298	836.0		1.52	998	D4052	835.7		-0.16
230	D1298	835.7		-0.16	1006	D4052	835.8		0.40
238	D4052	835.65		-0.44	1011	D4052	835.6		-0.72
240	D4052	835.9		0.96	1017	D4052	835.7		-0.16
242	D4052	835.9		0.96	1033	IP365	836.0		1.52
252	D1298	835.84		0.62	1059	ISO12185	835.7		-0.16
253	D4052	835.6		-0.72	1067	D4052	835.7		-0.16
254	D4052	835.8		0.40	1080	D4052	835.7		-0.16
256	D4052	835.8		0.40	1081	ISO12185	835.8		0.40
258	D1298	835.8		0.40	1082	ISO12185	835.7		-0.16
273	D4052	835.5		-1.28	1095		-----		-----
311	D4052	835.7		-0.16	1107	D4052	835.7	C	-0.16
312	D4052	835.6		-0.72	1109	D4052	835.75		0.12
323	D4052	835.5		-1.28	1121	IP365	835.9		0.96
332	ISO12185	835.7		-0.16	1124	ISO12185	835.664		-0.36
334	D4052	835.7		-0.16	1134		-----		-----
335	D4052	835.7		-0.16	1146	D4052	835.73		0.01
336	D4052	835.7		-0.16	1159		-----		-----
337	D4052	835.7		-0.16	1161	ISO12185	835.59		-0.78
338	ISO12185	835.7		-0.16	1167	D4052	835.78		0.29
340	D4052	835.81		0.45	1171	D4052	835.62	C	-0.61
343	D4052	835.67		-0.33	1182	ISO12185	835.743		0.08
344	D4052	835.8		0.40	1191	ISO12185	835.7		-0.16
349	D4052	835.3	R(0.05)	-2.40	1201	D4052	830.7	R(0.01)	-28.16
350	ISO3675	836.0		1.52	1227	D4052	835.7		-0.16
353	IP365	835.8		0.40	1229	ISO12185	835.81		0.45
356	D4052	835.73		0.01	1259		-----		-----
360	D4052	835.8		0.40	1297	D4052	835.7		-0.16
430		-----		-----	1299	D4052	835.6		-0.72
431	ISO12185	835.49		-1.34	1340	ISO12185	835.7		-0.16
445	D4052	835.7		-0.16	1379	D4052	835.8		0.40
447	D4052	835.7		-0.16	1382	SH/T0604	835.3	R(0.05)	-2.40
463	D4052	835.70		-0.16	1395	D4052	835.7		-0.16
485	D4052	835.6		-0.72	1409	D4052	835.7		-0.16
491	D4052	835.69		-0.22	1417	IP365	835.7		-0.16
493		-----		-----	1428	ISO12185	835.7		-0.16
494	D4052	835.7		-0.16	1430	D4052	835.7		-0.16
496	D4052	835.69		-0.22	1431	D4052	835.8		0.34
507	D4052	835.8	C	0.40	1457	D4052	835.7		-0.16
511	D4052	835.61		-0.67	1459	ISO12185	835.7		-0.16
541	D4052	835.8		0.40	1498	D1298	835.6		-0.72
557		-----		-----	1510	D4052	835.7	C	-0.16
562	D4052	835.95		1.24	1521		-----		-----
575		-----		-----	1556	ISO12185	835.86		0.73
603	D4052	835.7		-0.16	1564	D4052	835.6		-0.72
604	D4052	835.84		0.62	1575	D4052	835.5		-1.28
607	D1298	835.8		0.40	1586	D4052	835.7		-0.16
608	D4052	835.9		0.96	1616	D4052	835.73		0.01
631	D4052	835.9		0.96	1629		-----		-----
657	D4052	835.8		0.40	1634	D4052	835.699		-0.17
671	D4052	835.9		0.96	1635		-----		-----
732	D4294	835.8		0.40	1643	D4052	835.9		0.96
759	D4052	835.61		-0.67	1654		-----		-----
781	D4052	835.7		-0.16	1677	D4052	835.7		-0.16
823	D4052	835.88		0.85	1709	D4052	835.7		-0.16
824	ISO12185	835.6		-0.72	1710	ISO12185	835.7		-0.16

1720	D4052	835.7	-0.16	1872	ISO12185	835.72	-0.05
1724	D4052	835.93	1.13	1884	D4052	835.82	0.51
1730	ISO12185	835.5	-1.28	1896	ISO12185	835.7	-0.16
1776	ISO12185	835.7	-0.16	1906		-----	-----
1792	D4052	835.7	-0.16	1938	ISO12185	835.8	0.40
1807	D4052	835.8	0.40	1944	D1298	835.38	-1.95
1810	D4052	835.7	-0.16	1948	D4052	835.8	0.40
1811	D4052	835.7	-0.16	1951	D4052	835.8	0.40
1833	D4052	835.7	-0.16	2129	D4052	835.7	-0.16
1842	D4052	835.6	-0.72	7012		-----	-----
1849	ISO12185	835.783	0.30				

normality OK
 n 152
 outliers 4
 mean (n) 835.73
 st.dev. (n) 0.108
 R(calc.) 0.30
 R(D4052:11) 0.50

Lab 242: First reported 853.9
 Lab 507: First reported 0.8348
 Lac 1107: First reported 0.8357
 Lab 1171: First reported 835.12
 Lab 1951: Reported 0.8358



Determination of Distillation (automated) on sample #14175; result in °C

lab	method	IBP	mark	10% rec	mark	50%rec	mark	90%rec	mark	95%rec	mark	FBP	mark
52	D86	168.0		207.9		273.1		329.4		344.6		354.2	
53		----		----		----		----		----		----	
92	D86	173.6		211.7		272.5		328.9		343.5		354.9	
120	D86	166.2		208.2		271.6		331.0		347.1		352.2	
132	D86	168.1		210.3		272.3		329.5		343.7		354.5	
140	D86	169.5		211.1		271.0		329.2		346.0		354.8	
150	D86	164.8		205.7		272.3		331.9		348.9		356.1	
158	D86	164.8		210.1		269.3	R(0.05)	327.9		345.6		354.4	
159	D86	172.1		212.7		273.9		332.4		347.8		358.3	
169	D86	168.9		208.0		272.0		331.6		348.3		357.5	
171	D86	167.6		212.6		273.0		331.7		347.5		355.4	
175	D86	172.6		209.6		275.3		336.0		353.8		358.9	
186		----		----		----		----		----		----	
193	D86	170.2		213.7		273.7		331.1		346.9		354.9	
194		----		----		----		----		----		----	
212	D86	169.4		212.6		273.3		335.2		354.1		357.4	
217	D86	171.0		208.4		272.9		331.0		346.5		357.1	
221		----		----		----		----		----		----	
224	D86	171.50		207.0		272.0		332.33		349.0		359.2	
225		----		----		----		----		----		----	
228		----		----		----		----		----		----	
230	D86	171.2		210.2		272.7		331.3		348.7		359.5	
238		----		----		----		----		----		----	
240		----		----		----		----		----		----	
242		----		----		----		----		----		----	
252		----		----		----		----		----		----	
253		----		----		----		----		----		----	
254		----		----		----		----		----		----	
256		----		----		----		----		----		----	
258	D86	173.0		210.4		272.6		330.2		343.4		352.5	
273	D86	169.1		208.8		271.9		330.0		344.6		353.5	C
311	D86	166.4		207.9		271.6		330.8		347.2		356.6	
312	D86	168.4		210.1		273.4		330.8		346.1		354.1	
323	D86	170.8		211.5		273.4		332.1		349.5		356.4	
332		----		----		----		----		----		----	
334	D86	172.6		211.5		273.4		330.6		345.8		357.0	
335	D86	172.2		208.5		272.6		331.7		348.4		358.0	
336	D86	173.2		210.1		272.2		329.4		345.7		358.3	
337	D86	174.7		211.0		273.1		331.9		346.6		356.4	
338	ISO3405	173.2		211.7		273.6		333.6		351.0		359.0	
340	D86	175.0		207.4		273.3		333.1		350.0		357.5	
343		----		----		----		----		----		----	
344	D86	169.2		209.9		272.7		329.8		343.6		355.7	
349		----		----		----		----		----		----	
350		----		----		----		----		----		----	
353	IP123	156.3	R(0.01)	204.5		271.1		332.2		348.3		358.5	
356	D86	173.2		212.9		274.4		333.3		350.8		360.8	
360	D86	165.4		209.5		272.1		331.3		346.7		353.6	
430		----		----		----		----		----		----	
431	D86	167.0		210.6		272.7		334.6		355.6		356.2	
445	D86	169.0		209.7		272.4		331.2		348.0		357.2	
447	D86	164.3		210.2		273.3		331.3		346.4		357.9	
463	D86	168.6		209.7		273.3		332.8		350.1		359.6	
485	D86	171.25		211.10		272.80		330.55		346.00		353.20	
491		----		----		----		----		----		----	
493		----		----		----		----		----		----	
494	D86	167.0		208.5		271.7		329.9		345.3		357.2	
496	D86	168.4		208.6		271.9		330.4		346.2		357.8	
507		----		----		----		----		----		----	
511		----		----		----		----		----		----	
541	D86	172.4		210.1		273.1		331.4		346.5		358.3	
557		----		----		----		----		----		----	
562	D86	168.25		208.35		272.80		332.40		348.55		359.50	
575		----		----		----		----		----		----	
603		----		----		----		----		----		----	
604	D86	172.5		211.0		273.5		333.2		349.4		353.6	
607		----		----		----		----		----		----	
608	D86	169.6		209.9		273.0		331.0		346.7		357.1	
631		----		----		----		----		----		----	
657	D86	164.0		208.8		271.1		327.4		341.3		353.8	
671		----		----		----		----		----		----	
732		----		----		----		----		----		----	
759		----		----		----		----		----		----	
781	D86	168.4		211.9		273.4		331.4		346.2		357.5	
823	D86	171.0		210.9		273.6		332.9		349.9		358.8	
824	D86	170.8		210.7		273.7		333.3		350.3		359.1	







825	D86	166.1	211.0	272.6	332.0	348.4	358.1	
854	D86	173.4	213.3	274.0	331.9	349.0	357.2	
862	D86	161.1	208.2	272.3	330.2	345.8	356.2	
863		----	----	----	----	----	----	
873		----	----	----	----	----	----	
874		----	----	----	----	----	----	
875	D86	169.4	211.6	273.6	331.5	347.0	359.2	
887		----	----	----	----	----	----	
902		----	----	----	----	----	----	
922		----	----	----	----	----	----	
951		----	----	----	----	----	----	
962		----	----	----	----	----	----	
963	D86	170.3	211.9	273.3	330.9	345.4	357.1	
970		----	----	----	----	----	----	
971	D86	170.6	208.8	273.0	333.1	347.1	358.0	
974	D86	169.4	211.5	273.6	331.6	346.7	353.7	
994		----	----	----	----	----	----	
995		----	----	----	----	----	----	
996		----	----	----	----	----	----	
997		----	----	----	----	----	----	
998		----	----	----	----	----	----	
1006	D86	169.0	209.9	272.6	329.8	344.0	354.2	
1011	ISO3405	168.7	211.1	273.2	332.0	348.1	358.7	
1017		----	----	----	----	----	----	
1033	IP123	173.3	212.5	275.0	333.0	346.9	358.1	
1059	ISO3405	168.9	208.0	270.8	328.1	342.9	353.8	
1067	D86	172.2	212.3	273.6	332.4	348.1	353.8	
1080	D86	161.0	206.9	272.0	331.1	346.9	356.9	
1081	D86	168.5	211.5	274.1	334.6	353.8	358.7	
1082	ISO3405	169.0	208.8	272.7	332.1	348.3	355.8	
1095		----	----	----	----	----	----	
1107	D86	171.6	211.9	272.7	330.4	346.1	355.8	
1109	D86	171.7	210.3	273.1	330.8	345.6	358.0	
1121		----	----	----	----	----	----	
1124	ISO3405	173.0	210.5	274.5	334.5	351.0	355.0	
1134		----	----	----	----	----	----	
1146	ISO3405	169.6	208.2	271.3	329.5	343.5	356.7	
1159		----	----	----	----	----	----	
1161	ISO3405	167.7	200.2	R(0.01) 271.2	331.8	347.7	357.3	
1167	D86	164.05	205.05	272.50	330.7	345.8	356.3	
1171		----	----	----	----	----	----	
1182	D86	167.1	210.4	273.4	334.1	352.5	355.9	
1191	ISO3405	167.9	209.8	273.3	333.3	349.8	358.0	
1201	D86	166.5	208.0	271.6	330.4	346.3	353.6	
1227	D86	172.7	209.7	274.1	334.0	350.0	357.9	
1229	ISO3405	170.0	209.8	272.9	331.7	347.5	358.4	
1259	D86	167.6	208.0	271.8	327.9	340.0	358.0	
1297	D86	170.8	209.3	272.6	330.0	344.2	355.0	
1299	D86	165.8	206.7	271.4	331.4	347.8	358.2	
1340	ISO3405	173.8	210.2	273.7	333.5	352.9	357.7	
1379		----	----	----	----	----	----	
1382		----	----	----	----	----	----	
1395	D86	173.0	211.3	272.9	331.3	345.9	357.3	
1409	D86	172.4	212.4	274.0	333.2	350.8	358.0	
1417	ISO3405	171.2	207.7	272.7	332.3	350.1	357.4	
1428	ISO3405	169.2	208.4	272.6	330.4	345.7	357.0	
1430	D86	150.1	C,R(1) 214.5	C,R(1) 280.1	C,R(1) 342.3	C,R(1) 352.1	C,ex 338.3	R(1)
1431	D86	172.5	212.8	274.2	333.0	350.5	361.2	
1457	D86	168.8	209.2	272.4	330.5	346.0	358.9	
1459	ISO3405	167.6	210.5	272.9	329.5	343.6	354.4	
1498	D86	167.4	211.2	273.9	332.6	349.0	358.5	
1510	D86	165.6	208.2	270.8	329.8	345.5	353.2	
1521		----	----	----	----	----	----	
1556	ISO3405	165.0	207.2	271.4	329.9	345.4	355.6	
1564	D86	166.2	210.6	272.2	330.0	345.7	355.8	
1575		----	----	----	----	----	----	
1586	D86	168.4	207.1	271.0	330.8	347.1	356.8	C
1616		----	----	----	----	----	----	
1629		----	----	----	----	----	----	
1634	D86	170.4	209.9	272.4	330.2	345.3	356.5	
1635		----	----	----	----	----	----	
1643		----	----	----	----	----	----	
1654		----	----	----	----	----	----	
1677	D86	168.0	210.0	275.5	334.0	349.5	358.5	
1709	D86	166.1	208.2	272.3	331.5	347.3	358.0	
1710	ISO3405	167.5	210.3	273.6	331.7	347.1	357.0	
1720	D86	172.0	213.1	274.8	334.6	352.7	359.3	
1724	D86	168.2	208.3	272.1	330.3	345.4	357.6	
1730	D86	167.2	209.4	275.6	332.8	348.8	359.2	
1776	ISO3405	166.3	208.6	272.0	332.6	350.1	356.7	

1792	D86	166.8	209.7	272.3	330.7	346.1	352.1
1807	D86	174.2	209.1	272.5	331.9	347.6	359.5
1810	D86	170.5	209.1	272.3	329.3	342.5	354.6
1811	D86	170.0	209.6	273.2	331.3	346.5	356.4
1833	D86	170.6	208.9	272.2	330.8	345.9	358
1842	D86	164.3	208.6	272.1	330.2	345.3	357.4
1849	ISO3405	169.8	210	271.8	330.1	344	357.5
1872		----	----	----	----	----	----
1884	D86	168.5	206.6	271.1	330.7	346.5	356.5
1896	ISO3405	168.5	211.7	272.5	329.5	343.5	353.3
1906		----	----	----	----	----	----
1938	ISO3405	164.2	208.1	272.0	330.5	346.4	356.4
1944	D86	171.3	210.9	275.1	332.2	348.1	355.7
1948	D86	174.3	210	272.2	331.5	349.4	358.2
1951	D86	166.5	208.6	275.2	335.9	351.8	363.2
2129	D86	172.8	210.5	273.1	330.5	344.3	361.2
7012		----	----	----	----	----	----
	normality	OK	OK	OK	OK	OK	OK
	n	109	109	109	110	110	110
	outliers	2	2	2	1	0 + 1 excl.	1
	mean (n)	169.31	209.78	272.83	331.45	347.32	356.84
	st.dev. (n)	2.950	1.800	1.045	1.661	2.758	2.088
	R(calc.)	8.26	5.04	2.93	4.65	7.72	5.85
	R(D86:12)	9.31	4.62	2.97	4.97	8.77	7.10

Lab 273: First reported 350.1

Lab 1430: First reported, 140.0, 202.1, 269.1, 325.5, 336.9, 338.3

Lab 1586: First reported 365.8







Determination of Distillation (automated) on sample #14175; result in %V/V

lab	method	Vol. 250°C	mark	z(targ)	Vol. 350°C	mark	z(targ)	%residue
52	D86	32.5		-0.18	96.1		0.43	1.3
53		----		----	----		----	----
92	D86	32.7		0.03	96.5		0.86	1.7
120	D86	33.7		1.08	95.8		0.12	1.3
132	D86	32.8		0.14	96.3		0.65	1.5
140	D86	33.3		0.66	95.9		0.22	0.8
150	D86	33.1		0.45	95.2		-0.51	1.4
158		----		----	----		----	1.6
159		----		----	----		----	1.7
169		----		----	----		----	1.7
171	D86	33.0		0.35	95.0		-0.72	1.7
175		----		----	----		----	1.5
186		----		----	----		----	----
193	D86	31.8		-0.92	95.6		-0.09	1.6
194		----		----	----		----	----
212		----		----	----		----	2.0
217	D86	32.5		-0.18	95.8		0.12	1.4
221		----		----	----		----	----
224	D86	33.60		0.98	95.50		-0.20	1.3
225		----		----	----		----	----
228		----		----	----		----	----
230	D86	31.8		-0.92	95.3		-0.41	1.3
238		----		----	----		----	----
240		----		----	----		----	----
242		----		----	----		----	----
252		----		----	----		----	----
253		----		----	----		----	----
254		----		----	----		----	----
256		----		----	----		----	----
258	D86	32.4		-0.28	96.5		0.86	1.3
273	D86	33.4		0.77	97.2		1.59	2.3
311	D86	33.3		0.66	95.6		-0.09	1.4
312	D86	31.8		-0.92	95.8		0.12	2.0
323	D86	32.7		0.03	95.9		0.22	1.4
332		----		----	----		----	----
334	D86	33.5		0.87	95.8		0.12	1.4
335	D86	33.3		0.66	95.4		-0.30	0.6
336	D86	32.7		0.03	96.1		0.43	1.0
337	D86	32.6		-0.07	95.6		-0.09	1.4
338	ISO3405	32.1		-0.60	94.8		-0.93	1.4
340	D86	32.3		-0.39	95.0		-0.72	1.4
343		----		----	----		----	----
344	D86	32.6		-0.07	96.4		0.75	1.0
349		----		----	----		----	----
350		----		----	----		----	----
353	IP123	33.7		1.08	95.4		-0.30	1.0
356	D86	32.9		0.24	95.9		0.22	1.4
360	D86	33.4		0.77	95.5		-0.20	1.4
430		----		----	----		----	----
431	D86	36.3	R(0.01)	3.82	97.9		2.33	0.0
445	D86	32.4		-0.28	95.5		-0.20	1.4
447	D86	32.1		-0.60	95.7		0.01	1.4
463	D86	32.4		-0.28	95		-0.72	1.8
485	D86	32.35		-0.34	96.15		0.49	1.75
491		----		----	----		----	----
493		----		----	----		----	----
494	D86	33.2		0.56	96.0		0.33	1.4
496	D86	32.8		0.14	95.9		0.22	1.2
507		----		----	----		----	----
511		----		----	----		----	----
541	D86	33.0		0.35	95.0		-0.72	1.4
557		----		----	----		----	----
562	D86	32.7		0.03	95.3		-0.41	1.9
575		----		----	----		----	----
603		----		----	----		----	----
604	D86	31.9		-0.81	95.2		-0.51	1.4
607		----		----	----		----	----
608		----		----	----		----	1.4
631		----		----	----		----	----
657	D86	33.5		0.87	97.1		1.49	0.8
671		----		----	----		----	----
732		----		----	----		----	----
759		----		----	----		----	----
781	D86	32.1		-0.60	96.0		0.33	1.2
823	D86	31.7		-1.02	95.0		-0.72	1.4
824	D86	32.3		-0.39	94.9		-0.83	1.4

825	D86	32.2	-0.50	93.5	R(0.05)	-2.30	1.6
854	D86	31.6	-1.13	95.3		-0.41	0.8
862	D86	33.3	0.66	95.8		0.12	1.7
863		----	----	----		----	----
873		----	----	----		----	----
874		----	----	----		----	----
875	D86	31.9	-0.81	95.7		0.01	1.4
887		----	----	----		----	----
902		----	----	----		----	----
922		----	----	----		----	----
951		----	----	----		----	----
962		----	----	----		----	----
963	D86	31.8	-0.92	96.0		0.33	1.2
970		----	----	----		----	----
971	D86	32.6	-0.07	95.3		-0.41	1.4
974	D86	32.6	-0.07	95.8		0.12	1.3
994		----	----	----		----	----
995		----	----	----		----	----
996		----	----	----		----	----
997		----	----	----		----	----
998		----	----	----		----	----
1006		----	----	----		----	1.8
1011	ISO3405	32.2	-0.50	95.4		-0.30	1.2
1017		----	----	----		----	----
1033	IP123	30.7	-2.07	95.8		0.12	1.5
1059	ISO3405	34.4	1.82	96.6		0.96	1.8
1067	D86	31.8	-0.92	95.4		-0.30	2.0
1080	D86	33.7	1.08	95.7		0.01	1.2
1081	D86	31.5	-1.23	94.3		-1.46	0.6
1082	ISO3405	32.7	0.03	95.3		-0.41	----
1095		----	----	----		----	----
1107	D86	32.7	0.03	95.8		0.12	1.9
1109	D86	32.5	-0.18	96.1		0.43	----
1121		----	----	----		----	----
1124	ISO3405	32.0	-0.71	95.0		-0.72	1.9
1134		----	----	----		----	----
1146	ISO3405	33.84	1.23	96.33		0.68	1.0
1159		----	----	----		----	----
1161	ISO3405	34.4	1.82	95.4		-0.30	1.4
1167	D86	33.5	0.87	96.2		0.54	1.5
1171		----	----	----		----	----
1182	D86	32.2	-0.50	94.5		-1.25	1.6
1191	ISO3405	32.2	-0.50	95.0		-0.72	----
1201	D86	33.6	0.98	95.9		0.22	1.4
1227	D86	31.8	-0.92	95.0		-0.72	1.0
1229	ISO3405	32.4	-0.28	95.6		-0.09	1.7
1259	D86	33.0	0.35	97.5		1.91	1.4
1297	D86	32.9	0.24	96.3		0.65	1.4
1299	D86	33.8	1.19	95.4		-0.30	1.2
1340	ISO3405	32.1	-0.60	94.5		-1.25	1.2
1379		----	----	----		----	----
1382		----	----	----		----	----
1395	D86	32.2	-0.50	95.9		0.22	1.4
1409	D86	32.1	-0.60	94.8		-0.93	1.4
1417	ISO3405	32.4	-0.28	95.0		-0.72	0.9
1428	ISO3405	32.6	-0.07	95.8		0.12	1.6
1430		----	----	----		----	1.4
1431	D86	31.8	-0.92	94.9		-0.83	2.3
1457	D86	33.1	0.45	95.8		0.12	1.3
1459	ISO3405	32.5	-0.18	96.3		0.65	1.4
1498	D86	32	-0.71	95		-0.72	1.3
1510	D86	33.8	1.19	96.1		0.43	1.2
1521		----	----	----		----	----
1556	ISO3405	34.1	1.50	96.0		0.33	1.4
1564	D86	32.8	0.14	95.8		0.12	1.1
1575		----	----	----		----	----
1586	D86	34.0	1.40	95.6		-0.09	1.2
1616		----	----	----		----	----
1629		----	----	----		----	----
1634	D86	33.1	0.45	96.5		0.86	1.4
1635		----	----	----		----	----
1643		----	----	----		----	----
1654		----	----	----		----	----
1677	D86	31.0	-1.76	95.1		-0.62	2.0
1709	D86	32.9	0.24	95.6		-0.09	1.6
1710	ISO3405	32.0	-0.71	95.7		0.01	1.5
1720	D86	30.6	-2.18	94.4		-1.35	1.4
1724	D86	33.2	0.56	96.0		0.33	1.4
1730	D86	33.1	0.45	95.3		-0.41	0.8
1776	ISO3405	33.1	0.45	95.0		-0.72	1.4

1792	D86	32.9	0.24	96.0	0.33	1.4
1807	D86	33.0	0.35	95.3	-0.41	1.4
1810	D86	33.1	0.45	97.0	1.38	0.8
1811	D86	32.4	-0.28	95.9	0.22	1.4
1833	D86	33.2	0.56	95.8	0.12	1.6
1842	D86	33.2	0.56	95.9	0.22	1.4
1849	ISO3405	33.2	0.56	96.1	0.43	1.4
1872		----	----	----	----	----
1884	D86	33.9	1.29	95.8	0.12	1.4
1896	ISO3405	32.5	-0.18	96.5	0.86	0.9
1906		----	----	----	----	----
1938	ISO3405	33.5	0.87	95.7	0.01	1.4
1944	D86	30.9	-1.86	96.0	0.33	1.8
1948	D86	32.6	-0.07	95.1	-0.62	1.7
1951	D86	31.9	-0.81	94.5	-1.25	1.4
2129	D86	31.8	-0.92	96.4	0.75	1.4
7012		----	----	----	----	----

normality	OK	suspect
n	102	102
outliers	1	1
mean (n)	32.67	95.69
st.dev. (n)	0.766	0.641
R(calc.)	2.14	1.79
R(D86:12)	2.66	2.66









-- empty page --

Determination of Distillation (Manual) on sample #14175; result in °C

lab	method	IBP	mark	10%rec	mark	50%rec	mark	90%rec	mark	95%rec	mark	FBP	mark
52		----		----		----		----		----		----	
53		----		----		----		----		----		----	
92		----		----		----		----		----		----	
120		----		----		----		----		----		----	
132		----		----		----		----		----		----	
140		----		----		----		----		----		----	
150		----		----		----		----		----		----	
158		----		----		----		----		----		----	
159		----		----		----		----		----		----	
169		----		----		----		----		----		----	
171		----		----		----		----		----		----	
175		----		----		----		----		----		----	
186		----		----		----		----		----		----	
193		----		----		----		----		----		----	
194		----		----		----		----		----		----	
212		----		----		----		----		----		----	
217		----		----		----		----		----		----	
221	D86	167.0		206.0		271.0		332.0		339.0		355.0	
224		----		----		----		----		----		----	
225	D86	171.0		208.0		271.5		332.0		350.0		357.0	
228	D86	174.0		210.0		271.0		332.0		348.0		356.0	
230		----		----		----		----		----		----	
238		----		----		----		----		----		----	
240	D86	170.0		205.0		272.0		332.0		350.0		356.0	
242		----		----		----		----		----		----	
252	D86	172.0		205.0		271.0		331.0		346.0		358.0	
253	D86	168.0		208.5		272.0		331.0		348.5		357.0	
254	D86	172.0		205.0		272.0		331.0		348.0		358.0	
256	D86	172.0		207.0		272.0		331.0		----		357.0	
258		----		----		----		----		----		----	
273		----		----		----		----		----		----	
311		----		----		----		----		----		----	
312		----		----		----		----		----		----	
323		----		----		----		----		----		----	
332		----		----		----		----		----		----	
334		----		----		----		----		----		----	
335		----		----		----		----		----		----	
336		----		----		----		----		----		----	
337		----		----		----		----		----		----	
338		----		----		----		----		----		----	
340		----		----		----		----		----		----	
343		----		----		----		----		----		----	
344		----		----		----		----		----		----	
349		----		----		----		----		----		----	
350	ISO3405	164.84		202.82		270.80		330.78		347.27		357.77	
353		----		----		----		----		----		----	
356		----		----		----		----		----		----	
360		----		----		----		----		----		----	
430		----		----		----		----		----		----	
431		----		----		----		----		----		----	
445		----		----		----		----		----		----	
447		----		----		----		----		----		----	
463		----		----		----		----		----		----	
485		----		----		----		----		----		----	
491		----		----		----		----		----		----	
493		----		----		----		----		----		----	
494		----		----		----		----		----		----	
496		----		----		----		----		----		----	
507	D86	177.40		211.40		274.50		333.50		343.50		353.50	
511	D86	172.5		207.5		270.0		330.5		347.5		356.0	
541		----		----		----		----		----		----	
557		----		----		----		----		----		----	
562		----		----		----		----		----		----	
575		----		----		----		----		----		----	
603		----		----		----		----		----		----	
604		----		----		----		----		----		----	
607		----		----		----		----		----		----	
608		----		----		----		----		----		----	
631	D86	171.0		201.5		270.0		329.0		343.0		353.0	
657		----		----		----		----		----		----	
671		----		----		----		----		----		----	
732	D86	171.5		207.5		272.5		333.0		349.5		359.0	
759	D86	167.0		209.5		272.5		330.5		345.5		356.5	
781		----		----		----		----		----		----	
823		----		----		----		----		----		----	
824		----		----		----		----		----		----	

825		----	----	----	----	----	----
854		----	----	----	----	----	----
862		----	----	----	----	----	----
863	D86	173.5	211.0	274.0	332.0	347.5	361.0
873	D86	169.0	210.0	273.0	331.0	346.5	357.5
874	D86	172.0	210.0	273.0	332.5	350.0	357.0
875		----	----	----	----	----	----
887	D86	169.0	208.0	271.0	332.5	347.5	355.5
902		----	----	----	----	----	----
922	D86	170.1	205.1	271.1	331.2	345.2	359.2
951	D86	172.63	209.59	273.54	332.49	346.48	356.47
962	D86	170.0	208.0	273.0	333.0	341.5	359.0
963		----	----	----	----	----	----
970	D86	166.0	208.0	274.0	331.0	346.0	354.0
971		----	----	----	----	----	----
974		----	----	----	----	----	----
994	D86	172.0	208.5	273.0	333.0	350.0	358.5
995	D86	172.0	208.5	273.0	332.5	350.0	359.0
996		----	----	----	----	----	----
997	D86	171.5	208.0	272.5	332.0	350.0	359.0
998	D86	170.5	209.0	273.0	332.0	348.5	358.5
1006		----	----	----	----	----	----
1011		----	----	----	----	----	----
1017		----	----	----	----	----	----
1033		----	----	----	----	----	----
1059		----	----	----	----	----	----
1067		----	----	----	----	----	----
1080		----	----	----	----	----	----
1081		----	----	----	----	----	----
1082		----	----	----	----	----	----
1095		----	----	----	----	----	----
1107		----	----	----	----	----	----
1109		----	----	----	----	----	----
1121	IP123	172.0	206.0	275.0	335.0	349.0	360.0
1124		----	----	----	----	----	----
1134		----	----	----	----	----	----
1146		----	----	----	----	----	----
1159	D86	176.008	210.154	273.938	332.198	348.111	352.343
1161		----	----	----	----	----	----
1167		----	----	----	----	----	----
1171	ISO3405	167.03	204.03	271.04	330.29	345.97	356.80
1182		----	----	----	----	----	----
1191		----	----	----	----	----	----
1201		----	----	----	----	----	----
1227		----	----	----	----	----	----
1229		----	----	----	----	----	----
1259	D86	167.0	209.0	271.0	328.5	340.5	357.5
1297		----	----	----	----	----	----
1299		----	----	----	----	----	----
1340		----	----	----	----	----	----
1379	INH-2177	174.5	211	273	332	343	351
1382	GB/T6536	168	206	273	331	345	356
1395		----	----	----	----	----	----
1409		----	----	----	----	----	----
1417		----	----	----	----	----	----
1428		----	----	----	----	----	----
1430		----	----	----	----	----	----
1431		----	----	----	----	----	----
1457		----	----	----	----	----	----
1459		----	----	----	----	----	----
1498		----	----	----	----	----	----
1510		----	----	----	----	----	----
1521		----	----	----	----	----	----
1556		----	----	----	----	----	----
1564		----	----	----	----	----	----
1575		----	----	----	----	----	----
1586		----	----	----	----	----	----
1616	D86	165	205	271	330	344	357
1629		----	----	----	----	----	----
1634		----	----	----	----	----	----
1635	D86	173.0	207.0	271.0	329.0	344.0	360.0
1643		----	----	----	----	----	----
1654		----	----	----	----	----	----
1677		----	----	----	----	----	----
1709		----	----	----	----	----	----
1710		----	----	----	----	----	----
1720		----	----	----	----	----	----
1724		----	----	----	----	----	----
1730		----	----	----	----	----	----
1776		----	----	----	----	----	----

1792	----	----	----	----	----	----	----
1807	----	----	----	----	----	----	----
1810	----	----	----	----	----	----	----
1811	----	----	----	----	----	----	----
1833	----	----	----	----	----	----	----
1842	----	----	----	----	----	----	----
1849	----	----	----	----	----	----	----
1872	----	----	----	----	----	----	----
1884	----	----	----	----	----	----	----
1896	----	----	----	----	----	----	----
1906	----	----	----	----	----	----	----
1938	----	----	----	----	----	----	----
1944	----	----	----	----	----	----	----
1948	----	----	----	----	----	----	----
1951	----	----	----	----	----	----	----
2129	----	----	----	----	----	----	----
7012	D86	170	210	275	331	347	355
normality	OK	OK	OK	OK	OK	OK	OK
n	35	35	35	35	34	35	35
outliers	0	0	0	0	0	0	0
mean (n)	170.60	207.62	272.31	331.53	346.52	356.86	
st.dev. (n)	2.956	2.403	1.352	1.320	2.895	2.246	
R(calc.)	8.28	6.73	3.79	3.70	8.11	6.29	
R(D86:12)	6.24	4.51	3.86	3.99	5.17	3.97	







Determination of Distillation (Manual) on sample #14175; result in %V/V

lab	method	Vol. 250°C	mark	z(targ)	Vol. 350°C	mark	z(targ)	%residue
52		----		----	----		----	----
53		----		----	----		----	----
92		----		----	----		----	----
120		----		----	----		----	----
132		----		----	----		----	----
140		----		----	----		----	----
150		----		----	----		----	----
158		----		----	----		----	----
159		----		----	----		----	----
169		----		----	----		----	----
171		----		----	----		----	----
175		----		----	----		----	----
186		----		----	----		----	----
193		----		----	----		----	----
194		----		----	----		----	----
212		----		----	----		----	----
217		----		----	----		----	----
221	D86	35		1.91	96		0.34	1.8
224		----		----	----		----	----
225	D86	34.0		0.84	95.0		-0.93	1.6
228	D86	33.0		-0.24	95.0		-0.93	1.8
230		----		----	----		----	----
238		----		----	----		----	----
240	D86	34.0		0.84	95.0		-0.93	2.0
242		----		----	----		----	----
252		----		----	----		----	----
253	D86	33.0		-0.24	95.2		-0.68	1.3
254	D86	32.0		-1.32	96.0		0.34	----
256		----		----	----		----	----
258		----		----	----		----	----
273		----		----	----		----	----
311		----		----	----		----	----
312		----		----	----		----	----
323		----		----	----		----	----
332		----		----	----		----	----
334		----		----	----		----	----
335		----		----	----		----	----
336		----		----	----		----	----
337		----		----	----		----	----
338		----		----	----		----	----
340		----		----	----		----	----
343		----		----	----		----	----
344		----		----	----		----	----
349		----		----	----		----	----
350	ISO3405	33.67		0.48	95.50		-0.29	1.0
353		----		----	----		----	----
356		----		----	----		----	----
360		----		----	----		----	----
430		----		----	----		----	----
431		----		----	----		----	----
445		----		----	----		----	----
447		----		----	----		----	----
463		----		----	----		----	----
485		----		----	----		----	----
491		----		----	----		----	----
493		----		----	----		----	----
494		----		----	----		----	----
496		----		----	----		----	----
507	D86	32		-1.32	96		0.34	1.4
511	D86	34.5		1.37	95.5		-0.29	1.0
541		----		----	----		----	----
557		----		----	----		----	----
562		----		----	----		----	----
575		----		----	----		----	----
603		----		----	----		----	----
604		----		----	----		----	----
607		----		----	----		----	----
608		----		----	----		----	----
631	D86	35.0		1.91	96.5		0.98	1.5
657		----		----	----		----	----
671		----		----	----		----	----
732	D86	32.5		-0.78	95.5		-0.29	1.6
759	D86	33.5		0.30	96.0		0.34	1.9
781		----		----	----		----	----
823		----		----	----		----	----
824		----		----	----		----	----

825		----	----	----	----	----
854		----	----	----	----	----
862		----	----	----	----	----
863	D86	31.9	-1.43	96.0	0.34	1.1
873	D86	32.5	-0.78	96.5	0.98	1.8
874	D86	33.0	-0.24	95.0	-0.93	1.5
875		----	----	----	----	----
887	D86	33	-0.24	96	0.34	1.7
902		----	----	----	----	----
922	D86	35	1.91	96	0.34	1.10
951	D86	32.5	-0.78	95.5	-0.29	1.8
962	D86	33.5	0.30	96.5	0.98	1.0
963		----	----	----	----	----
970	D86	32.6	-0.67	96.3	0.72	1.6
971		----	----	----	----	----
974		----	----	----	----	----
994	D86	33.0	-0.24	95.0	-0.93	1.3
995	D86	33.7	0.51	95.0	-0.93	1.38
996		----	----	----	----	----
997	D86	34.0	0.84	95.0	-0.93	1.4
998	D86	32.5	-0.78	95.5	-0.29	1.4
1006		----	----	----	----	----
1011		----	----	----	----	----
1017		----	----	----	----	----
1033		----	----	----	----	----
1059		----	----	----	----	----
1067		----	----	----	----	----
1080		----	----	----	----	----
1081		----	----	----	----	----
1082		----	----	----	----	----
1095		----	----	----	----	----
1107		----	----	----	----	----
1109		----	----	----	----	----
1121	IP123	32	-1.32	95	-0.93	1.4
1124		----	----	----	----	----
1134		----	----	----	----	----
1146		----	----	----	----	----
1159	D86	34.0	0.84	95.5	-0.29	2.6
1161		----	----	----	----	----
1167		----	----	----	----	----
1171	ISO3405	34.01	0.85	96.15	0.53	1.1
1182		----	----	----	----	----
1191		----	----	----	----	----
1201		----	----	----	----	----
1227		----	----	----	----	----
1229		----	----	----	----	----
1259	D86	34.0	0.84	97.0	1.61	1.2
1297		----	----	----	----	----
1299		----	----	----	----	----
1340		----	----	----	----	----
1379	INH-2177	33	-0.24	96	0.34	2.5
1382	GB/T6536	33	-0.24	96	0.34	2.0
1395		----	----	----	----	----
1409		----	----	----	----	----
1417		----	----	----	----	----
1428		----	----	----	----	----
1430		----	----	----	----	----
1431		----	----	----	----	----
1457		----	----	----	----	----
1459		----	----	----	----	----
1498		----	----	----	----	----
1510		----	----	----	----	----
1521		----	----	----	----	----
1556		----	----	----	----	----
1564		----	----	----	----	----
1575		----	----	----	----	----
1586		----	----	----	----	----
1616	D86	32	-1.32	96	0.34	1.6
1629		----	----	----	----	----
1634		----	----	----	----	----
1635	D86	34.0	0.84	96.0	0.34	1.3
1643		----	----	----	----	----
1654		----	----	----	----	----
1677		----	----	----	----	----
1709		----	----	----	----	----
1710		----	----	----	----	----
1720		----	----	----	----	----
1724		----	----	----	----	----
1730		----	----	----	----	----
1776		----	----	----	----	----

1792		----	----	----	----	----
1807		----	----	----	----	----
1810		----	----	----	----	----
1811		----	----	----	----	----
1833		----	----	----	----	----
1842		----	----	----	----	----
1849		----	----	----	----	----
1872		----	----	----	----	----
1884		----	----	----	----	----
1896		----	----	----	----	----
1906		----	----	----	----	----
1938		----	----	----	----	----
1944		----	----	----	----	----
1948		----	----	----	----	----
1951		----	----	----	----	----
2129		----	----	----	----	----
7012	D86	31	-2.39	96	0.34	1.1
	normality	OK		OK		
	n	33		33		
	outliers	0		0		
	mean (n)	33.22		95.73		
	st.dev. (n)	0.991		0.549		
	R(calc.)	2.77		1.54		
	R(D86:12)	2.60		2.20		



-- empty page --

Determination of FAME Content on sample #14175; result in %V/V



lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854		----		----
92		----		----	862	EN14078	2.624		-0.05
120	D7371	2.84		0.67	863	EN14078	2.69		0.17
132	D7371	2.80		0.53	873		----		----
140		----		----	874		----		----
150	D7371	2.9		0.87	875		----		----
158		----		----	887		----		----
159		----		----	902		----		----
169		----		----	922		----		----
171	D7371	2.44		-0.67	951		----		----
175		----		----	962		----		----
186		----		----	963		----		----
193		----		----	970		----		----
194		----		----	971		----		----
212		----		----	974		----		----
217		----		----	994		----		----
221		----		----	995	D7371	2.39		-0.84
224		----		----	996		----		----
225		----		----	997		----		----
228		----		----	998		----		----
230		----		----	1006	EN14078	2.65		0.03
238		----		----	1011	EN14078	2.45		-0.64
240		----		----	1017	EN14078	2.63		-0.03
242		----		----	1033		----		----
252		----		----	1059	EN14078	2.59		-0.17
253		----		----	1067	EN14078	2.52		-0.40
254		----		----	1080		----		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311	EN14078	2.56		-0.27	1107	in house	2.7		0.20
312	EN14078	2.57		-0.23	1109		----		----
323	D7371	2.60		-0.13	1121		----		----
332		----		----	1124	EN14078	2.66		0.07
334	EN14078	2.654		0.05	1134		----		----
335	EN14078	2.62		-0.07	1146		----		----
336	EN14078	2.66		0.07	1159		----		----
337		----		----	1161	EN14078	2.7		0.20
338	EN14078	2.351		-0.97	1167	EN14078	2.340		-1.00
340	EN14078	2.59		-0.17	1171	EN14078	1.60	R(0.01)	-3.48
343	EN14078	2.7		0.20	1182		----		----
344	EN14078	2.196	R(0.05)	-1.49	1191		----		----
349	EN14078	2.80		0.53	1201		----		----
350		----		----	1227		----		----
353	EN14078	2.691		0.17	1229		----		----
356	EN14078	2.651		0.04	1259	EN14078	2.90186		0.88
360	EN14078	2.55		-0.30	1297		----		----
430		----		----	1299	EN14078	2.68		0.13
431		----		----	1340		----		----
445	EN14078	2.697		0.19	1379		----		----
447	EN14078	2.82		0.60	1382		----		----
463	EN14078	2.76		0.40	1395	D7371	2.6		-0.13
485		----		----	1409	EN14078	2.74		0.33
491		----		----	1417		----		----
493		----		----	1428	EN14078	2.7478		0.36
494		----		----	1430		----		----
496		----		----	1431		----		----
507		----		----	1457	EN14078	2.52		-0.40
511	D7371	2.416		-0.75	1459	EN14078	2.69		0.17
541		----		----	1498		----		----
557		----		----	1510		----		----
562		----		----	1521		----		----
575		----		----	1556		----		----
603		----		----	1564	EN14078	2.7		0.20
604		----		----	1575		----		----
607		----		----	1586	EN14078	2.65		0.03
608		----		----	1616		----		----
631		----		----	1629		----		----
657	EN14078	2.73		0.30	1634	EN14078	2.7		0.20
671		----		----	1635	D7371	2.77		0.43
732		----		----	1643		----		----
759		----		----	1654		----		----
781	EN14078	2.61		-0.10	1677		----		----
823	D7371	2.65		0.03	1709	EN14078	2.64		0.00
824		----		----	1710	EN14078	2.64		0.00

1720		----			1872	----	----
1724	EN14078	2.58	-0.20	1884		----	----
1730	EN14078	2.6	-0.13	1896		----	----
1776	EN14078	2.78	0.47	1906		----	----
1792	EN14078	2.60	-0.13	1938		----	----
1807	EN14078	2.60	-0.13	1944	EN14078	2.83	0.64
1810	D7371	2.7	0.20	1948	D7371	2.64	0.00
1811	EN14078	2.55	-0.30	1951		----	----
1833		----	----	2129	IP579	2.60	-0.13
1842	EN14078	2.57	-0.23	7012		----	----
1849	EN14078	2.413	-0.76				

normality	OK	<u>Only D7371</u>	<u>Only EN14078</u>
n	61	OK	suspect
outliers	2	13	47
mean (n)	2.640	0	2
st.dev. (n)	0.1229	2.642	2.638
R(calc.)	0.344	0.1610	0.1134
R(D7371:14)	0.837	0.451	0.318
		0.837	0.155

Application Range: 1 – 20%V/V

Compare R(EN14078:09 range A) = 0.155





Determination of Flash Point PMcc, on sample #14175; result in °C

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D93	65.0		1.12	825	D93	60.5		-1.69
53	D93	62		-0.75	854	D93	63.5		0.18
92	D93	62.0		-0.75	862	D93	66.0		1.74
120	D93	64		0.50	863	D93	65.0		1.12
132	D93	64.0		0.50	873	D93	64.0		0.50
140	D93	60.0		-2.00	874	D93	64.5		0.81
150	D93	63.3		0.06	875	D93	63.0		-0.13
158	D93	64		0.50	887	D93	62.5		-0.44
159	D93	62.22		-0.61	902	D93	63.0		-0.13
169	D93	63.5		0.18	922	D93	62.5		-0.44
171	D93	63.3		0.06	951	D93	63.77		0.35
175	D93	64		0.50	962		----		----
186		----		----	963	D93	62.0		-0.75
193	D93	62.778		-0.27	970	D93	63.0		-0.13
194		----		----	971	D93	61.5		-1.06
212	ISO2719	64.9		1.06	974	D93	63.0		-0.13
217	D93	65.93		1.70	994	D93	63.5		0.18
221	D93	64.0		0.50	995	D93	62.7		-0.31
224	D93	61.97		-0.77	996		----		----
225	D93	67.0		2.37	997	D93	63.0		-0.13
228	D93	64.0		0.50	998	D93	62.5		-0.44
230	D93	61.0		-1.38	1006	D93	62.5		-0.44
238	D93	62.0		-0.75	1011	D93	65.0		1.12
240	D93	62.0		-0.75	1017	D93	64.0		0.50
242	D93	64.2		0.62	1033	IP34	63.5		0.18
252	D93	64.0		0.50	1059	ISO2719	64.0		0.50
253	D93	62.5		-0.44	1067	D93	63.0		-0.13
254	D93	63.0		-0.13	1080		----		----
256	D93	63.0		-0.13	1081	D93	63.1		-0.07
258	D93	63.132		-0.05	1082	ISO2719	63.0		-0.13
273	D93	62.0		-0.75	1095		----		----
311	D93	63.0		-0.13	1107	D93	63.0		-0.13
312	D93	63.0		-0.13	1109	D93	63.0		-0.13
323	D93	61.5		-1.06	1121	IP34	61.0		-1.38
332		----		----	1124	ISO3675	65.2		1.24
334	D93	63.8		0.37	1134		----		----
335	D93	64.0		0.50	1146	D93	61.9		-0.81
336	D93	63.0		-0.13	1159	D93	62.73625		-0.29
337	D93	66.0		1.74	1161	ISO2719	63.5		0.18
338	ISO2719	64.0		0.50	1167	ISO2719	63.0		-0.13
340	D93	63.0		-0.13	1171	ISO2719	63.33		0.08
343	D93	64.0		0.50	1182	D93	64		0.50
344	D93	60.0		-2.00	1191	ISO2719	63.0		-0.13
349	D93	63		-0.13	1201	D93	59.0		-2.62
350	ISO2719	63.885		0.42	1227	D93	65.0		1.12
353	IP34	63.750		0.34	1229		----		----
356	D93	64.0		0.50	1259	D93	65.0		1.12
360	D93	63.0		-0.13	1297	D93	64		0.50
430		----		----	1299	D93	66.5		2.06
431	ISO2719	62.5		-0.44	1340	ISO2719	65.0		1.12
445	D93	66.0		1.74	1379	D93	63.5		0.18
447	D93	65.0		1.12	1382	GB/T261	68.0		2.99
463	D93	63.5		0.18	1395	D93	60.0		-2.00
485	D93	63.0		-0.13	1409	D93	64.5		0.81
491		----		----	1417	D93	63		-0.13
493		----		----	1428	ISO2719	62.5		-0.44
494	D93	65.0		1.12	1430	D93	63.5		0.18
496	D93	62.0		-0.75	1431	D93	63.4		0.12
507	D93	61.0		-1.38	1457	D93	61.7		-0.94
511	D93	61.1		-1.31	1459	ISO2719	61.5		-1.06
541	D93	63.0		-0.13	1498	D93	63.5		0.18
557		----		----	1510	D93	61.0		-1.38
562	D93	65.80		1.62	1521		----		----
575		----		----	1556	ISO2719	62.5		-0.44
603	D93	63.0		-0.13	1564	D93	63.0		-0.13
604	D93	63.5		0.18	1575	D93	64.4		0.75
607	D93	64.0		0.50	1586	D93	64.0		0.50
608	D93	62.0		-0.75	1616	D93	64.0		0.50
631	D93	59.0		-2.62	1629	D93	62.8		-0.25
657	D93	64.0		0.50	1634	D93	64.0		0.50
671	D93	62		-0.75	1635	D93	67.0		2.37
732	D93	62.0		-0.75	1643	D93	63.75		0.34
759	D93	63.0		-0.13	1654		----		----
781	D93	63.0		-0.13	1677	D93	66.0		1.74
823	D93	62.0		-0.75	1709		----		----
824	ISO2719	63.0		-0.13	1710	ISO2719	62.0		-0.75

1720	D93	64.0	0.50	1872	ISO2719	62	-0.75
1724	D93	63	-0.13	1884	D93	63.5	0.18
1730	ISO2719	63.0	-0.13	1896	D93	62	-0.75
1776	ISO2719	63.0	-0.13	1906		----	----
1792	D93	62.5	-0.44	1938	ISO2719	63	-0.13
1807	D93	64.0	0.50	1944	D93	62.5	-0.44
1810	D93	61.5	-1.06	1948	D93	63.0	-0.13
1811	ISO2719	60.4	-1.75	1951	D93	62.0	-0.75
1833	D93	64	0.50	2129	D93	63.0	-0.13
1842	D93	62.0	-0.75	7012	D93	63	-0.13
1849	ISO2719	64	0.50				

normality suspect
n 155
outliers 0
mean (n) 63.205
st.dev. (n) 1.4389
R(calc.) 4.029
R(D93:13e1) 4.488





Determination of Kinematic Viscosity @ 40°C, on sample #14175; result in mm²/s

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D445	2.768		0.13	825	D445	2.757		-0.87
53		----		----	854	D445	2.7712		0.42
92	D445	2.816	R(0.01)	4.48	862	D445	2.7790		1.12
120	D445	2.753	C	-1.23	863	D445	2.7683		0.15
132	D445	2.769		0.22	873	D445	2.772		0.49
140	D445	2.748	C	-1.69	874	D445	2.767		0.03
150	D445	2.7681		0.13	875		----		----
158		----		----	887		----		----
159	D445	2.768		0.13	902	D445	2.778		1.03
169	D445	2.7440		-2.05	922	D445	2.7781		1.04
171	D445	2.755		-1.05	951	D445	2.7503		-1.48
175	D445	2.753		-1.23	962		----		----
186		----		----	963	D445	2.768		0.13
193	D445	2.4249	R(0.01)	-30.98	970	D7042	2.769		0.22
194		----		----	971	D445	2.778		1.03
212	ISO3104	2.765		-0.15	974	D445	2.763		-0.33
217	D445	2.7816		1.36	994	D445	2.767		0.03
221	D445	2.771		0.40	995	D445	2.768		0.13
224	D445	2.673	C,R(0.01)	-8.49	996		----		----
225	D445	2.772		0.49	997	D445	2.770		0.31
228	D445	2.776	C	0.85	998	D445	2.771		0.40
230	D445	2.7725		0.53	1006	D445	2.7680		0.13
238		----		----	1011	D445	2.764		-0.24
240	D445	2.7645		-0.19	1017	D445	2.8347	R(0.01)	6.17
242	D445	2.7650911		-0.14	1033	IP71	2.746		-1.87
252	D445	2.766		-0.06	1059	ISO3104	2.770		0.31
253	D445	2.747		-1.78	1067	D445	2.775		0.76
254	D445	2.764		-0.24	1080	D7042	2.7574		-0.84
256	D445	2.770		0.31	1081	D445	2.755		-1.05
258	D445	2.749581		-1.54	1082	ISO3104	2.7644		-0.20
273	D445	2.769		0.22	1095		----		----
311	D445	2.768		0.13	1107	D445	2.786		1.76
312	D445	2.757		-0.87	1109	D445	2.7615		-0.46
323	D445	2.769		0.22	1121	IP71	2.769		0.22
332		----		----	1124	ISO3104	2.7630		-0.33
334	D445	2.768		0.13	1134		----		----
335		----		----	1146	D445	2.7665		-0.01
336		----		----	1159	D445	2.756722		-0.90
337	D445	2.783		1.48	1161	D445	2.768		0.13
338		----		----	1167	ISO3104	2.762		-0.42
340	D445	2.7636		-0.27	1171	ISO3104	2.7464	C	-1.83
343	D445	2.7938		2.46	1182		----	W	----
344		----		----	1191	ISO3104	2.7668		0.02
349	D445	2.810	R(0.01)	3.93	1201	D445	2.767		0.03
350		----		----	1227	D445	2.759		-0.69
353	IP71	2.7641		-0.23	1229	ISO3104	2.7669		0.03
356	D445	2.7602		-0.58	1259	D445	2.79812856		2.86
360	D445	2.7703		0.33	1297	D7042	2.760		-0.60
430		----		----	1299	D445	2.757		-0.87
431	ISO3104	2.7748		0.74	1340	ISO3104	2.789		2.03
445	D445	2.7666		0.00	1379	D445	2.776		0.85
447	D445	2.766		-0.06	1382		----		----
463	D445	2.7685		0.17	1395	D445	2.748	C	-1.69
485		----		----	1409	D445	2.771		0.40
491		----		----	1417		----		----
493		----		----	1428	ISO3104	2.758		-0.78
494	D445	2.783		1.48	1430	D445	3.230	R(0.01)	42.01
496	D445	2.7790		1.12	1431	D7042	2.7712		0.42
507	D445	2.7742		0.69	1457	D445	2.7661		-0.05
511	D445	2.7723		0.51	1459	D7042	2.767		0.03
541	D445	2.754		-1.14	1498	D445	2.763		-0.33
557		----		----	1510	D445	2.757		-0.87
562		----		----	1521		----		----
575		----		----	1556	ISO3104	2.7648		-0.17
603	D445	2.7815		1.35	1564	D445	2.762		-0.42
604	D445	2.747		-1.78	1575	D445	2.7839		1.57
607	D445	2.7542		-1.13	1586	D445	2.765		-0.15
608	D445	2.771		0.40	1616	D445	2.763		-0.33
631	D445	2.7751		0.77	1629		----		----
657	D445	2.762		-0.42	1634		----		----
671	D445	2.749		-1.60	1635	D445	2.755		-1.05
732	D445	2.772		0.49	1643	D445	2.760		-0.60
759	D445	2.757		-0.87	1654		----		----
781	D445	2.770		0.31	1677	D445	2.778		1.03
823	D445	2.7607		-0.54	1709		----		----
824	ISO3104	2.763		-0.33	1710	ISO3104	2.761		-0.51

1720		-----		1872	ISO3104	2.760		-0.60
1724	D445	2.769	0.22	1884	D445	2.764		-0.24
1730	D445	2.788	1.94	1896	ISO3104	2.770		0.31
1776	D7042	2.7932	2.41	1906		-----		-----
1792	D445	2.768	0.13	1938	ISO3104	2.7704		0.34
1807	D445	2.779	1.12	1944	D445	2.7586		-0.73
1810	D445	2.766	-0.06	1948	D445	2.7671		0.04
1811	ISO3104	2.7772	0.96	1951	D445	2.750		-1.51
1833	D445	2.767	0.03	2129	D445	2.7825		1.44
1842	IP71	2.759	-0.69	7012	D445	2.345	C,R(0.01)	-38.22
1849	ISO3104	2.76	-0.60					

normality OK
 n 132
 outliers 7
 mean (n) 2.7666
 st.dev. (n) 0.01023
 R(calc.) 0.0286
 R(D445:14e2) 0.0309

Lab 120: First reported 2.735
 Lab 140: First reported 2.799
 Lab 224: First reported 2.897
 Lab 228: First reported 2.824
 Lab 1171: First reported 2.7313
 Lab 1182: Result withdrawn, reported 2.81
 Lab 1395: First reported 2.808





Determination of Lubricity by HFRR on sample #14175; result in µm

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854	D6079	320		1.16
92		----		----	862	D6079	264.5		-0.79
120	D6079	200		-3.04	863	D6079	319		1.12
132	D6079	231		-1.96	873	D6079	367		2.80
140	D6079	274.5		-0.44	874		----		----
150	D6079	335.0		1.68	875		----		----
158		----		----	887		----		----
159	D6079	330.0		1.51	902		----		----
169		----		----	922		----		----
171	D6079	313.5		0.93	951		----		----
175	D6079	340		1.86	962		----		----
186		----		----	963	D6079	356.5		2.43
193		----		----	970		----		----
194		----		----	971		----		----
212		----		----	974	D6079	298		0.39
217		----		----	994		----		----
221		----		----	995	D6079	307		0.70
224		----		----	996		----		----
225		----		----	997		----		----
228		----		----	998		----		----
230		----		----	1006	D6079	300		0.46
238		----		----	1011	ISO12156-1	239		-1.68
240		----		----	1017		----		----
242		----		----	1033	ISO12156-1	349		2.17
252		----		----	1059	ISO12156-1	347		2.10
253		----		----	1067	D7688	338		1.79
254		----		----	1080		----		----
256		----		----	1081	ISO12156-1	307		0.70
258		----		----	1082	ISO12156-1	337.5		1.77
273		----		----	1095		----		----
311	ISO12156-1	309		0.77	1107	ISO12156	286		-0.03
312	ISO12156-1	296		0.32	1109	IP450	297		0.35
323	D6079	327		1.40	1121		----		----
332		----		----	1124		----		----
334	D6079	278		-0.31	1134		----		----
335	ISO12156	206		-2.83	1146		----		----
336		----		----	1159		----		----
337		----		----	1161	ISO12156-1	249.62		-1.31
338		----		----	1167	ISO12156-1	281.84		-0.18
340	D6079	310		0.81	1171		----		----
343	D6079	327		1.40	1182		----		----
344		----		----	1191	ISO12156-1	234		-1.85
349		----		----	1201	D6079	322		1.23
350		----		----	1227		----		----
353		----		----	1229	ISO12156-1	276		-0.38
356	D6079	252		-1.22	1259	ISO12156-1	206		-2.83
360	ISO12156-1	270		-0.59	1297		----		----
430	D6079	192		-3.32	1299	ISO12156-1	249		-1.33
431		----		----	1340	ISO12156-1	315		0.98
445	D6079	253		-1.19	1379		----		----
447	ISO12156-1	363		2.66	1382		----		----
463	ISO12156	211.2		-2.65	1395	D6079	331		1.54
485		----		----	1409	ISO12156-1	304		0.60
491		----		----	1417	INH-96	317		1.05
493		----		----	1428	ISO12156-1	241		-1.61
494	D6079	329		1.47	1430		----		----
496	D6079	308		0.74	1431		----		----
507	D6079	219.5		-2.36	1457	D6079	348.0		2.14
511		----		----	1459		----		----
541		----		----	1498		----		----
557		----		----	1510		----		----
562		----		----	1521		----		----
575		----		----	1556	ISO12156-1	285		-0.07
603		----		----	1564	ISO12156-1	259		-0.98
604		----		----	1575		----		----
607		----		----	1586	ISO12156-1	271		-0.56
608		----		----	1616	D6079	222		-2.27
631	D7688	240		-1.64	1629		----		----
657	D6079	340		1.86	1634		----		----
671		----		----	1635	D6079	206		-2.83
732		----		----	1643		----		----
759		----		----	1654		----		----
781	D6079	345		2.03	1677	D6079	209		-2.73
823	D6079	313.0		0.91	1709	D6079	305.5		0.65
824	D6079	330		1.51	1710	ISO12156-1	230		-1.99

1720		----		1872		----
1724	ISO12156-1	239	-1.68	1884		----
1730		----		1896	ISO12156-1	185
1776	ISO12156-1	319	1.12	1906		----
1792	ISO12156-1	250	-1.29	1938		----
1807	ISO12156-1	262	-0.87	1944	D6079	229
1810	D6079	197	-3.15	1948	D6079	240
1811	D6079	324	1.30	1951	D6079	355
1833	D6079	344	2.00	2129	D6079	382
1842		----		7012		----
1849	ISO12156-1	319	1.12			

normality	OK	<u>Only D6079</u>	OK	<u>Only D7688/ISO12156/IP450</u>
n	78	OK	43	OK
outliers	0	43	0	35
mean (n)	287.0	0	295.2	0
st.dev. (n)	50.17	295.2	52.75	276.8
R(calc.)	140.5	52.75	147.7	45.50
R(D6079:11)	80.0	147.7	80.0	127.4
		80.0		102.0





Determination of Nitrogen on sample #14175; result in mg/kg

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825		----		----
53		----		----	854		----		----
92		----		----	862	D4629	58.4		-0.37
120		----		----	863	D4629	63.9		1.96
132		----		----	873		----		----
140	D4629	59.5		0.10	874		----		----
150	D4629	56.1		-1.34	875	D4629	62		1.15
158	D4629	55.1		-1.76	887		----		----
159	D4629	52		-3.07	902		----		----
169		----		----	922		----		----
171	D4629	64.0		2.00	951		----		----
175		----		----	962		----		----
186		----		----	963		----		----
193		----		----	970		----		----
194		----		----	971	D4629	62.2		1.24
212		----		----	974		----		----
217		----		----	994	D4629	59.93		0.28
221		----		----	995	D3228	60.2		0.39
224		----		----	996		----		----
225		----		----	997		----		----
228		----		----	998		----		----
230		----		----	1006		----		----
238		----		----	1011		----		----
240		----		----	1017		----		----
242		----		----	1033		----		----
252		----		----	1059		----		----
253		----		----	1067		----		----
254		----		----	1080		----		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311	D4629	64		2.00	1107	D4629	59		-0.11
312	D4629	60		0.31	1109	D4629	62.8		1.49
323	D4629	63		1.58	1121		----		----
332		----		----	1124		----		----
334		----		----	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161		----		----
338		----		----	1167		----		----
340		----		----	1171		----		----
343	D5291	<0.1	U	----	1182		----		----
344		----		----	1191	D4629	60		0.31
349		----		----	1201	D4629	64.46		2.19
350		----		----	1227	D4629	60.5		0.52
353		----		----	1229	D4629	58		-0.54
356		----		----	1259	D4629	51.94		-3.10
360		----		----	1297	D4629	57.9		-0.58
430		----		----	1299		----		----
431		----		----	1340	D4629	58.625		-0.27
445	D4629	52.9		-2.69	1379		----		----
447		----		----	1382		----		----
463	D4629	59.2		-0.03	1395	D4629	31.3	R(0.01)	-11.83
485		----		----	1409		----		----
491		----		----	1417		----		----
493		----		----	1428		----		----
494	D4629	59.5		0.10	1430		----		----
496		----		----	1431		----		----
507		----		----	1457	D4629	57.13		-0.91
511		----		----	1459		----		----
541		----		----	1498		----		----
557		----		----	1510		----		----
562		----		----	1521		----		----
575		----		----	1556	D4629	58.9		-0.16
603		----		----	1564	D4629	56.5		-1.17
604		----		----	1575		----		----
607		----		----	1586		----		----
608		----		----	1616	D4629	59.06		-0.09
631		----		----	1629		----		----
657	D4629	54.8		-1.89	1634		----		----
671		----		----	1635	D4629	57.1		-0.92
732		----		----	1643		----		----
759		----		----	1654		----		----
781	D4629	61.36		0.88	1677		----		----
823	D4629	61.6		0.98	1709		----		----
824		----		----	1710	D4629	60.0		0.31

1720	D4629	58.0		-0.54	1872	----	----
1724		----		----	1884	----	----
1730		----		----	1896	D4629	63
1776	D4629	58.7		-0.24	1906	----	----
1792		----		----	1938	----	----
1807		----		----	1944	----	----
1810		----		----	1948	----	----
1811		----		----	1951	----	----
1833	D4629	60.3		0.43	2129	----	----
1842	INH-12	45	R(0.01)	-6.03	7012	----	----
1849		----		----			

normality OK
 n 39
 outliers 2
 mean (n) 59.27
 st.dev. (n) 3.176
 R(calc.) 8.89
 R(D4629:12) 6.62

Lab 343: reported test method is not applicable for low Nitrogen amounts. Result probably reported in %m/m





Determination of Pour Point (Manual) on sample #14175; result in °C

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825	D97	-24		0.97
53		----		----	854	D97	-27		-0.30
92	D97	<-30		----	862	D97	-27		-0.30
120	D97	-24		0.97	863	D97	-27		-0.30
132	D97	<-27		----	873	D97	-24		0.97
140	D97	-27		-0.30	874	D97	-24		0.97
150	D97	-27		-0.30	875	D97	-24		0.97
158		----		----	887		----		----
159	D97	-27		-0.30	902		----		----
169	D97	-30		-1.57	922	D97	-30.0		-1.57
171	D97	-24.0		0.97	951	D97	< -21		----
175		----		----	962		----		----
186		----		----	963	D97	-27		-0.30
193		----		----	970		----		----
194		----		----	971	D97	-30		-1.57
212	ISO3016	-30		-1.57	974	D97	-30		-1.57
217	D97	-27		-0.30	994	D97	-27		-0.30
221	D97	-27		-0.30	995	D97	-24		0.97
224	D97	-29		-1.15	996		----		----
225	D97	<-24		----	997	D97	-24		0.97
228	D97	<-18		----	998	D97	-24.0		0.97
230	D97	-26.7		-0.17	1006	D97	-24		0.97
238	D97	< - 24		----	1011	D97	-27		-0.30
240	D97	-24		0.97	1017		----		----
242		----		----	1033	IP15	-27		-0.30
252		----		----	1059	ISO3016	-24		0.97
253	D97	-27		-0.30	1067		----		----
254		----		----	1080		----		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311		----		----	1107		----		----
312		----		----	1109		----		----
323	D97	-24		0.97	1121	IP15	-27		-0.30
332		----		----	1124		----		----
334		----		----	1134		----		----
335		----		----	1146	ISO3016	-24.7		0.67
336		----		----	1159		----		----
337	D97	-27		-0.30	1161	D97	-27		-0.30
338		----		----	1167	ISO3016	-27		-0.30
340		----		----	1171	ISO3016	-24.0		0.97
343	D97	-27		-0.30	1182		----		----
344		----		----	1191		----		----
349		----		----	1201	D97	-27		-0.30
350		----		----	1227	D97	-24		0.97
353	IP15	-27		-0.30	1229		----		----
356	D97	-27		-0.30	1259	D97	-27		-0.30
360	D97	-27		-0.30	1297		----		----
430		----		----	1299	D97	-24		0.97
431		----		----	1340		----		----
445	D97	-24		0.97	1379		----		----
447		----		----	1382		----		----
463		----		----	1395	D97	-24		0.97
485		----		----	1409		----		----
491		----		----	1417		----		----
493		----		----	1428	ISO3016	-21		2.24
494		----		----	1430		----		----
496	D97	-24.0		0.97	1431		----		----
507	D97	-27		-0.30	1457	D97	-24		0.97
511		----		----	1459	ISO3016	-27		-0.30
541	D97	<-21		----	1498	D97	-27		-0.30
557		----		----	1510		----		----
562	D97	-27.0		-0.30	1521	ISO3016	-27		-0.30
575		----		----	1556		----		----
603	D97	-24		0.97	1564		----		----
604	D97	-30		-1.57	1575		----		----
607		----		----	1586	D97	-27		-0.30
608	D97	-30		-1.57	1616	D97	-24		0.97
631	D97	-27		-0.30	1629		----		----
657	D97	-27		-0.30	1634		----		----
671	D97	-27		-0.30	1635		----		----
732	D97	-27		-0.30	1643		----		----
759	D97	-24		0.97	1654		----		----
781	D97	-24		0.97	1677	D97	-30		-1.57
823	D97	-27		-0.30	1709		----		----
824	ISO3016	-24		0.97	1710	ISO3016	-27		-0.30

1720		----		----	1872		----		----
1724	D97	-27		-0.30	1884	D97	-33		-2.85
1730	D97	-27.0		-0.30	1896	ISO3016	-27		-0.30
1776		----		----	1906		----		----
1792	D97	-27		-0.30	1938		----		----
1807	D97	< -24		----	1944	D97	-27		-0.30
1810		----		----	1948		----		----
1811		----		----	1951		----		----
1833		----		----	2129	D97	-24		0.97
1842	D97	-24		0.97	7012	D97	-27		-0.30
1849		----		----					

normality OK
n 81
outliers 0
mean (n) -26.29
st.dev. (n) 2.108
R(calc.) 5.90
R(D97:12) 6.60





Determination of Pour Point (Automated) on sample #14175; result in °C

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D5949	-26.0		-0.12	825		----		----
53		----		----	854		----		----
92		----		----	862	D5950	-27		-0.58
120		----		----	863		----		----
132		----		----	873		----		----
140	D5949	-27		-0.58	874		----		----
150	D5950	-27		-0.58	875		----		----
158		----		----	887		-24		0.80
159		----		----	902		----		----
169		----		----	922		----		----
171	D5950	-27.0		-0.58	951		----		----
175	D5950	-27		-0.58	962		----		----
186		----		----	963		----		----
193		----		----	970		----		----
194		----		----	971		----		----
212		----		----	974		----		----
217		----		----	994		----		----
221		----		----	995		----		----
224		----		----	996		----		----
225		----		----	997		----		----
228		----		----	998		----		----
230		----		----	1006		----		----
238		----		----	1011	D6892	-24		0.80
240		----		----	1017	D5950	-24		0.80
242		----		----	1033		----		----
252		----		----	1059		----		----
253		----		----	1067	D5950	-24.0		0.80
254		----		----	1080	D6749	-24		0.80
256		----		----	1081	D5950	-24		0.80
258		----		----	1082	D5950	-27		-0.58
273		----		----	1095		----		----
311	D5950	-24		0.80	1107	D5950	-24		0.80
312	D5950	-25		0.34	1109		----		----
323	D5950	-24		0.80	1121		----		----
332		----		----	1124	ISO3016	-24	ex	0.80
334		----		----	1134		----		----
335	D5950	-27		-0.58	1146		----		----
336		----		----	1159		----		----
337		----		----	1161	D6749	-25		0.34
338	INH-105	-27		-0.58	1167	D6749	-27		-0.58
340	ISO3016	-27.0	ex	-0.58	1171		----		----
343		----		----	1182	D5949	-24		0.80
344		----		----	1191		----		----
349		----		----	1201	D5950	-28		-1.04
350		----		----	1227		----		----
353		----		----	1229		----		----
356	D5950	-27		-0.58	1259		----		----
360		----		----	1297	D5950	-27		-0.58
430		----		----	1299		----		----
431		----		----	1340	ISO3016	-27	ex	-0.58
445	D5950	-24		0.80	1379		----		----
447		----		----	1382		----		----
463	D6892	-24.0		0.80	1395		----		----
485		----		----	1409		----		----
491		----		----	1417	D5950	-25		0.34
493		----		----	1428		----		----
494	D6892	-24		0.80	1430	D5950	-51	R(0.01)	-11.60
496		----		----	1431		----		----
507		----		----	1457		----		----
511		----		----	1459		----		----
541	D5950	-27		-0.58	1498		----		----
557		----		----	1510		----		----
562		----		----	1521		----		----
575		----		----	1556	ISO6016	-24	ex	0.80
603		----		----	1564	D5950	-27		-0.58
604		----		----	1575		----		----
607		----		----	1586	D5950	-27		-0.58
608		----		----	1616	D6749	-26		-0.12
631		----		----	1629		----		----
657	D5950	-27		-0.58	1634		----		----
671		----		----	1635	D5950	-27		-0.58
732		----		----	1643		----		----
759		----		----	1654		----		----
781		----		----	1677		----		----
823		----		----	1709	D5950	-27		-0.58
824		----		----	1710	D5950	-27		-0.58

1720		----		----	1872	----	----
1724		----		----	1884	----	----
1730	D5950	-27.0		-0.58	1896	----	----
1776	D5950	-24	C	0.80	1906	----	----
1792		----		----	1938	----	----
1807		----		----	1944	----	----
1810		----		----	1948	D5950	-27
1811	D5950	-25		0.34	1951	D5950	-27
1833	D5950	-27		-0.58	2129	D5950	-24
1842	D5950	-24		0.80	7012	----	----
1849		----		----			

normality OK
 n 45
 outliers 1 + 4 excl.
 mean (n) -25.73
 st.dev. (n) 1.437
 R(calc.) 4.02
 R(D5950:14) 6.10

Lab 340: result excluded, used test method is not an automated test method
 Lab 1124: result excluded, used test method is not an automated test method
 Lab 1340: result excluded, used test method is not an automated test method
 Lab 1556: result excluded, used test method is not an automated test method
 Lab 1776: First reported 924





Determination of Sulphur Content on sample #14175; result in mg/kg

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D5453	8.7		-0.03	825	D5453	9.5		0.73
53	D5453	9.6		0.82	854	D5453	8.6		-0.13
92	D5453	7.5		-1.17	862	D5453	9.3		0.54
120	D5453	11.2		2.34	863	D5453	9.24		0.48
132	D5453	9.36		0.60	873	ISO20846	9.3		0.54
140	D5453	9.87		1.08	874	D5453	8.70		-0.03
150	D5453	8.6		-0.13	875	D5453	8.895		0.15
158	D5453	7.6		-1.08	887		----		----
159	D5453	9.2		0.44	902		----		----
169	D5453	10.92		2.08	922	D5453	6.95		-1.70
171	D5453	7.5		-1.17	951	D4294	<17		----
175	D5453	8.7		-0.03	962		----		----
186		----		----	963	D5453	8.6		-0.13
193		----		----	970	D5453	8.40		-0.32
194		----		----	971	D5453	9.611		0.83
212		----		----	974		----		----
217	D5453	8.26		-0.45	994	D5453	8.82		0.08
221		----		----	995	D5453	8.81		0.07
224		----		----	996		----		----
225		----		----	997		----		----
228		----		----	998		----		----
230		----		----	1006	D5453	8.7		-0.03
238		----		----	1011	ISO20846	8.5		-0.22
240		----		----	1017	ISO20846	9.46		0.69
242		----		----	1033		----		----
252		----		----	1059	ISO20846	8.4		-0.32
253		----		----	1067	D5453	8.7		-0.03
254		----		----	1080	D5453	9.2		0.44
256	D4294	<17		----	1081	ISO20846	8.8		0.06
258	D5453	8.47		-0.25	1082		----		----
273	D5453	8.29		-0.42	1095		----		----
311	D5453	7.9		-0.79	1107	D5453	8.3		-0.41
312	D5453	8.4		-0.32	1109	D7039	8.6		-0.13
323	D5453	8.4		-0.32	1121		----		----
332		----		----	1124	EN20846	8.72		-0.01
334	D5453	8.6		-0.13	1134		----		----
335	ISO20846	9.1		0.35	1146	D4294	40	R(0.01)	29.72
336	ISO20846	8.5		-0.22	1159		----		----
337	D5453	7.9		-0.79	1161	ISO20846	9.4		0.63
338	ISO20846	8.66		-0.07	1167	ISO20846	7.38		-1.29
340	D5453	8.08		-0.62	1171	ISO20846	9.35		0.59
343	ISO20846	9.38		0.61	1182	ISO20846	8.5		-0.22
344	D5453	8.693		-0.04	1191	ISO20846	9.3		0.54
349		----		----	1201	D5453	9.28		0.52
350		----		----	1227	D5453	8.6		-0.13
353	IP531	9.2		0.44	1229	ISO20846	9.65		0.87
356	ISO20846	9.20		0.44	1259	D5453	8.54		-0.18
360	D5453	9.13		0.38	1297	D5453	9.19		0.43
430		----		----	1299	ISO20884	6.3		-2.31
431		----		----	1340	ISO20846	8.95		0.21
445	D5453	9.02		0.27	1379		----		----
447	D5453	8.1		-0.60	1382	SH/T0689	9.11		0.36
463	D5453	7.82		-0.87	1395	D5453	8.3		-0.41
485		----		----	1409	ISO20846	8.5		-0.22
491		----		----	1417		----		----
493		----		----	1428	ISO20846	8.2		-0.51
494	D5453	8.6		-0.13	1430	In house	50	R(0.01)	39.23
496	D5453	7.95		-0.75	1431	D7220	8.5		-0.22
507		----		----	1457	D5453	8.74		0.01
511	D5453	10.47		1.65	1459	in house	6.7		-1.93
541		----		----	1498	D5453	7.7		-0.98
557		----		----	1510		----		----
562	D5453	9.24		0.48	1521		----		----
575		----		----	1556	ISO20884	8.2		-0.51
603		----		----	1564	ISO8754	9.8		1.01
604		----		----	1575		----		----
607		----		----	1586	D5453	9.2		0.44
608		----		----	1616	D5453	8.24		-0.47
631	D5453	9.57		0.79	1629		----		----
657	D5453	8.0		-0.70	1634	ISO20846	9.0		0.25
671	D5453	8.60		-0.13	1635	D5453	11.8		2.91
732	D4294	<100		----	1643		----		----
759	D4294	8		-0.70	1654		----		----
781	D5453	8.77		0.03	1677	D5453	8.72		-0.01
823	D5453	8.78		0.04	1709	D5453	8.7		-0.03
824	D5453	9.0		0.25	1710	ISO20846	8.9		0.16

1720	D5453	8.71	-0.02	1872	ISO20884	8.09	-0.61
1724	D5453	8.6	-0.13	1884	D5453	9.2	0.44
1730	ISO20846	8.64	-0.09	1896		----	----
1776	ISO20846	8.2	-0.51	1906		----	----
1792	D7220	8.3	-0.41	1938	ISO20846	8.8	0.06
1807	D5453	10.3	1.49	1944	D5453	8.74	0.01
1810	D5453	9.0	0.25	1948	D5453	10.04	1.24
1811	D5453	7.6	-1.08	1951	D5453	6.0	-2.60
1833	D5453	8.6	-0.13	2129	D5453	9.12	0.37
1842	D5453	8.6	-0.13	7012	D4294	42	31.63
1849	ISO20846	8.72	-0.01				

normality not OK
 n 113
 outliers 3
 mean (n) 8.734
 st.dev. (n) 0.8317
 R(calc.) 2.329
 R(D5453:12) 2.945





Determination of Water Content on sample #14175; result in mg/kg

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D6304	41.8		-0.09	825		----		----
53		----		----	854	D6304-A	47.5		0.01
92	E203	85		0.62	862	D6304-A	36.0		-0.18
120	D6304	79	C	0.52	863	D6304-C	40		-0.12
132	D6304-A	39.7		-0.12	873	D6304	39		-0.13
140	D6304	36.6		-0.17	874	D6304	40.0		-0.12
150	D6304-C	59		0.20	875		----		----
158	D6304	61.5		0.24	887	D6304-A	45		-0.03
159		----		----	902	D6304-A	65.5		0.30
169		----		----	922	D6304	34.8		-0.20
171	D6304-A	43.0		-0.07	951		----		----
175		----		----	962	D6304	70		0.38
186		----		----	963	D6304-A	50		0.05
193	D6304	61		0.23	970	D6304	40		-0.12
194		----		----	971	D6304	43.89		-0.05
212		----		----	974	D6304-A	48		0.02
217	D6304	55.8		0.14	994	D6304-A	49.03		0.03
221		----		----	995	D6304	46.4		-0.01
224		----		----	996		----		----
225	D6304-A	69.85		0.37	997	D6304	44		-0.05
228		----		----	998	D6304	45		-0.03
230	D95	<500		----	1006	D6304-A	65		0.29
238		----		----	1011	ISO12937	55		0.13
240		----		----	1017		----		----
242	D95	<500		----	1033	IP438	23		-0.40
252		----		----	1059	ISO12937	50		0.05
253		----		----	1067	ISO12937	40		-0.12
254		----		----	1080		----		----
256	D6304	36		-0.18	1081	ISO12937	46		-0.02
258	D6304	42		-0.08	1082	ISO12937	43		-0.07
273	D6304	45		-0.03	1095		----		----
311	D6304-A	43		-0.07	1107	D6304	43		-0.07
312	ISO12937	49		0.03	1109	D6304-C	44.3		-0.05
323	D6304-A	46		-0.02	1121	IP438	42		-0.08
332	ISO12937	45.6		-0.02	1124	ISO12937	41.91		-0.09
334	D6304-A	44		-0.05	1134		----		----
335	ISO12937	40		-0.12	1146	D6304-C	18		-0.48
336	ISO12937	50		0.05	1159		----		----
337	ISO12937	45		-0.03	1161	ISO12937	38.672		-0.14
338	D6304	51.29		0.07	1167	ISO12937	46.6		-0.01
340	D6304-A	42.9		-0.07	1171	ISO12937	53.30		0.10
343	ISO12937	46		-0.02	1182		----		----
344	ISO12937	41.9		-0.09	1191	ISO12937	35		-0.20
349	D6304	49		0.03	1201	ISO12937	35		-0.20
350	ISO12937	58.13		0.18	1227	D6304	41.8		-0.09
353	IP439	63		0.26	1229	ISO12937	48.65		0.03
356	D6304-A	48.2		0.02	1259	ISO12937	49		0.03
360	D6304-A	43.1		-0.07	1297	D6304	42.3		-0.08
430		----		----	1299	ISO12937	50		0.05
431		----		----	1340	ISO12937	44.113		-0.05
445	D6304	38.9		-0.13	1379	D6304	44		-0.05
447	IP438	44		-0.05	1382	ISO12937	45.2		-0.03
463	D6304	33		-0.23	1395	D6304	63.6		0.27
485	D6304-A	41.0		-0.10	1409	ISO12937	42		-0.08
491		----		----	1417	D6304-A	55		0.13
493		----		----	1428	ISO12937	54		0.11
494	D6304-A	44		-0.05	1430	D6304-A	16		-0.51
496	D6304-A	46.5		-0.01	1431	D6304-A	43.51		-0.06
507		----		----	1457	ISO12937	51		0.06
511		----		----	1459	ISO12937	33		-0.23
541	D6304-A	41		-0.10	1498		----		----
557		----		----	1510	D6304	41		-0.10
562		----		----	1521		----		----
575		----		----	1556	ISO12937	45.5		-0.03
603	D6304	71.5		0.40	1564	ISO12937	37.5		-0.16
604		----		----	1575	D6304	54.4		0.12
607	D95	<500		----	1586	D6304-A	37		-0.17
608		----		----	1616	UOP481	42.6		-0.07
631	D6304-B	53		0.10	1629		----		----
657	D6304-A	47		0.00	1634	D6304	44		-0.05
671		----		----	1635	D6304	49.0		0.03
732		----		----	1643	ISO6296	76	C	0.48
759		----		----	1654		----		----
781	D6304	46.23		-0.01	1677	D6304-A	51.5		0.07
823	D6304	45.3		-0.03	1709		----		----
824	D6304-A	45		-0.03	1710	ISO12937	37.2		-0.16

1720		-----		1872	ISO12937	41.2	C	-0.10
1724	ISO12937	49	0.03	1884	D6304	40		-0.12
1730	ISO12937	72	0.41	1896	ISO12937	46.1		-0.02
1776	ISO12937	25	-0.36	1906	D6304	65.27		0.30
1792	ISO12937	42	-0.08	1938	ISO12937	42		-0.08
1807	ISO12937	47	0.00	1944	D6304-A	38		-0.15
1810	D6304-A	45	-0.03	1948	D6304	79.65		0.54
1811	ISO12937	45	-0.03	1951	D6304	43		-0.07
1833	D6304-A	64	0.28	2129	IP438	54.0		0.11
1842	D6304	45	-0.03	7012	D95	<1000		-----
1849	ISO12937	55	0.13					

normality not OK
 n 124
 outliers 0
 mean (n) 47.09
 st.dev. (n) 11.183
 R(calc.) 31.31
 R(D6304:07) 170.38

Lab 120: First reported 147
 Lab 1643: First reported 0.0076
 Lab 1872: First reported 0.00293



Determination of Water and sediment (D2709) on sample #14175; result in %V/V

lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52	D2709	0		----	825	D2709	0.00		----
53		----		----	854	D2709	<0.005		----
92	D2709	0		----	862	D2709	0		----
120	D2709	<0.005		----	863	D2709	<0.005		----
132	D2709	0		----	873		----		----
140		----		----	874	D2709	<0.005		----
150	D2709	<0.005		----	875		----		----
158		----		----	887		----		----
159		----		----	902		----		----
169		----		----	922		----		----
171	D2709	0.0000		----	951		----		----
175		----		----	962		----		----
186		----		----	963	D2709	0.005		----
193	D2709	<0.005		----	970		----		----
194		----		----	971		----		----
212		----		----	974	D2709	0.005		----
217		----		----	994		----		----
221		----		----	995		----		----
224		----		----	996		----		----
225		----		----	997	D2709	0.0		----
228		----		----	998		----		----
230		----		----	1006		----		----
238		----		----	1011		----		----
240		----		----	1017		----		----
242		----		----	1033		----		----
252		----		----	1059		----		----
253		----		----	1067		----		----
254		----		----	1080		----		----
256		----		----	1081		----		----
258		----		----	1082		----		----
273		----		----	1095		----		----
311		----		----	1107		----		----
312		----		----	1109	D2709	0		----
323	D2709	0		----	1121		----		----
332		----		----	1124		----		----
334		----		----	1134		----		----
335		----		----	1146		----		----
336		----		----	1159		----		----
337		----		----	1161		----		----
338		----		----	1167		----		----
340	D2709	<0.0025		----	1171		----		----
343	D2709	<0.005		----	1182		----		----
344	D2709	<0.05		----	1191		----		----
349		----		----	1201	D2709	0		----
350		----		----	1227		----		----
353		----		----	1229		----		----
356	D2709	<0.05		----	1259		----		----
360	D2709	< 0.005		----	1297		----		----
430		----		----	1299		----		----
431		----		----	1340		----		----
445	D2709	0		----	1379		----		----
447		----		----	1382		----		----
463	D2709	<0.005		----	1395		----		----
485		----		----	1409		----		----
491		----		----	1417		----		----
493		----		----	1428		----		----
494		----		----	1430		----		----
496		----		----	1431		----		----
507	D2709	0.00		----	1457	D2709	0		----
511	D2709	<0.005		----	1459		----		----
541	D2709	<0.05		----	1498	D2709	0		----
557		----		----	1510		----		----
562	D2709	0.000		----	1521		----		----
575		----		----	1556		----		----
603		----		----	1564		----		----
604		----		----	1575	D2709	<0.05		----
607		----		----	1586	D2709	0.05	False positive?	----
608		----		----	1616		----		----
631	D2709	0		----	1629		----		----
657	D2709	0		----	1634		----		----
671	D2709	<0.01		----	1635		----		----
732		----		----	1643		----		----
759		----		----	1654		----		----
781	D2709	0.000		----	1677		----		----
823	D2709	0		----	1709		----		----
824		----		----	1710		----		----

1720	----	----	1872	----	----
1724	----	----	1884	----	----
1730	----	----	1896	D2709	0
1776	----	----	1906	----	----
1792	D2709	0.005	1938	----	----
1807	----	----	1944	D2709	0.005
1810	----	----	1948	----	----
1811	----	----	1951	----	----
1833	----	----	2129	----	----
1842	----	----	7012	----	----
1849	----	----	----	----	----

normality	not OK
n	25
outliers	0
mean (n)	<0.05
st.dev. (n)	n.a.
R(calc.)	n.a.
R(D2709:96e1)	n.a.

Determination of Water and sediment (D1796) on sample #14175; result in %V/V



lab	method	value	mark	z(targ)	lab	method	value	mark	z(targ)
52		----		----	825	D1796	0.00		----
53		----		----	854				----
92	D1796	0		----	862	D1796	0.00		----
120	D1796	<0.05		----	863				----
132	ISO3734	0.00		----	873				----
140	D1796	0.0		----	874	D1796	<0.05		----
150		----		----	875				----
158		----		----	887				----
159		----		----	902				----
169	D1796	0.000		----	922	D1796	<0.05		----
171	D1796	0.0000		----	951				----
175		----		----	962				----
186		----		----	963				----
193		----		----	970				----
194		----		----	971				----
212		----		----	974	D1796	0.00		----
217		----		----	994				----
221		----		----	995				----
224		----		----	996				----
225		----		----	997				----
228		----		----	998				----
230		----		----	1006	D1796	<0.05		----
238		----		----	1011				----
240		----		----	1017				----
242		----		----	1033				----
252		----		----	1059				----
253		----		----	1067				----
254		----		----	1080				----
256		----		----	1081				----
258		----		----	1082				----
273		----		----	1095				----
311		----		----	1107				----
312		----		----	1109	D1796	0.00		----
323		----		----	1121				----
332		----		----	1124				----
334		----		----	1134				----
335		----		----	1146				----
336		----		----	1159				----
337		----		----	1161				----
338		----		----	1167				----
340		----		----	1171				----
343	D1796	0.0		----	1182				----
344		----		----	1191				----
349		----		----	1201				----
350		----		----	1227				----
353		----		----	1229				----
356		----		----	1259				----
360	D1796	< 0.005		----	1297				----
430		----		----	1299	D1796	0.01		----
431		----		----	1340				----
445		----		----	1379				----
447		----		----	1382				----
463	D1796	0.00		----	1395				----
485		----		----	1409				----
491		----		----	1417				----
493		----		----	1428				----
494		----		----	1430				----
496		----		----	1431				----
507	D1796	0		----	1457				----
511	D1796	<0.05		----	1459				----
541	D1796	<0.1		----	1498				----
557		----		----	1510				----
562		----		----	1521				----
575		----		----	1556				----
603		----		----	1564				----
604		----		----	1575				----
607		----		----	1586				----
608		----		----	1616	D1796	0.025		----
631		----		----	1629				----
657	D1796	0.00		----	1634				----
671		----		----	1635				----
732		----		----	1643				----
759		----		----	1654				----
781	D1796	0.00		----	1677				----
823	D1796	0		----	1709				----
824		----		----	1710				----

1720		----	----	1872	----	----
1724		----	----	1884	----	----
1730	D1796	0.01	----	1896	----	----
1776		----	----	1906	----	----
1792	D1796	0	----	1938	----	----
1807		----	----	1944	----	----
1810		----	----	1948	----	----
1811		----	----	1951	----	----
1833		----	----	2129	----	----
1842		----	----	7012	----	----
1849		----	----			

normality	not OK
n	19
outliers	0
mean (n)	<0.05
st.dev. (n)	n.a.
R(calc.)	n.a.
R(D1796:11e1)	n.a.

Determination of Cetane Number (ASTM D613) of sample #14176




lab	method	value	mark	z(targ)	remarks
120	D613	55.0		-0.01	
171	D613	53.82		-0.72	
311		-----		-----	
312	D613	56.4		0.83	
323	D613	55.1		0.05	
334	D613	57.3		1.37	
343		-----		-----	
356		-----		-----	
360	D613	54.64		-0.22	
370	D613	54.5		-0.31	
420	ISO5165	55.6		0.35	
430	D613	56.14		0.67	
445	D613	59.36	R(0.05)	2.60	
447	D613	55.4		0.23	
463	D613	55.09		0.04	
496	D613	56.01		0.60	
753	D613	53.68		-0.80	
862	D613	53.9		-0.67	
963		-----		-----	
1059		-----		-----	
1065	D613	59.2	R(0.05)	2.51	
1067		-----		-----	
1080		-----		-----	
1081		-----		-----	
1082	ISO5165	57.0		1.19	
1095		-----		-----	
1107		-----		-----	
1124	ISO5165	54.52		-0.30	
1131	ISO5165	54.0		-0.61	
1134		-----		-----	
1161		-----		-----	
1167		-----		-----	
1191		-----		-----	
1194	D613	55.1		0.05	
1201		-----		-----	
1229		-----		-----	
1259	ISO5165	55.99		0.58	
1299	D613	54.6		-0.25	
1300	ISO5165	54.32		-0.42	
1340	ISO5165	54.96		-0.03	
1395		-----		-----	
1428	D613	54.9		-0.07	
1457		-----		-----	
1538	ISO5165	54.6		-0.25	
1556	ISO5165	53.99		-0.61	
1616		-----		-----	
1635	D613	60.0	R(0.05)	2.98	
1710	ISO5165	54.7		-0.19	
1724	D613	53.1		-1.15	
1776		-----		-----	
1807		-----		-----	
1809		-----		-----	
1810		-----		-----	
1833	D613	54.35		-0.40	
1896		-----		-----	
1948	D613	56.74		1.03	
1951		-----		-----	
	normality	OK			
	n	29			
	outliers	3			
	mean (n)	55.016			
	st.dev. (n)	1.0353			
	R(calc.)	2.899			
	R(D613:13)	4.677			



Determination of Derived Cetane Number (D6890) of sample #14176

lab	method	value	mark	z(targ)	Ignition delay	Air Temp.	Remarks
120		----		----	----	----	
171	D7170	56.2	C,E	-1.46	2.95 C,G(0.01)	544.4	First reported 53.2, 3.14
311		----		----	----	----	
312		----		----	----	----	
323		----		----	----	----	
334		----		----	----	----	
343		----		----	----	----	
356		----		----	----	----	
360		----		----	----	----	
370		----		----	----	----	
420		----		----	----	----	
430	D6890	56.76		-0.92	3.568	522.4	
445	D6890	57.49		-0.22	3.519	579.0	
447		----		----	----	----	
463		----		----	----	----	
496		----		----	----	----	
753		----		----	----	----	
862		----		----	----	----	
963		----		----	----	----	
1059		----		----	----	----	
1065		----		----	----	----	
1067	D6890	58.07		0.33	3.4805	582.5	
1080		----		----	----	----	
1081		----		----	----	----	
1082		----		----	----	----	
1095		----		----	----	----	
1107		----		----	----	----	
1124		----		----	----	----	
1131	EN15195	54.41	G(0.05)	-3.18	3.736	585.5	
1134		----		----	----	----	
1161	D6890	58.42		0.67	3.458	585.2	
1167	D6890	56.93		-0.76	----	----	
1191	D6890	57.2		-0.50	3.541	570	
1194		----		----	----	----	
1201		----		----	----	----	
1229	D6890	58.56		0.80	3.449	547.5	
1259		----		----	----	----	
1299		----		----	----	----	
1300		----		----	----	----	
1340		----		----	----	----	
1395	D6890	57.4	E	-0.31	3.5	591.1	
1428		----		----	----	----	
1457	D6890	56.66		-1.02	3.574	548.5	
1538		----		----	----	----	
1556		----		----	----	----	
1616		----		----	----	----	
1635		----		----	----	----	
1710		----		----	----	----	
1724		----		----	----	----	
1776		----		----	----	----	
1807	EN15195	59.95		2.14	----	----	
1809		----		----	----	----	
1810		----		----	----	----	
1833		----		----	----	----	
1896	D6890	59.7	E	1.90	3.77	----	
1948	D6890	56.74		-0.94	3.569	583.6	
1951	D6890	58.03		0.30	3.483	578.4	
	normality	OK			not OK		<u>DCN after recalculation by iis</u>
	n	14			12		suspect
	outliers	1			1		13
	mean (n)	57.72			3.55		2
	st.dev. (n)	1.133			0.103		57.73
	R(calc.)	3.17			0.29		0.931
	R(D6890:13be1)	2.92			0.19		2.61
							2.91



Recalculated values by iis
 Lab 171: 57.97
 Lab 1395: 57.77
 Lab 1896: 53.96



Determination of Derived Cetane Number (D7668) of sample #14176



lab	method	value	mark	z(targ)	Ignition delay		Air Temp.	Remarks
120		----		----			----	
171		----		----			----	
311	D7668	55.1		-3.61	2.7969		589.09	
312		----		----			----	
323		----		----			----	
334		----		----			----	
343	D7668	58.3		1.73	2.61		595.05	
356	D7668	58.67		2.34	2.725		611.16	
360		----		----			----	
370		----		----			----	
420		----		----			----	
430		----		----			----	
445		----		----			----	
447		----		----			----	
463		----		----			----	
496		----		----			----	
753		----		----			----	
862		----		----			----	
963		----		----			----	
1059	D7668	57.01		-0.42	2.7618		603.17	
1065		----		----			----	
1067		----		----			----	
1080		----		----			----	
1081	D7668	56.09		-1.96	2.7936		----	
1082		----		----			----	
1095		----		----			----	
1107	D7668	57.2		-0.11	2.71		----	
1124		----		----			----	
1131		----		----			----	
1134		----		----			----	
1161		----		----			----	
1167		----		----			----	
1191		----		----			----	
1194		----		----			----	
1201	D7668	59.57	ex	3.85	2.87	ex	555.2	Air temp out of range (560 – 640°C)
1229		----		----			----	
1259		----		----			----	
1299	D7668	54.65		-4.36	----		----	
1300		----		----			----	
1340		----		----			----	
1395		----		----			----	
1428	D7668	57.87		1.01	2.7465		595.9	
1457		----		----			----	
1538		----		----			----	
1556	D7668	55.71	C, ex	-2.59	2.1651	C, G(0.01)	19.6 ex	First reported 56.06, 2.6397
1616		----		----			----	
1635		----		----			----	
1710		----		----			----	
1724		----		----			----	
1776	D7668	59.25		3.31	2.76		----	
1807		----		----			----	
1809		----		----			----	
1810		58.5		2.06	2.73		600	
1833		----		----			----	
1896		----		----			----	
1948		----		----			----	
1951		----		----			----	
	normality	OK				not OK		
	n	10 + 2 excl				9 + 1 excl.		
	outliers	0				1		
	mean (n)	57.26				2.74		
	st.dev. (n)	1.558				0.056		
	R(calc.)	4.36				0.16		
	R(D7668:14a)	1.68				0.12		

Lab 1556: result DCN was excluded, as ignition delay was a statistical outlier and Air Temperature was out of range.





Determination of Total Contamination on sample #14177; result in mg/kg

lab	method	value	mark	z(targ)	remarks
120	D6217	18.6		-3.53	
132	D6217	26.92		0.52	
150	D6217	25.4		-0.22	
159	D6217	27.62		0.86	
171	D6217	21.1		-2.31	
311	D6217	20.4		-2.65	
312	EN12662	27.9		1.00	
323	EN12662	<12.0		<-6.76	False negative result?
334	EN12662	28.0		1.05	
335	EN12662	27.4		0.76	
336	EN12662	26.9		0.51	
337	EN12662	27.8		0.95	
340	EN12662	26.93		0.53	
343	EN12662	23.1		-1.34	
349	EN12662	21.4		-2.17	
353	IP440	28.198		1.15	
360	EN12662	26.3		0.22	
445	D6217	23.23		-1.28	
447	IP440	21.0		-2.36	
463	EN12662	26.53		0.33	
494		-----		-----	
496	EN12662	27.07		0.60	
657	D6217	16.0		-4.80	
862	D6217	23.79		-1.00	
875	IP440	20.75		-2.48	
963	D6217	22.8		-1.48	
970		-----		-----	
974	D6217	23.33		-1.23	
1011	EN12662	26.8		0.46	
1033	IP440	14.9		-5.34	
1059	EN12662	31.7		2.85	
1081	EN12662	29.2		1.63	
1082	EN12662	28.05		1.07	
1095		-----		-----	
1107		-----		-----	
1134		-----		-----	
1167	EN12662	27.4		0.76	
1171	EN12662	29.54		1.80	
1191	EN12662	30.57		2.30	
1201	D6217	24.61		-0.60	
1229	EN12662	18		-3.82	
1259	EN12662	30.40		2.22	
1299	EN12662	23.2		-1.29	
1395	EN12662	10.3	R(0.05)	-7.58	
1409	EN12662	36.5		5.19	
1428	EN12662	24.5		-0.66	
1457	D6217	26.56		0.35	
1510		-----		-----	
1521	EN12662	35		4.46	
1556	EN12662	31.0		2.51	
1586	EN12662	25.1		-0.36	
1616	D6217	29.5		1.78	
1635	D6217	22		-1.87	
1654	EN12662	22.0		-1.87	
1710	EN12662	27.9		1.00	
1724	EN12662	26.7		0.42	
1807	EN12662	26.7		0.42	
1810	D6217	29.0		1.54	
1811	EN12662	43.07	R(0.05)	8.39	
1833	EN12662	27.32		0.72	
1938	EN12662	>30		>2.02	
1948	D6217	30.46		2.25	
1951	D6217	29.91		1.98	
2129	IP440	22.71		-1.53	
					<u>Only ASTM D6217 data</u>
	normality	OK			OK
	n	54			23
	outliers	2	<u>Spike</u>		0
	mean (n)	25.85	12.1		23.86
	st.dev. (n)	4.278			4.289
	R(calc.)	11.98			12.01
	R(D6217:11)	5.74			5.52
					Compare R(EN12662:08) = 7.76
					<u>Only EN12662 data</u>
					suspect
					36
					2
					26.51
					4.287
					12.00
					8.47



Determination of Oxidation Stability on sample #14178; result in mg/100ml

lab	method	value	mark	z(targ)	remarks
120	D2274	0.23		0.08	
132	D2274	0.0	ex	-0.82	Result excluded, zero is not a real result
140	D2274	0.10		-0.43	
159		----		----	
171		----		----	
230	ISO12205	0.26		0.19	
311	D2274	0.2		-0.04	
312	D2274	<0.1		----	
323	D2274	0.3		0.35	
334	D2274	0.4		0.74	
340	D2274	0.2		-0.04	
343	ISO12205	0.17		-0.16	
360	D2274	0.14		-0.28	
369	D2274	0.06		-0.59	
370	D2274	0.06		-0.59	
445	D2274	<0.1		----	
447	D2274	0.3		0.35	
463	ISO12205	0.14		-0.28	
494		----		----	
496	D2274	0.17		-0.16	
507	D2274	0.0055	ex,U	-0.80	Result excluded, probably unit error?
657	D2274	0.14		-0.28	
862	D2274	0.03		-0.70	
874	D2274	0.095		-0.45	
963	D2274	0.25		0.15	
974	D2274	0.257		0.18	
1011	ISO12205	3.46	R(0.01)	12.66	
1033		----		----	
1059	D2274	1.057	R(0.01)	3.30	
1081	D2274	0.2		-0.04	
1082	ISO12205	0.117		-0.37	
1095	ISO12205	0.2		-0.04	
1107	D2274	0.7	R(0.05)	1.91	
1109	D2274	0.35		0.54	
1134		----		----	
1167	ISO12205	0.6		1.52	
1191	ISO12205	0.39		0.70	
1201	D2274	0.09		-0.47	
1299	D2274	0.12		-0.35	
1395	D2274	0.9	R(0.01)	2.69	
1428	ISO12205	0.5		1.13	
1457	D2274	0.38		0.66	
1510		----		----	
1556		----		----	
1616	D2274	0.0009	ex,U	-0.82	Result excluded, probably unit error?
1654	ISO12205	0.229		0.07	
1709		----		----	
1710	D2274	0.09		-0.47	
1724		----	W	----	Result withdrawn, reported 2.57
1792	D2274	0.17		-0.16	
1807	ISO12205	0.3		0.35	
1833	ISO12205	0.271	C	0.24	First reported 1.71
1948	D2274	0.1714		-0.15	
1951	D2274	0.086		-0.49	
2129	D2274	0.028		-0.71	
	normality	not OK			
	n	37			
	outliers	4	+ 3 excl.		
	mean (n)	0.211			
	st.dev. (n)	0.1298			
	R(calc.)	0.363			
	R(D2274:10)	0.718			



APPENDIX 2 z-scores Distillation

Automated							Manual					
lab	IBP	10%rec	50%rec	90%rec	95%rec	FBP	IBP	10%rec	50%rec	90%rec	95%rec	FBP
52	-0.39	-1.14	0.25	-1.15	-0.87	-1.04	----	----	----	----	----	----
53	----	----	----	----	----	----	----	----	----	----	----	----
92	1.29	1.16	-0.31	-1.44	-1.22	-0.76	----	----	----	----	----	----
120	-0.93	-0.96	-1.16	-0.25	-0.07	-1.83	----	----	----	----	----	----
132	-0.36	0.31	-0.50	-1.10	-1.15	-0.92	----	----	----	----	----	----
140	0.06	0.80	-1.73	-1.27	-0.42	-0.80	----	----	----	----	----	----
150	-1.36	-2.48	-0.50	0.25	0.51	-0.29	----	----	----	----	----	----
158	-1.36	0.19	-3.33	-2.00	-0.55	-0.96	----	----	----	----	----	----
159	0.84	1.77	1.01	0.54	0.15	0.58	----	----	----	----	----	----
169	-0.12	-1.08	-0.78	0.09	0.31	0.26	----	----	----	----	----	----
171	-0.51	1.71	0.16	0.14	0.06	-0.57	----	----	----	----	----	----
175	0.99	-0.11	2.33	2.56	2.07	0.81	----	----	----	----	----	----
186	----	----	----	----	----	----	----	----	----	----	----	----
193	0.27	2.38	0.82	-0.20	-0.13	-0.76	----	----	----	----	----	----
194	----	----	----	----	----	----	----	----	----	----	----	----
212	0.03	1.71	0.44	2.11	2.17	0.22	----	----	----	----	----	----
217	0.51	-0.84	0.06	-0.25	-0.26	0.10	----	----	----	----	----	----
221	----	----	----	----	----	----	-1.61	-1.00	-0.95	0.33	-4.07	-1.31
224	0.66	-1.69	-0.78	0.50	0.54	0.93	----	----	----	----	----	----
225	----	----	----	----	----	----	0.18	0.24	-0.59	0.33	1.89	0.10
228	----	----	----	----	----	----	1.52	1.48	-0.95	0.33	0.80	-0.61
230	0.57	0.25	-0.12	-0.08	0.44	1.05	----	----	----	----	----	----
238	----	----	----	----	----	----	----	----	----	----	----	----
240	----	----	----	----	----	----	-0.27	-1.63	-0.23	0.33	1.89	-0.61
242	----	----	----	----	----	----	----	----	----	----	----	----
252	----	----	----	----	----	----	0.63	-1.63	-0.95	-0.37	-0.28	0.80
253	----	----	----	----	----	----	-1.17	0.55	-0.23	-0.37	1.07	0.10
254	----	----	----	----	----	----	0.63	-1.63	-0.23	-0.37	0.80	0.80
256	----	----	----	----	----	----	0.63	-0.38	-0.23	-0.37	----	0.10
258	1.11	0.37	-0.22	-0.70	-1.25	-1.71	----	----	----	----	----	----
273	-0.06	-0.60	-0.88	-0.82	-0.87	-1.32	----	----	----	----	----	----
311	-0.87	-1.14	-1.16	-0.37	-0.04	-0.09	----	----	----	----	----	----
312	-0.27	0.19	0.54	-0.37	-0.39	-1.08	----	----	----	----	----	----
323	0.45	1.04	0.54	0.37	0.70	-0.17	----	----	----	----	----	----
332	----	----	----	----	----	----	----	----	----	----	----	----
334	0.99	1.04	0.54	-0.48	-0.48	0.06	----	----	----	----	----	----
335	0.87	-0.78	-0.22	0.14	0.35	0.46	----	----	----	----	----	----
336	1.17	0.19	-0.60	-1.15	-0.52	0.58	----	----	----	----	----	----
337	1.62	0.74	0.25	0.25	-0.23	-0.17	----	----	----	----	----	----
338	1.17	1.16	0.72	1.21	1.18	0.85	----	----	----	----	----	----
340	1.71	-1.45	0.44	0.93	0.86	0.26	----	----	----	----	----	----
343	----	----	----	----	----	----	----	----	----	----	----	----
344	-0.03	0.07	-0.12	-0.93	-1.19	-0.45	----	----	----	----	----	----
349	----	----	----	----	----	----	----	----	----	----	----	----
350	----	----	----	----	----	----	-2.58	-2.98	-1.10	-0.52	0.41	0.64
353	-3.91	-3.21	-1.63	0.42	0.31	0.66	----	----	----	----	----	----
356	1.17	1.89	1.48	1.04	1.11	1.56	----	----	----	----	----	----
360	-1.17	-0.17	-0.69	-0.08	-0.20	-1.28	----	----	----	----	----	----
430	----	----	----	----	----	----	----	----	----	----	----	----
431	-0.69	0.49	-0.12	1.77	2.65	-0.25	----	----	----	----	----	----
445	-0.09	-0.05	-0.41	-0.14	0.22	0.14	----	----	----	----	----	----
447	-1.51	0.25	0.44	-0.08	-0.29	0.42	----	----	----	----	----	----
463	-0.21	-0.05	0.44	0.76	0.89	1.09	----	----	----	----	----	----
485	0.58	0.80	-0.03	-0.51	-0.42	-1.43	----	----	----	----	----	----
491	----	----	----	----	----	----	----	----	----	----	----	----
493	----	----	----	----	----	----	----	----	----	----	----	----
494	-0.69	-0.78	-1.07	-0.87	-0.64	0.14	----	----	----	----	----	----
496	-0.27	-0.72	-0.88	-0.59	-0.36	0.38	----	----	----	----	----	----
507	----	----	----	----	----	----	3.05	2.35	1.59	1.38	-1.63	-2.37
511	----	----	----	----	----	----	0.85	-0.07	-1.68	-0.72	0.53	-0.61
541	0.93	0.19	0.25	-0.03	-0.26	0.58	----	----	----	----	----	----
557	----	----	----	----	----	----	----	----	----	----	----	----
562	-0.32	-0.87	-0.03	0.54	0.39	1.05	----	----	----	----	----	----
575	----	----	----	----	----	----	----	----	----	----	----	----
603	----	----	----	----	----	----	----	----	----	----	----	----
604	0.96	0.74	0.63	0.99	0.67	-1.28	----	----	----	----	----	----
607	----	----	----	----	----	----	----	----	----	----	----	----
608	0.09	0.07	0.16	-0.25	-0.20	0.10	----	----	----	----	----	----
631	----	----	----	----	----	----	0.18	-3.80	-1.68	-1.77	-1.90	-2.72
657	-1.60	-0.60	-1.63	-2.28	-1.92	-1.20	----	----	----	----	----	----
671	----	----	----	----	----	----	----	----	----	----	----	----
732	----	----	----	----	----	----	0.40	-0.07	0.14	1.03	1.62	1.51
759	----	----	----	----	----	----	-1.61	1.17	0.14	-0.72	-0.55	-0.25
781	-0.27	1.28	0.54	-0.03	-0.36	0.26	----	----	----	----	----	----
823	0.51	0.68	0.72	0.82	0.83	0.77	----	----	----	----	----	----

824	0.45	0.56	0.82	1.04	0.95	0.89	----	----	----	----	----	----
825	-0.96	0.74	-0.22	0.31	0.35	0.50	----	----	----	----	----	----
854	1.23	2.13	1.10	0.25	0.54	0.14	----	----	----	----	----	----
862	-2.47	-0.96	-0.50	-0.70	-0.48	-0.25	----	----	----	----	----	----
863	----	----	----	----	----	----	1.30	2.10	1.22	0.33	0.53	2.92
873	----	----	----	----	----	----	-0.72	1.48	0.50	-0.37	-0.01	0.45
874	----	----	----	----	----	----	0.63	1.48	0.50	0.68	1.89	0.10
875	0.03	1.10	0.72	0.03	-0.10	0.93	----	----	----	----	----	----
887	----	----	----	----	----	----	-0.72	0.24	-0.95	0.68	0.53	-0.96
902	----	----	----	----	----	----	----	----	----	----	----	----
922	----	----	----	----	----	----	-0.22	-1.56	-0.88	-0.23	-0.71	1.65
951	----	----	----	----	----	----	0.91	1.23	0.89	0.67	-0.02	-0.27
962	----	----	----	----	----	----	-0.27	0.24	0.50	1.03	-2.72	1.51
963	0.30	1.28	0.44	-0.31	-0.61	0.10	----	----	----	----	----	----
970	----	----	----	----	----	----	-2.06	0.24	1.22	-0.37	-0.28	-2.02
971	0.39	-0.60	0.16	0.93	-0.07	0.46	----	----	----	----	----	----
974	0.03	1.04	0.72	0.09	-0.20	-1.24	----	----	----	----	----	----
994	----	----	----	----	----	----	0.63	0.55	0.50	1.03	1.89	1.16
995	----	----	----	----	----	----	0.63	0.55	0.50	0.68	1.89	1.51
996	----	----	----	----	----	----	----	----	----	----	----	----
997	----	----	----	----	----	----	0.40	0.24	0.14	0.33	1.89	1.51
998	----	----	----	----	----	----	-0.04	0.86	0.50	0.33	1.07	1.16
1006	-0.09	0.07	-0.22	-0.93	-1.06	-1.04	----	----	----	----	----	----
1011	-0.18	0.80	0.35	0.31	0.25	0.73	----	----	----	----	----	----
1017	----	----	----	----	----	----	----	----	----	----	----	----
1033	1.20	1.65	2.04	0.87	-0.13	0.50	----	----	----	----	----	----
1059	-0.12	-1.08	-1.92	-1.89	-1.41	-1.20	----	----	----	----	----	----
1067	0.87	1.53	0.72	0.54	0.25	-1.20	----	----	----	----	----	----
1080	-2.50	-1.75	-0.78	-0.20	-0.13	0.02	----	----	----	----	----	----
1081	-0.24	1.04	1.20	1.77	2.07	0.73	----	----	----	----	----	----
1082	-0.09	-0.60	-0.12	0.37	0.31	-0.41	----	----	----	----	----	----
1095	----	----	----	----	----	----	----	----	----	----	----	----
1107	0.69	1.28	-0.12	-0.59	-0.39	-0.41	----	----	----	----	----	----
1109	0.72	0.31	0.25	-0.37	-0.55	0.46	----	----	----	----	----	----
1121	----	----	----	----	----	----	0.63	-1.00	1.95	2.43	1.35	2.22
1124	1.11	0.43	1.57	1.72	1.18	-0.72	----	----	----	----	----	----
1134	----	----	----	----	----	----	----	----	----	----	----	----
1146	0.09	-0.96	-1.44	-1.10	-1.22	-0.05	----	----	----	----	----	----
1159	----	----	----	----	----	----	2.43	1.58	1.18	0.47	0.86	-3.19
1161	-0.48	-5.81	-1.54	0.20	0.12	0.18	----	----	----	----	----	----
1167	-1.58	-2.87	-0.31	-0.42	-0.48	-0.21	----	----	----	----	----	----
1171	----	----	----	----	----	----	-1.60	-2.23	-0.92	-0.87	-0.30	-0.04
1182	-0.66	0.37	0.54	1.49	1.66	-0.37	----	----	----	----	----	----
1191	-0.42	0.01	0.44	1.04	0.79	0.46	----	----	----	----	----	----
1201	-0.84	-1.08	-1.16	-0.59	-0.32	-1.28	----	----	----	----	----	----
1227	1.02	-0.05	1.20	1.44	0.86	0.42	----	----	----	----	----	----
1229	0.21	0.01	0.06	0.14	0.06	0.62	----	----	----	----	----	----
1259	-0.51	-1.08	-0.97	-2.00	-2.34	0.46	-1.61	0.86	-0.95	-2.12	-3.26	0.45
1297	0.45	-0.29	-0.22	-0.82	-0.99	-0.72	----	----	----	----	----	----
1299	-1.05	-1.87	-1.35	-0.03	0.15	0.54	----	----	----	----	----	----
1340	1.35	0.25	0.82	1.16	1.78	0.34	----	----	----	----	----	----
1379	----	----	----	----	----	----	1.75	2.10	0.50	0.33	-1.90	-4.13
1382	----	----	----	----	----	----	-1.17	-1.00	0.50	-0.37	-0.82	-0.61
1395	1.11	0.92	0.06	-0.08	-0.45	0.18	----	----	----	----	----	----
1409	0.93	1.59	1.10	0.99	1.11	0.46	----	----	----	----	----	----
1417	0.57	-1.26	-0.12	0.48	0.89	0.22	----	----	----	----	----	----
1428	-0.03	-0.84	-0.22	-0.59	-0.52	0.06	----	----	----	----	----	----
1430	-5.78	2.86	6.85	6.11	1.53	-7.31	----	----	----	----	----	----
1431	0.96	1.83	1.29	0.87	1.02	1.72	----	----	----	----	----	----
1457	-0.15	-0.35	-0.41	-0.53	-0.42	0.81	----	----	----	----	----	----
1459	-0.51	0.43	0.06	-1.10	-1.19	-0.96	----	----	----	----	----	----
1498	-0.57	0.86	1.01	0.65	0.54	0.66	----	----	----	----	----	----
1510	-1.11	-0.96	-1.92	-0.93	-0.58	-1.43	----	----	----	----	----	----
1521	----	----	----	----	----	----	----	----	----	----	----	----
1556	-1.30	-1.57	-1.35	-0.87	-0.61	-0.49	----	----	----	----	----	----
1564	-0.93	0.49	-0.60	-0.82	-0.52	-0.41	----	----	----	----	----	----
1575	----	----	----	----	----	----	----	----	----	----	----	----
1586	-0.27	-1.63	-1.73	-0.37	-0.07	-0.02	----	----	----	----	----	----
1616	----	----	----	----	----	----	-2.51	-1.63	-0.95	-1.07	-1.36	0.10
1629	----	----	----	----	----	----	----	----	----	----	----	----
1634	0.33	0.07	-0.41	-0.70	-0.64	-0.13	----	----	----	----	----	----
1635	----	----	----	----	----	----	1.08	-0.38	-0.95	-1.77	-1.36	2.22
1643	----	----	----	----	----	----	----	----	----	----	----	----
1654	----	----	----	----	----	----	----	----	----	----	----	----
1677	-0.39	0.13	2.52	1.44	0.70	0.66	----	----	----	----	----	----
1709	-0.96	-0.96	-0.50	0.03	0.00	0.46	----	----	----	----	----	----
1710	-0.54	0.31	0.72	0.14	-0.07	0.06	----	----	----	----	----	----
1720	0.81	2.01	1.86	1.77	1.72	0.97	----	----	----	----	----	----
1724	-0.33	-0.90	-0.69	-0.65	-0.61	0.30	----	----	----	----	----	----
1730	-0.63	-0.23	2.61	0.76	0.47	0.93	----	----	----	----	----	----

1776	-0.90	-0.72	-0.78	0.65	0.89	-0.05	----	----	----	----	----	----
1792	-0.75	-0.05	-0.50	-0.42	-0.39	-1.87	----	----	----	----	----	----
1807	1.47	-0.42	-0.31	0.25	0.09	1.05	----	----	----	----	----	----
1810	0.36	-0.42	-0.50	-1.21	-1.54	-0.88	----	----	----	----	----	----
1811	0.21	-0.11	0.35	-0.08	-0.26	-0.17	----	----	----	----	----	----
1833	0.39	-0.54	-0.60	-0.37	-0.45	0.46	----	----	----	----	----	----
1842	-1.51	-0.72	-0.69	-0.70	-0.64	0.22	----	----	----	----	----	----
1849	0.15	0.13	-0.97	-0.76	-1.06	0.26	----	----	----	----	----	----
1872	----	----	----	----	----	----	----	----	----	----	----	----
1884	-0.24	-1.93	-1.63	-0.42	-0.26	-0.13	----	----	----	----	----	----
1896	-0.24	1.16	-0.31	-1.10	-1.22	-1.40	----	----	----	----	----	----
1906	----	----	----	----	----	----	----	----	----	----	----	----
1938	-1.54	-1.02	-0.78	-0.53	-0.29	-0.17	----	----	----	----	----	----
1944	0.60	0.68	2.14	0.42	0.25	-0.45	----	----	----	----	----	----
1948	1.50	0.13	-0.60	0.03	0.67	0.54	----	----	----	----	----	----
1951	-0.84	-0.72	2.23	2.51	1.43	2.51	----	----	----	----	----	----
2129	1.05	0.43	0.25	-0.53	-0.96	1.72	----	----	----	----	----	----
7012	----	----	----	----	----	----	-0.27	1.48	1.95	-0.37	0.26	-1.31
1951		0.51	0.59	0.55	0.56	0.31	----	----	----	----	----	----
2129		0.25	-0.54	-0.36	-0.13	-0.48	----	----	----	----	----	----
5019		----	----	----	----	----	----	----	----	----	----	----
7006		----	----	----	----	2.75	----	----	----	----	----	----

APPENDIX 3**Participants per country**

1 laboratory in AFGHANISTAN	2 laboratories in MALTA
1 laboratory in ARGENTINA	1 laboratory in MAURITIUS
1 laboratory in AUSTRALIA	1 laboratory in MOROCCO
2 laboratories in AUSTRIA	1 laboratory in MOZAMBIQUE
1 laboratory in AZERBAIJAN	1 laboratory in MYANMAR
4 laboratories in BELGIUM	7 laboratories in NETHERLANDS
2 laboratories in BOSNIA and HERZEGOVINA	1 laboratory in NIGERIA
1 laboratory in BRAZIL	1 laboratory in OMAN
1 laboratory in BULGARIA	1 laboratory in PAKISTAN
3 laboratories in CANADA	1 laboratory in PANAMA
2 laboratories in CHILE	1 laboratory in PERU
4 laboratories in CHINA, People's Republic	1 laboratory in PHILIPPINES
1 laboratory in COLOMBIA	3 laboratories in POLAND
1 laboratory in CONGO Brazzaville	3 laboratories in PORTUGAL
1 laboratory in COSTA RICA	1 laboratory in QATAR
1 laboratory in COTE D'IVOIRE	1 laboratory in ROMANIA
2 laboratories in CROATIA	5 laboratories in RUSSIAN FEDERATION
2 laboratories in CZECH REPUBLIC	2 laboratories in SAUDI ARABIA
1 laboratory in DJIBOUTI	1 laboratory in SENEGAL
1 laboratory in EQUATORIAL GUINEA	2 laboratories in SINGAPORE
1 laboratory in ESTONIA	1 laboratory in SLOVENIA
3 laboratories in FINLAND	1 laboratory in SOUTH AFRICA
8 laboratories in FRANCE	3 laboratories in SOUTH KOREA
4 laboratories in GEORGIA	10 laboratories in SPAIN
4 laboratories in GERMANY	2 laboratories in SUDAN
6 laboratories in GREECE	4 laboratories in SWEDEN
1 laboratory in GUAM	3 laboratories in TAIWAN
1 laboratory in GUINEA REPUBLIC	1 laboratory in TANZANIA
1 laboratory in HONG KONG	1 laboratory in TOGO
2 laboratories in HUNGARY	1 laboratory in TRINIDAD & TOBAGO
1 laboratory in IRAN, Islamic Republic of	1 laboratory in TUNISIA
1 laboratory in IRELAND	10 laboratories in TURKEY
1 laboratory in KAZAKHSTAN	1 laboratory in TURKMENISTAN
2 laboratories in KENYA	2 laboratories in UNITED ARAB EMIRATES
2 laboratories in LATVIA	10 laboratories in UNITED KINGDOM
1 laboratory in LITHUANIA	11 laboratories in UNITED STATES OF AMERICA
4 laboratories in MALAYSIA	

APPENDIX 4**Abbreviations:**

C	= final result after checking of first reported suspect result
D(0.01)	= outlier in Dixon's outlier test
D(0.05)	= straggler in Dixon's outlier test
G(0.01)	= outlier in Grubbs' outlier test
G(0.05)	= straggler in Grubbs' outlier test
DG(0.01)	= outlier in Double Grubbs' outlier test
DG(0.05)	= straggler in Double Grubbs' outlier test
R(0.01)	= outlier in Rosner outlier test
R(0.05)	= straggler in Rosner outlier test
E	= error in calculations
U	= reported in different unit
ex	= excluded from calculations
n.a.	= not applicable
W	= result withdrawn on request of participant

Literature:

- 1 iis Interlaboratory Studies, Protocol for the Organisation, Statistics & Evaluation, April 2014
- 2 ASTM E178-02
- 3 ASTM E1301-03
- 4 ISO 5725-86
- 5 ISO 5725, parts 1-6, 1994
- 6 ISO 13528-05
- 7 M. Thompson and R. Wood, J. AOAC, Int, 76, 926, (1993)
- 8 W.J. Youden and E.H. Steiner, Statistical Manual of the AOAC, (1975)
- 9 IP 367/84
- 10 DIN 38402 T41/42
- 11 P.L. Davies, C,Z. Anal. Chem, 331, 513, (1988)
- 12 J.N. Miller, Analyst, 118, 455, (1993)
- 13 Analytical Methods Committee Technical Brief, No4 January 2001
- 14 The Royal Society of Chemistry 2002, Analyst 2002, 127 page1359-1364, P.J. Lowthian and M. Thompson (see <http://www.rsc.org/suppdata/an/b2/b205600n/>).
- 15 Influence of silica gel humidity on the determination of hydrocarbon types in gasoline by ASTM D1319, Accreditation Quality Assurance (2006), H.Verplaetse and M. Lacourt.
- 16 Bernard Rosner, Percentage Points for a Generalized ESD Many-Outlier Procedure, *Technometrics*, 25(2), pp. 165-172, (1983)