

Results of Proficiency Test
LPG Composition & Sulphur
October 2018

Organised by: Institute for Interlaboratory Studies
Spijkenisse, the Netherlands

Author: ing. C.M. Nijssen-Wester
Correctors: ing. A.S. Noordman-de Neef & ing. R.J. Starink
Report: iis18S03P & iis18S03S

December 2018

CONTENTS

1	INTRODUCTION	3
2	SET UP	3
2.1	QUALITY SYSTEM.....	3
2.2	PROTOCOL.....	4
2.3	CONFIDENTIALITY STATEMENT	4
2.4	SAMPLES.....	4
2.5	STABILITY OF THE SAMPLES	6
2.6	ANALYSES.....	6
3	RESULTS	6
3.1	STATISTICS	7
3.2	GRAPHICS	7
3.3	Z-SCORES	8
4	EVALUATION	8
4.1	EVALUATION PER SAMPLE AND PER TEST	9
4.2	PERFORMANCE EVALUATION FOR THE GROUP OF LABORATORIES.....	13
4.3	COMPARISON OF THE PROFICIENCY TEST OF OCTOBER 2018 WITH PREVIOUS PTS	14
5	DISCUSSION	15
Appendices:		
1.	Data and statistical results	17
2.	Number of participants per country	38
3.	Abbreviations and literature	39

1 INTRODUCTION

Since 2009, the Institute for Interlaboratory Studies organizes a proficiency test for the analysis of Liquefied Propane every year. It was decided to continue the interlaboratory study for Liquefied Propane during the annual program 2018/2019. At the request of several participants, the Institute of Interlaboratory Studies decided to organise an interlaboratory study for Sulphur (total) in LPG in the 2018/2019 PT program for the second time.

Because iis has limited gas-handling facilities in place to prepare gas samples, a co-operation with EffecTech (Uttoxeter, United Kingdom) was set up for the Liquefied Propane PT (iis18S03P) and a co-operation with Praxair NV (Belgium) was set up for the Sulphur in LPG PT (iis18S03S). Both EffecTech and Praxair are fully equipped and have experience in the preparation of gas mixtures.

In the interlaboratory studies for Liquefied Propane 48 laboratories in 23 different countries and for Sulphur (total) in LPG 19 laboratories in 11 different countries registered for participation. In this report, the results of the 2018 proficiency tests Liquefied Propane and Sulphur (total) in LPG are presented and discussed. This report is also electronically available through the iis website www.iisnl.com.

2 SET UP

The Institute for Interlaboratory Studies (iis) in Spijkenisse, the Netherlands, was the organizer of this proficiency test (PT).

To optimise the costs for the participants for the Liquefied Propane PT (iis18S03P), it was decided to prepare one Liquefied Propane mixture for composition. The mixture was divided over a batch of 54 cylinders-(1L cylinder with dip tube device). Each cylinder, filled with approx. 250 grams of liquefied propane mixture, was labelled #18210 and uniquely coded. For the Sulphur in LPG PT (iis18S03S) it was decided to use a batch of 20 cylinders, filled with approximately 1500 grams of LPG, each spiked with Dimethyl Sulfide (DMS). Each cylinder (5L cylinder with dip tube device), was labelled #18211 and uniquely coded. The limited cylinder sizes (1L and 5L) are chosen to optimise sample stability, cylinder costs, transport and handling costs.

The preparation and testing of the sample cylinders was subcontracted to ISO 17025 accredited laboratories. Participants were requested to report rounded and unrounded test results. The unrounded test results were preferably used for statistical evaluation.

2.1 QUALITY SYSTEM

The Institute for Interlaboratory Studies in Spijkenisse, the Netherlands, has implemented a quality system based on ISO/IEC 17043:2010. This ensures strict adherence to protocols for sample preparation and statistical evaluation and 100% confidentiality of participant's data. Feedback from the participants on the reported data is encouraged and customer's satisfaction is measured on a regular basis by sending out questionnaires.

EffecTech is accredited in conformance with ISO/IEC17043:2010 by UKAS (no. 4719), ISO guide 35:2006 and ISO 17025:2005. Praxair is accredited in conformance with ISO 9001-2008, ISO 14001-2004, ISO 17025-No 159 Cal and ISO TS 16949.

2.2 PROTOCOL

The protocol followed in the organisation of this proficiency test was the one as described for proficiency testing in the report 'iis Interlaboratory Studies: Protocol for the Organisation, Statistics and Evaluation' of June 2018 (iis-protocol, version 3.5). This protocol is electronically available through the iis website www.iisnl.com, from the FAQ page.

2.3 CONFIDENTIALITY STATEMENT

All data presented in this report must be regarded as confidential and for use by the participating companies only. Disclosure of the information in this report is only allowed by means of the entire report. Use of the contents of this report for third parties is only allowed by written permission of the Institute for Interlaboratory Studies. Disclosure of the identity of one or more of the participating companies will be done only after receipt of a written agreement of the companies involved.

2.4 SAMPLES

LIQUEFIED PROPANE #18210

One batch of 54 one litre cylinders with artificial Liquefied Propane mixture was prepared and tested for homogeneity by EffecTech (Uttoxeter, United Kingdom) in conformance with ISO guide 35:2006 and ISO 17025:2005 (job 18/1030, September 2018). Each cylinder was labelled #18210 and uniquely coded. Every cylinder in the batch was analysed using 5 replicate measurements. The within bottle and between bottle variations were assessed in accordance with ISO Guide 35:2006 (Annex A.1). This procedure showed that the between bottle variations were small compared to the uncertainties on the reference values on each component. Hence, a single reference value could be safely assigned to the entire batch of samples.

The repeatability values (r) were calculated per component by multiplication of the respective standard deviation by 2.8. Subsequently, the calculated repeatabilities were compared with 0.3 times the corresponding reproducibility of the reference method in agreement with the procedure of ISO 13528, Annex B2 in the next table:

Component	r (observed) in %mol/mol	0.3 * R(D2163:14e1) in %mol/mol
Ethane	0.0019	0.0447
Propane	0.0235	1.2560
Propene	0.0032	0.0603
Iso-Butane	0.0068	0.0627
n-Butane	0.0118	0.0601
1-Butene	0.0014	0.0197
iso-Butene	0.0014	0.0188
n-Pentane	0.0043	0.0242

Table 1: homogeneity test results of samples #18210

Each calculated repeatability is less than 0.3 times the corresponding reproducibility of the reference method ASTM D2163:14e1. Therefore, homogeneity of the subsamples #18210 was assumed.

Sulphur

In this proficiency test, one batch of twenty 5L cylinders with artificial LPG mixture with Dimethylsulfide in Propane/n-Butane was prepared and tested for homogeneity by Praxair NV (Belgium) in conformance with ISO 9001-2008, ISO 14001-2004, ISO 17025-No 159 Cal and ISO TS 16949 in September 2018. Each cylinder was labelled #18211 and uniquely coded.

	Sulphur in mg/kg		Sulphur in mg/kg
Sample #18211-1	47.8	Sample #18211-11	49.3
Sample #18211-2	49.6	Sample #18211-12	49.5
Sample #18211-3	49.3	Sample #18211-13	49.1
Sample #18211-4	49.7	Sample #18211-14	49.3
Sample #18211-5	49.4	Sample #18211-15	49.4
Sample #18211-6	49.7	Sample #18211-16	48.7
Sample #18211-7	49.6	Sample #18211-17	49.3
Sample #18211-8	48.7	Sample #18211-18	48.9
Sample #18211-9	49.3	Sample #18211-19	49.5
Sample #18211-10	48.9	Sample #18211-20	49.0

Table 2: homogeneity test results of subsamples #18211

From the above test results, the repeatability was calculated and compared with 0.3 times the corresponding reproducibility of the reference test method and in agreement with the procedure of ISO 13528, Annex B2 in the next table:

	<i>Sulphur in mg/kg</i>
r (observed)	1.3
reference test method	ASTM D6667:14
0.3 * R (ref. test method)	4.6

Table 3: evaluation of the repeatability of subsamples #18211

The calculated repeatability is less than 0.3 times the corresponding reproducibility of the reference test method ASTM D6667:14. Therefore, homogeneity of the subsamples #18211 was assumed.

Depending on their registration to each of the participating laboratories one 1L cylinder of Liquefied Propane labelled #18210 and/or one 5L cylinder of Sulphur in LPG labelled #18211 was sent on October 3, 2018. Per cylinder one SDS was added to the sample package.

2.5 STABILITY OF THE SAMPLES

The shelf life time of the prepared gas cylinders is sufficient for the period of the proficiency test.

2.6 ANALYSES

The participants were asked to determine on the Liquefied Propane sample #18210 the composition: Ethane, Propane, Propene, iso-Butane, n-Butane, 1-Butene, iso-Butene, n-Pentane and to calculate several physical parameters from the composition: Molar Mass, Relative Density at 60F, Absolute and Relative Vapor pressure at 100F, Absolute and Relative Vapor pressure at 40°C, MON, Ideal Gross Heating Value and Ideal Net Heating Value at 14.696 psia and 60F.

On the LPG sample #18211 the total Sulphur content was requested.

It was explicitly requested to treat the samples as if they were routine samples and to report the test results using the indicated units on the report form and not to round the test results, but report as much significant figures as possible. It was also requested not to report 'less than' results, which are above the detection limit, because such test results cannot be used for meaningful statistical calculations.

To get comparable test results, a detailed report form and a letter of instructions are prepared. On the report form the reporting units are given as well as the appropriate reference test methods that will be used during the evaluation. The detailed report form and the letter of instructions are both made available on the data entry portal www.kpmd.co.uk/sgs-iis/. The participating laboratories are also requested to confirm the sample receipt on this data entry portal. The letter of instructions can also be downloaded from the iis website www.iisnl.com.

3 RESULTS

During five weeks after sample dispatch, the test results of the individual laboratories were gathered via the data entry portal www.kpmd.co.uk/sgs-iis/. The reported test results are tabulated per determination in appendix 1 of this report. The laboratories are presented by their code numbers.

Directly after the deadline, a reminder was sent to those laboratories that had not reported test results at that moment.

Shortly after the deadline, the available test results were screened for suspect data. A test result was called suspect in case the Huber Elimination Rule (a robust outlier test) found it to be an outlier. The laboratories that produced these suspect data were asked to check the reported test results (no reanalysis). Additional or corrected test results are used for data analysis and original test results are placed under 'Remarks' in the test result tables in appendix 1. Test results that came in after the deadline were not taken into account in this screening for suspect data and thus these participants were not requested for checks.

3.1 STATISTICS

The protocol followed in the organization of this proficiency test was the one as described for proficiency testing in the report 'iis Interlaboratory Studies: Protocol for the Organisation, Statistics and Evaluation' of June 2018 (iis-protocol, version 3.5).

For the statistical evaluation the *unrounded* (when available) figures were used instead of the rounded test results. Test results reported as '<...>' or '>...>' were not used in the statistical evaluation.

First, the normality of the distribution of the various data sets per determination was checked by means of the Lilliefors-test, a variant of the Kolmogorov-Smirnov test and by the calculation of skewness and kurtosis. Evaluation of the three normality indicators in combination with the visual evaluation of the graphic Kernel density plot, lead to judgement of the normality being either 'unknown', 'OK', 'suspect' or 'not OK'. After removal of outliers, this check was repeated. If a data set does not have a normal distribution, the results of the statistical evaluation should be used with due care.

According to ISO 5725 the original test results per determination were submitted to Dixon's, Grubbs' and/or Rosner's outlier tests. Outliers are marked by D(0.01) for the Dixon's test, by G(0.01) or DG(0.01) for the Grubbs' test and by R(0.01) for the Rosner's test. Stragglers are marked by D(0.05) for the Dixon's test, by G(0.05) or DG(0.05) for the Grubbs' test and by R(0.05) for the Rosner's test. Both outliers and stragglers were not included in the calculations of averages and standard deviations.

For each assigned value, the uncertainty was determined in accordance with ISO13528. Subsequently the calculated uncertainty was evaluated against the respective requirement based on the target reproducibility in accordance with ISO13528. In this PT, the criterion of ISO13528, paragraph 9.2.1. was met for all evaluated tests, therefore, the uncertainty of all assigned values may be negligible and need not be included in the PT report.

Finally, the reproducibilities were calculated from the standard deviations by multiplying them with a factor of 2.8.

3.2 GRAPHICS

In order to visualise the data against the reproducibilities from literature, Gauss plots were made, using the sorted data for one determination (see appendix 1). On the Y-axis the reported test results are plotted. The corresponding laboratory numbers are on the X-axis. The straight horizontal line presents the consensus value (a trimmed mean). The four striped lines, parallel to the consensus value line, are the +3s, +2s, -2s and -3s target reproducibility limits of the selected reference test method. Outliers and other data, which were excluded from the calculations, are represented as a cross. Accepted data are represented as a triangle.

Furthermore, Kernel Density Graphs were made. This is a method for producing a smooth density approximation to a set of data that avoids some problems associated with histograms. Also, a normal Gauss curve was projected over the Kernel Density Graph for reference.

3.3 Z-SCORES

To evaluate the performance of the participating laboratories the z-scores were calculated. As it was decided to evaluate the performance of the participants in this proficiency test (PT) against the literature requirements, e.g. ASTM reproducibilities, the z-scores were calculated using a target standard deviation. This results in an evaluation independent of the variation in this interlaboratory study.

The target standard deviation was calculated from the literature reproducibility by division with 2.8. In case no literature reproducibility was available, other target values were used. In some cases, a reproducibility based on former iis proficiency tests could be used.

When a laboratory did use a test method with a reproducibility that is significantly different from the reproducibility of the reference test method used in this report, it is strongly advised to recalculate the z-score, while using the reproducibility of the actual test method used, this in order to evaluate whether the reported test result is fit-for-use.

The z-scores were calculated according to:

$$Z_{(\text{target})} = (\text{test result} - \text{average of PT}) / \text{target standard deviation}$$

The $Z_{(\text{target})}$ scores are listed in the test result tables in appendix 1. Absolute values for $z < 2$ are very common and absolute values for $z > 3$ are very rare. The usual interpretation of z-scores is as follows:

$ z < 1$	good
$1 < z < 2$	satisfactory
$2 < z < 3$	questionable
$3 < z $	unsatisfactory

4 EVALUATION

In this interlaboratory study, some problems were encountered with the dispatch of the samples.

For the Liquefied Propane PT (iis18S03P), not all laboratories did report all test results requested. Three participants reported test results after the deadline and four participants did not report any test result at all. In total 44 participants reported 495 numerical test results. Observed were 20 outlying test results, which is 4.0%. In proficiency studies outlier percentages of 3% - 7.5% are quite normal.

For the Sulphur in LPG PT (iis18S03S), four participants did not report any result at all. In total 15 participants reported 15 numerical test results. Observed was 1 outlying test result, which is 6.7%. In proficiency studies outlier percentages of 3% - 7.5% are quite normal.

Not all original data sets proved to have normal Gaussian distribution. These are referred to as “not OK” or “suspect”. The statistical evaluation of these data sets should be used with due care, see also paragraph 3.1.

4.1 EVALUATION PER SAMPLE AND PER TEST

In this section, the reported test results are discussed per sample and per test. The test methods, which were used by the various laboratories, were taken into account for explaining the observed differences when possible and applicable. These test methods are also in the tables together with the original data. The abbreviations, used in these tables, are listed in appendix 3.

In the iis PT reports, ASTM methods are referred to with a number (e.g. D3588) and an added designation for the year that the method was adopted or revised (e.g. D3588:98). If applicable, a designation in parentheses is added to designate the year of reapproval (e.g. D3588:98(2017)). In the test results tables of appendix 1 only the method number and year of adoption or revision (e.g. D3588:98) will be used.

Because the majority of the participating laboratories used ASTM D2163 as test method for the determination of the Propane Composition, it was decided to use the reproducibilities of this test method as target reproducibilities, and to mention the reproducibilities of EN27941 (identical to IP 405 and ISO 7941) for reference only. In ASTM D2163 no reproducibilities of 1-butene and iso-butene are mentioned, the reproducibilities of n-butane were used to calculate the reproducibilities of these two components.

Liquefied Propane: sample #18210

Ethane: The determination of this component was not problematic. Three statistical outliers were observed. However, the calculated reproducibility after rejection of the statistical outliers is in agreement with the requirements of ASTM D2163:14e1 and also with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).

Propane: The determination of this component was not problematic. One statistical outlier was observed. However, the calculated reproducibility after rejection of the statistical outlier is in agreement with the requirements of ASTM D2163:14e1 and also in agreement with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).

- Propene: The determination of this component was not problematic. No statistical outliers were observed. The calculated reproducibility is in agreement with the requirements of ASTM D2163:14e1 and also with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).
- iso-Butane: The determination of this component may be problematic, depending on the test method used by the laboratory. One statistical outlier was observed. The calculated reproducibility after rejection of the statistical outlier is not in agreement with the requirements of ASTM D2163:14e1, but is in agreement with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).
- n-Butane: The determination of this component may be problematic, depending on the test method used by the laboratory. One statistical outlier was observed. The calculated reproducibility after rejection of the statistical outlier is not in agreement with the requirements of ASTM D2163:14e1, but is in full agreement with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).
- 1-Butene: The determination of this component was not problematic. No statistical outliers were observed. The calculated reproducibility is in agreement with the requirements of ASTM D2163:14e1 and also with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).
- Iso-Butene: The determination of this component was not problematic. One statistical outlier was observed. However, the calculated reproducibility after rejection of the statistical outlier is in agreement with the requirements of ASTM D2163:14e1 and also with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).
- n-Pentane: The determination of this component may be problematic, depending on the test method used by the laboratory. Three statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is not in agreement with the requirements of ASTM D2163:14e1, but is in agreement with the reproducibility requirements of EN27941:93 (identical to IP405 and ISO7941).
- Molar Mass: This calculated parameter may not be problematic. Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is in line with the calculated reproducibility using the published molar mass factors obtained from ASTM D2421:18 over all reported component concentrations (0.10 vs. 0.17 g/mol).

Rel. Density at 60F: This calculated parameter may not be problematic. One statistical outlier was observed. The calculated reproducibility after rejection of the statistical outlier is in line with the calculated reproducibility using the published relative density factors obtained from ASTM D2598:16 over all reported component concentrations (0.001 vs. 0.001).

Abs. VP at 100F: As the reported results calculated via ISO8973 and ASTM D2598 are not identical, it was decided to evaluate the test results for both methods separately.

Results reported with ISO8973: This calculated parameter may be problematic. One statistical outlier was observed. The calculated reproducibility after rejection of statistical outlier is not in line with the calculated reproducibility using the published vapour pressure factors obtained from ISO8973:97 over all reported component concentrations (2.8 vs 1.5 psi).

Results reported with ASTM D2598: This calculated parameter may not be problematic. No statistical outliers were observed. The calculated reproducibility is more in line with the calculated reproducibility using the published vapour pressure factors obtained from ASTM D2598:16 over all reported component concentrations (2.2 vs. 1.6 psi).

See also the discussion in paragraph 5.

Rel. VP at 100F: As the reported results calculated via ISO8973 and ASTM D2598 are not identical, it was decided to evaluate the test results for both methods separately.

Results reported with ISO8973: This calculated parameter may not be problematic. One statistical outlier was observed. The calculated reproducibility after rejection of statistical outlier is in line with the calculated reproducibility using the published vapour pressure factors obtained from ISO8973:97 over all reported component concentrations (2.1 vs 1.5 psi).

Results reported with ASTM D2598: This calculated parameter may not be problematic. No statistical outliers were observed. The calculated reproducibility is also in line with the calculated reproducibility using the published vapour pressure factors obtained from ASTM D2598:16 over all reported component concentrations (2.0 vs. 1.6 psi).

See also the discussion in paragraph 5.

Abs. VP at 40°C: This determination may be problematic. Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is in line with the calculated reproducibility using the published vapour pressure factors obtained from ISO8973:97 over all reported component concentrations (8.6 vs. 10.4 psi).

Rel. VP at 40°C: This determination may be problematic. One statistical outlier was observed and two other test results were excluded. The calculated reproducibility after rejection of the suspect data is in line with the calculated reproducibility using the published vapour pressure factors obtained from ISO8973:97 over all reported component concentrations (10.8 vs. 10.4 psi).

MON: As the reported results calculated via EN589-A1 and ASTM D2598 are not identical, it was decided to evaluate the test results for both methods separately.
Results reported with EN589-A1: This calculated parameter may be problematic. One statistical outlier was observed. The calculated reproducibility after rejection of statistical outlier is not in line with the calculated reproducibility using the published vapour pressure factors obtained from EN589:08-A1:12 over all reported component concentrations (0.45 vs 0.05).
For D2598 only three test results were reported, so no conclusions could be drawn.
See also the discussion in paragraph 5.

Ideal Gross Heating Value at 14.696 psia / 60F:

All laboratories reported to have calculated according to ASTM D3588. This calculated parameter may be problematic. Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is less in line with the calculated reproducibility using the published Ideal Gross Heating Values obtained from EN3588:98(2017) over all reported component concentrations (12 vs 8). This may be caused by the small number of reported rest results.

Ideal Net Heating Value at 14.696 psia / 60F:

All laboratories reported to have calculated according to ASTM D3588. This calculated parameter may be problematic. Two statistical outliers were observed. The calculated reproducibility after rejection of the statistical outliers is less in line with the calculated reproducibility using the published Ideal Net Heating Values obtained from EN3588:98(2017) over all reported component concentrations (11 vs 8). This may be caused by the small number of reported rest results.

Sulphur in LPG: sample #18211

Sulphur, total: The determination of this component was problematic. No statistical outliers were observed. The calculated reproducibility is not in agreement with the requirements of ASTM D6667:14.

4.2 PERFORMANCE EVALUATION FOR THE GROUP OF LABORATORIES

A comparison has been made between the reproducibility as declared by the relevant standard and the reproducibility as found for the group of participating laboratories. The average results per sample, calculated reproducibilities and reproducibilities, derived from literature standards (in casu ASTM, ISO standards) are compared in the next tables.

Component	unit	n	average	2.8 * sd	R(D2163:14*1) in %mol	R(EN27941) liq.-inj. in %mol
Ethane	%mol/mol	41	0.279	0.052	0.140	0.299
Propane	%mol/mol	43	93.82	0.79	4.18	1.02
Propene	%mol/mol	44	0.583	0.076	0.200	0.213
iso-Butane	%mol/mol	43	1.86	0.25	0.21	0.39
n-Butane	%mol/mol	43	2.36	0.40	0.20	0.39
1-Butene	%mol/mol	44	0.197	0.039	0.066	0.160
Iso-Butene	%mol/mol	43	0.181	0.041	0.064	0.160
n-Pentane	%mol/mol	41	0.727	0.146	0.082	0.311

Table 4: reproducibilities of composition tests on sample #18210

Parameter	unit	n	average	2.8 * sd	R (iis calc.)	n (all calc.)
Molar Mass	g/mol	19	44.89	0.10	0.17	44
Rel. Density at 60F		24	0.512	0.001	0.001	43
Abs. VP at 100F-ISO	psi	7	185.2	2.8	1.5	44
Abs. VP at 100F-ASTM	psi	4	182.2	2.2	1.6	44
Rel. VP at 100F-ISO	psi	7	170.6	2.1	1.5	44
Rel. VP at 100F-ASTM	psi	8	167.2	2.0	1.6	44
Abs. VP at 40°C	kPa	16	1315	8.6	10.4	44
Rel. VP at 40°C	kPa	17	1214	10.9	10.4	44
MON – EN589		11	95.17	0.45	0.05	40
MON – D2598		3	96.15	(1.23)*	0.14	43
Ideal Gross HV	kJ/mol	5	2260	12	8	44
Net Gross HV	kJ/mol	5	2080	11	8	44

Table 5: reproducibilities of calculated parameters on sample #18210

*) results in brackets based on only three test results.

Component	unit	n	average	2.8 * sd	R(lit)
Sulphur, total	mg/kg	15	51.6	30.2	16.2

Table 6: reproducibility of test on sample #18211

Without further statistical calculations it can be concluded that for a large number of parameters there is a good compliance of the group of participating laboratories with the relevant reference test methods for the component determination. The problematic tests have been discussed in paragraph 4.1.

4.3 COMPARISON OF THE PROFICIENCY TEST OF OCTOBER 2018 WITH PREVIOUS PTS

	Oct. 2018	Oct. 2017	Oct. 2016	Oct. 2015	Oct. 2014
Number of reporting labs	44	47	43	41	44
Number of test results reported	495	536	472	468	395
Statistical outliers	20	30	34	24	27
Percentage outliers	4.0%	5.6%	7.2%	5.1%	6.8%

Table 7: comparison with previous proficiency tests on Liquefied Propane (excluded Sulphur in LPG)

	Oct. 2018	Oct. 2017
Number of reporting labs	15	8
Number of test results reported	15	8
Statistical outliers	1	1
Percentage outliers	6.7%	12.5%

Table 8: comparison with previous proficiency tests on Sulphur in LPG only

In proficiency tests, outlier percentages of 3% - 7.5% are quite normal.

The performance of the determinations of the proficiency tests was compared against the requirements of the respective reference test methods. The conclusions are given the following tables:

Component	Oct. 2018	Oct. 2017	Oct. 2016	Oct. 2015	Oct. 2014
Ethane	++	++	++	++	-
Propane	++	++	++	++	+/-
Propene	++	++	++	+	+/-
iso-Butane	-	+/-	-	+	+/-
n-Butane	--	-	-	-	-
1-Butene	+	++	++	++	--
Iso-Butene	+	++	+	++	--
n-Pentane	-	-	-	-	--

Table 9: comparison determinations on Liquefied Propane against the requirements of the reference standards

Component	Oct. 2018	Oct. 2017
Sulphur, total	-	+

Table 10: comparison determinations on Sulphur in LPG against the requirements of the reference standard

The performance of the determinations against the requirements of the respective reference test methods is listed in the above tables. The following performance categories were used:

- ++: group performed much better than the reference test method
- + : group performed better than the reference test method
- +/-: group performance equals the reference test method
- : group performed worse than the reference test method
- : group performed much worse than the reference test method

5 DISCUSSION

Because several of the reproducibility requirements of ASTM D2163 differ significantly from the reproducibility requirements of EN27941 (for liquid injection), the outcome of the evaluation will be strongly dependent on the target test method selected for the evaluation.

The consensus values as determined in this PT are compared with the average values from the homogeneity testing by EffectTech, United Kingdom in the following table.

Parameter	Average values by EffectTech in %mol/mol	Consensus values from participants in %mol/mol	Differences in %mol/mol	calc. z-score
Ethane	0.306	0.279	0.027	+0.54
Propane	93.92	93.82	0.100	-0.07
Propene	0.589	0.583	0.006	+0.08
iso-Butane	1.806	1.86	-0.054	-0.71
n-Butane	2.303	2.36	-0.057	-0.79
1-Butene	0.194	0.197	-0.003	-0.13
Iso-Butene	0.175	0.181	-0.006	-0.26
n-Pentane	0.704	0.727	-0.023	-0.79

Table 11: comparison of consensus values with values determined by EffectTech

From this comparison it is clear that all consensus values as determined in this PT are in line with the values as determined by EffectTech during the preparation of the cylinders.

In principle no additional variation should be introduced when applying a calculation on the reported component concentrations. However, in practice a significant additional uncertainty is added in most cases. See the differences between the values from the test results as reported by the participating laboratories (each using its own calculation procedure) and the values as calculated by iis using one calculation procedure for each set of laboratory test results.

For the calculation of the Molar Mass, Relative Density, Vapor Pressure, Motor Octane Number and Heating Value several standardized test methods are available, e.g. ASTM D2421 for the interconversion of the units to gas-volume, liquid-volume or mass basis. Also, different test methods for the calculation of the Vapor Pressure do exist. In ISO 8973 (identical to IP432) the Vapor Pressure is calculated from the mole fraction per component and a Vapor Pressure factor of that component (given for all components). In ASTM D2598 the Vapor Pressure is calculated from the liquid volume percentage per component and a Vapor Pressure factor of that component (given for only several components). The selection of the tables to be used for the calculations may cause additional uncertainty.

It is remarkable to see that the results for Vapour Pressure from the ASTM D2598 calculation are significantly lower than the results from the ISO8973/IP432 calculation.

The observed difference is caused by a difference in the VP factor of Ethane. ASTM (Subcommittee D02.H) commented (see also Appendix 3, literature: 20):

“The vapor pressure of ethane in D2598 was revised a few times prior to 2002. The current value, 611 psi, has remained the same for the last ten years. The revision of ethane was done because components in LPG blends do not necessarily behave as ideal gases. In particular, properties of ethane and ethylene appear to differ from ideality. Factors for these two components have been modified from ‘ideal gas’ values to make the calculated vapor pressure results more closely approximate actual measured vapor pressures of LPG blends. (i.e. D1267). Chapter 2 of Fuels and Lubricants Handbook (George Totten, © 2003), states that calculated vapor pressure were found to be biased high relative to experimental vapor pressure measured by D1267 for high ethane samples in earlier versions of D2598”.



APPENDIX 1

Determination of Ethane on sample #18210; results in %mol/mol

lab	method	value	mark	z(target)	remarks
92		0.271		-0.15	
150	D2163	0.30	C	0.43	first reported: 0.442
158		-----		-----	
171		-----		-----	
311	D2163	0.28		0.03	
317	D2163	0.27		-0.17	
323	D2163	0.31		0.63	
333	D2163	0.26		-0.37	
334	D2163	0.27		-0.17	
335	D2163	0.11	R(0.01)	-3.36	
336	EN27941	0.27		-0.17	
337	D2163	0.28		0.03	
347	D2163	0.289		0.21	
352	EN27941	0.2735		-0.10	
381	EN27941	0.31		0.63	
444	D2163	0.278		-0.01	
445	D2163	0.25		-0.57	
511		-----		-----	
529		0.242		-0.73	
704	EN27941	0.276		-0.05	
707	EN27941	0.270		-0.17	
754	D2163	0.25		-0.57	
868	D2163	0.287		0.17	
994	D2163	0.2816		0.06	
1006	D2163	0.300		0.43	
1026	ISO7941	0.26		-0.37	
1040	D2163	0.274	C	-0.09	first reported: 0.183%M/M
1095	ISO7941	0.23		-0.97	
1109	IP405	0.30		0.43	
1197	D2163	0.268		-0.21	
1198	D2163	0.295		0.33	
1257	D2163	0.2901		0.23	
1275	EN27941	0.301		0.45	
1394		0.269		-0.19	
1491	ISO7941	0.290		0.23	
1557	EN27941	0.361	R(0.05)	1.64	
1603	In house	0.2714		-0.14	
1634	ISO7941	0.35	R(0.05)	1.42	
1786	D2163	0.282		0.07	
1882	EN27941	0.2668		-0.24	
2124		0.307		0.57	
6018	EN27941	0.310		0.63	
6019	EN27941	0.272		-0.13	
6052	D2163	0.2842		0.11	
6065	D2163	0.2632		-0.31	
6193	D2163	0.28		0.03	
6215	D2163	0.29099704		0.25	
7014		-----		-----	

normality OK
n 41
outliers 3
mean (n) 0.2786
st.dev. (n) 0.01849
R(calc.) 0.0518
st.dev.(D2163:14e1) 0.05011
R(D2163:14e1) 0.1403

Compare R(EN27941:93(liq)) = 0.2986





Determination of Propane on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		93.537		-0.19	
150	D2163	93.78	C	-0.03	first reported: 91.932
158		-----		-----	
171		-----		-----	
311	D2163	93.80		-0.02	
317	D2163	93.71		-0.08	
323	D2163	93.23		-0.40	
333	D2163	93.56		-0.18	
334	D2163	93.78		-0.03	
335	D2163	93.63		-0.13	
336	EN27941	94.24		0.28	
337	D2163	94.47		0.43	
347	D2163	94.423		0.40	
352	EN27941	93.614		-0.14	
381	EN27941	93.86		0.03	
444	D2163	93.583		-0.16	
445	D2163	93.89		0.05	
511		-----		-----	
529		94.465		0.43	
704	EN27941	93.980		0.11	
707	EN27941	93.972		0.10	
754	D2163	94.01		0.13	
868	D2163	93.668		-0.10	
994	D2163	93.6472		-0.12	
1006	D2163	93.850		0.02	
1026	ISO7941	93.38		-0.30	
1040	D2163	94.009	C	0.12	first reported: 92.068%M/M
1095	ISO7941	93.35		-0.32	
1109	IP405	93.84		0.01	
1197	D2163	93.780		-0.03	
1198	D2163	93.768		-0.04	
1257	D2163	93.7634		-0.04	
1275	EN27941	93.691		-0.09	
1394		93.675		-0.10	
1491	ISO7941	93.801		-0.01	
1557	EN27941	93.947		0.08	
1603	In house	94.0132		0.13	
1634	ISO7941	92.46	R(0.01)	-0.91	
1786	D2163	93.771		-0.03	
1882	EN27941	93.3175		-0.34	
2124		93.997		0.12	
6018	EN27941	93.924		0.07	
6019	EN27941	94.081		0.17	
6052	D2163	94.3084		0.33	
6065	D2163	93.6018		-0.15	
6193	D2163	93.79		-0.02	
6215	D2163	93.861795		0.03	
7014		-----		-----	

normality OK
n 43
outliers 1
mean (n) 93.8226
st.dev. (n) 0.28340
R(calc.) 0.7935
st.dev.(D2163:14e1) 1.49410
R(D2163:14e1) 4.1835

Compare R(EN27941:93(liq)) = 1.018





Determination of Propene on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		0.598		0.21	
150	D2163	0.60	C	0.23	first reported: 0.632
158		-----		-----	
171		-----		-----	
311	D2163	0.58		-0.05	
317	D2163	0.57		-0.19	
323	D2163	0.64		0.79	
333	D2163	0.58		-0.05	
334	D2163	0.58		-0.05	
335	D2163	0.55		-0.47	
336	EN27941	0.54		-0.61	
337	D2163	0.61		0.37	
347	D2163	0.654		0.99	
352	EN27941	0.5602		-0.32	
381	EN27941	0.61		0.37	
444	D2163	0.588		0.07	
445	D2163	0.62		0.51	
511		-----		-----	
529		0.526		-0.80	
704	EN27941	0.562		-0.30	
707	EN27941	0.577		-0.09	
754	D2163	0.55		-0.47	
868	D2163	0.596		0.18	
994	D2163	0.5797		-0.05	
1006	D2163	0.592		0.12	
1026	ISO7941	0.58		-0.05	
1040	D2163	0.582	C	-0.02	first reported: 0.544%M/M
1095	ISO7941	0.57		-0.19	
1109	IP405	0.57		-0.19	
1197	D2163	0.618		0.49	
1198	D2163	0.613		0.42	
1257	D2163	0.5907		0.10	
1275	EN27941	0.584		0.01	
1394		0.537		-0.65	
1491	ISO7941	0.581		-0.03	
1557	EN27941	0.616		0.46	
1603	In house	0.5577		-0.36	
1634	ISO7941	0.58		-0.05	
1786	D2163	0.615		0.44	
1882	EN27941	0.5930		0.14	
2124		0.555		-0.40	
6018	EN27941	0.596		0.18	
6019	EN27941	0.541		-0.59	
6052	D2163	0.5487		-0.49	
6065	D2163	0.5900		0.09	
6193	D2163	0.59		0.09	
6215	D2163	0.595792		0.17	
7014		-----		-----	

normality OK
n 44
outliers 0
mean (n) 0.5833
st.dev. (n) 0.02730
R(calc.) 0.0764
st.dev.(D2163:14e1) 0.07132
R(D2163:14e1) 0.1997

Compare R(EN27941:93(liq)) = 0.2133




Determination of iso-Butane on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		1.941		1.08	
150	D2163	1.86	C	0.00	first reported: 1.432
158		-----		-----	
171		-----		-----	
311	D2163	1.85		-0.13	
317	D2163	1.90		0.53	
323	D2163	2.02		2.12	
333	D2163	1.94		1.06	
334	D2163	1.88		0.27	
335	D2163	2.57	R(0.01)	9.40	
336	EN27941	1.72		-1.85	
337	D2163	1.71		-1.98	
347	D2163	1.733		-1.68	
352	EN27941	1.9065		0.62	
381	EN27941	1.83		-0.39	
444	D2163	1.920		0.80	
445	D2163	1.88		0.27	
511		-----		-----	
529		1.669		-2.53	
704	EN27941	1.804		-0.74	
707	EN27941	1.825		-0.46	
754	D2163	1.79		-0.92	
868	D2163	1.891		0.41	
994	D2163	1.8593		-0.01	
1006	D2163	1.835		-0.33	
1026	ISO7941	1.96		1.33	
1040	D2163	1.871	C	0.15	first reported: 2.415%MM
1095	ISO7941	2.00		1.86	
1109	IP405	1.80		-0.79	
1197	D2163	1.869		0.12	
1198	D2163	1.858		-0.02	
1257	D2163	1.8571		-0.03	
1275	EN27941	1.883		0.31	
1394		1.974		1.51	
1491	ISO7941	1.842		-0.23	
1557	EN27941	1.747		-1.49	
1603	In house	1.8328		-0.36	
1634	ISO7941	2.11		3.31	
1786	D2163	1.865		0.07	
1882	EN27941	1.9961		1.81	
2124		1.816		-0.58	
6018	EN27941	1.825		-0.46	
6019	EN27941	1.685		-2.31	
6052	D2163	1.7647		-1.26	
6065	D2163	1.9199		0.80	
6193	D2163	1.88		0.27	
6215	D2163	1.8488884		-0.14	
7014		-----		-----	

normality OK
n 43
outliers 1
mean (n) 1.8597
st.dev. (n) 0.09025
R(calc.) 0.2527
st.dev.(D2163:14e1) 0.07553
R(D2163:14e1) 0.2115

Compare R(EN27941:93(liq)) = 0.3861





Determination of n-Butane on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		2.489		1.85	
150	D2163	2.37	C	0.21	first reported: 1.822
158		-----		-----	
171		-----		-----	
311	D2163	2.38		0.34	
317	D2163	2.46		1.45	
323	D2163	2.60		3.39	
333	D2163	2.51		2.14	
334	D2163	2.41		0.76	
335	D2163	1.97		-5.33	
336	EN27941	2.23		-1.73	
337	D2163	2.09		-3.67	
347	D2163	2.06		-4.08	
352	EN27941	2.4771		1.69	
381	EN27941	2.31		-0.62	
444	D2163	2.468		1.56	
445	D2163	2.34		-0.21	
511		-----		-----	
529		2.106		-3.45	
704	EN27941	2.316		-0.54	
707	EN27941	2.334		-0.29	
754	D2163	2.33		-0.35	
868	D2163	2.426		0.98	
994	D2163	2.4195		0.89	
1006	D2163	2.365		0.14	
1026	ISO7941	2.60		3.39	
1040	D2163	2.419	C	0.88	first reported: 3.122%M/M
1095	ISO7941	2.61		3.53	
1109	IP405	2.38		0.34	
1197	D2163	2.355		0.00	
1198	D2163	2.354		-0.02	
1257	D2163	2.3841		0.40	
1275	EN27941	2.407		0.72	
1394		2.423		0.94	
1491	ISO7941	2.381		0.36	
1557	EN27941	2.239		-1.61	
1603	In house	2.2620		-1.29	
1634	ISO7941	3.23	R(0.01)	12.11	
1786	D2163	2.355		0.00	
1882	EN27941	2.5957		3.33	
2124		2.267		-1.22	
6018	EN27941	2.272		-1.15	
6019	EN27941	2.112		-3.36	
6052	D2163	2.1902		-2.28	
6065	D2163	2.4769		1.69	
6193	D2163	2.38		0.34	
6215	D2163	2.3473865		-0.11	
7014		-----		-----	

normality OK
n 43
outliers 1
mean (n) 2.3551
st.dev. (n) 0.14449
R(calc.) 0.4046
st.dev.(D2163:14e1) 0.07225
R(D2163:14e1) 0.2023

Compare R(EN27941:93(liq)) = 0.3861





Determination of 1-Butene on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		0.202		0.23	
150	D2163	0.19	C	-0.28	first reported: 0.155
158		-----		-----	
171		-----		-----	
311	D2163	0.20		0.14	
317	D2163	0.19		-0.28	
323	D2163	0.21		0.57	
333	D2163	0.21		0.57	
334	D2163	0.19		-0.28	
335	D2163	0.21		0.57	
336	EN27941	0.18		-0.70	
337	D2163	0.18		-0.70	
347	D2163	0.175		-0.92	
352	EN27941	0.2027		0.26	
381	EN27941	0.19		-0.28	
444	D2163	0.205		0.35	
445	D2163	0.20		0.14	
511		-----		-----	
529		0.176		-0.87	
704	EN27941	0.190		-0.28	
707	EN27941	0.188		-0.37	
754	D2163	0.18		-0.70	
868	D2163	0.203		0.27	
994	D2163	0.1847		-0.50	
1006	D2163	0.188		-0.37	
1026	ISO7941	0.21		0.57	
1040	D2163	0.198	C	0.06	first reported: 0.247%M/M
1095	ISO7941	0.21		0.57	
1109	IP405	0.20		0.14	
1197	D2163	0.199		0.10	
1198	D2163	0.202		0.23	
1257	D2163	0.1967		0.00	
1275	EN27941	0.200		0.14	
1394		0.224		1.16	
1491	ISO7941	0.191		-0.24	
1557	EN27941	0.189		-0.32	
1603	In house	0.1807		-0.67	
1634	ISO7941	0.23		1.41	
1786	D2163	0.201		0.18	
1882	EN27941	0.2136		0.72	
2124		0.193		-0.15	
6018	EN27941	0.222		1.07	
6019	EN27941	0.185		-0.49	
6052	D2163	0.1587		-1.60	
6065	D2163	0.2067		0.43	
6193	D2163	0.20		0.14	
6215	D2163	0.1970809		0.02	
7014		-----		-----	

normality OK
n 44
outliers 0
mean (n) 0.1966
st.dev. (n) 0.01385
R(calc.) 0.0388
st.dev.(D2163:14e1) 0.02364
R(D2163:14e1) 0.0662

Compare R(EN27941:93(liq)) = 0.1600





Determination of iso-Butene on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		0.197		0.69	
150	D2163	0.18	C	-0.05	first reported: 0.142
158		-----		-----	
171		-----		-----	
311	D2163	0.18		-0.05	
317	D2163	0.17		-0.49	
323	D2163	0.20		0.82	
333	D2163	0.19		0.38	
334	D2163	0.18		-0.05	
335	D2163	0.19		0.38	
336	EN27941	0.16		-0.93	
337	D2163	0.17		-0.49	
347	D2163	0.162		-0.84	
352	EN27941	0.1780		-0.14	
381	EN27941	0.18		-0.05	
444	D2163	0.188		0.30	
445	D2163	0.19		0.38	
511		-----		-----	
529		0.163		-0.80	
704	EN27941	0.170		-0.49	
707	EN27941	0.171		-0.45	
754	D2163	0.17		-0.49	
868	D2163	0.186		0.21	
994	D2163	0.1913		0.44	
1006	D2163	0.177		-0.19	
1026	ISO7941	0.19		0.38	
1040	D2163	0.172	C	-0.41	first reported: 0.215%MM
1095	ISO7941	0.19		0.38	
1109	IP405	0.18		-0.05	
1197	D2163	0.182		0.03	
1198	D2163	0.183		0.08	
1257	D2163	0.1822		0.04	
1275	EN27941	0.185		0.17	
1394		0.225		1.92	
1491	ISO7941	0.176		-0.23	
1557	EN27941	0.173		-0.36	
1603	In house	0.1699		-0.50	
1634	ISO7941	0.21		1.26	
1786	D2163	0.183		0.08	
1882	EN27941	0.1963		0.66	
2124		0.184		0.12	
6018	EN27941	0.199		0.78	
6019	EN27941	0.151		-1.33	
6052	D2163	0.1433		-1.66	
6065	D2163	0.1941		0.56	
6193	D2163	0.00	R(0.01)	-7.95	
6215	D2163	0.1811388		0.00	
7014		-----		-----	

normality suspect
n 43
outliers 1
mean (n) 0.1812
st.dev. (n) 0.01472
R(calc.) 0.0412
st.dev.(D2163:14e1) 0.02279
R(D2163:14e1) 0.0638

Compare R(EN27941:93(liq)) = 0.1600





Determination of n-Pentane on sample #18210; results in %mol/mol

lab	method	value	mark	z(targ)	remarks
92		0.765		1.31	
150	D2163	0.72	C	-0.22	first reported: 0.443
158		-----		-----	
171		-----		-----	
311	D2163	0.73		0.12	
317	D2163	0.73		0.12	
323	D2163	0.79		2.17	
333	D2163	0.77		1.49	
334	D2163	0.71		-0.57	
335	D2163	0.77		1.49	
336	EN27941	0.66		-2.28	
337	D2163	0.50	R(0.01)	-7.75	
347	D2163	0.504	R(0.01)	-7.61	
352	EN27941	0.7883		2.11	
381	EN27941	0.71		-0.57	
444	D2163	0.765		1.31	
445	D2163	0.64		-2.96	
511		-----		-----	
529		0.652		-2.55	
704	EN27941	0.702		-0.84	
707	EN27941	0.662		-2.21	
754	D2163	0.72		-0.22	
868	D2163	0.744		0.60	
994	D2163	0.7580		1.08	
1006	D2163	0.692		-1.18	
1026	ISO7941	0.82		3.20	
1040	D2163	0.750	C	0.80	first reported: 1.202%M/M
1095	ISO7941	0.83		3.54	
1109	IP405	0.73		0.12	
1197	D2163	0.724		-0.09	
1198	D2163	0.723		-0.12	
1257	D2163	0.7357		0.31	
1275	EN27941	0.736		0.32	
1394		0.673		-1.83	
1491	ISO7941	0.737		0.36	
1557	EN27941	0.727		0.01	
1603	In house	0.7122		-0.49	
1634	ISO7941	0.82		3.20	
1786	D2163	0.724		-0.09	
1882	EN27941	0.8210		3.23	
2124		0.679		-1.63	
6018	EN27941	0.653		-2.52	
6019	EN27941	0.957	R(0.01)	7.88	
6052	D2163	0.6018		-4.27	
6065	D2163	0.7475		0.72	
6193	D2163	0.69		-1.25	
6215	D2163	0.6769479		-1.70	
7014		-----		-----	

normality OK
n 41
outliers 3
mean (n) 0.7266
st.dev. (n) 0.05207
R(calc.) 0.1458
st.dev.(D2163:14e1) 0.02923
R(D2163:14e1) 0.0818



Compare R(EN27941:93(liq)) = 0.3111



Determination of Molar Mass on sample #18210; results in g/mol

lab	method	value	mark	z(targ)	remarks
92	D2163	44.9		----	
150		----		----	
158		----		----	
171		----		----	
311	INH-407	44.90		----	
317	INH-001	44.9		----	
323		----		----	
333		----		----	
334		----		----	
335		----		----	
336		----		----	
337		----		----	
347	D2598	44.76	R(0.05)	----	
352		----		----	
381	ISO8973	44.87		----	
444		----		----	
445	D2163	44.869		----	
511		----		----	
529	D2421	44.9495		----	
704	D2421	44.8636		----	
707	D2421	44.8589		----	
754	D2421	44.871		----	
868	D2598	44.90		----	
994	D2598	44.91		----	
1006		----		----	
1026	ISO8973	44.97		----	
1040		----		----	
1095		----		----	
1109	ISO8973	44.88		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275	EN589	44.897		----	
1394		----		----	
1491		----		----	
1557	ISO8973	44.84		----	
1603		----		----	
1634		----		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018	ISO8973	44.85		----	
6019	ISO8973	44.89		----	
6052	D3588	44.95		----	
6065		44.923		----	
6193		----		----	
6215	D2598	45.0209	R(0.05)	----	
7014		----		----	



normality	OK	Calc. by iis from ALL rep. composition results (acc. to D2421:18)
n	19	suspect
outliers	2	44
mean (n)	44.894	44.888
st.dev. (n)	0.0351	0.0617
R(calc.)	0.098	0.173
comp R(iis17S03P)	0.085	0.082



Determination of Relative Density at 60/60F on sample #18210; unitless results

lab	method	value	mark	z(targ)	remarks
92	D2598	0.512		----	
150	D2598	0.5117	C	----	first reported: 0.5102
158		----		----	
171		----		----	
311	INH-407	0.5115		----	
317	INH-001	0.5116		----	
323	D2598	0.5121		----	
333		----		----	
334		----		----	
335		----		----	
336		----		----	
337		----		----	
347	D2598	0.5108		----	
352	ISO8973	0.511		----	
381	D2598	0.511		----	
444	D2598	0.512		----	
445		0.5117		----	
511		----		----	
529	D2421	0.51126		----	
704	D2598	0.5118		----	
707	D2598	0.5118		----	
754	D2598	0.5116		----	
868	D2598	0.5118		----	
994	D2598	0.5119		----	
1006	D2598	0.5116		----	
1026	ISO8973	511.1	R(0.01), E	----	calculation error: iis calculated: 0.5122
1040		----		----	
1095		----		----	
1109	D2598	0.5109	E	----	calculation error: iis calculated 0.5117
1197		----		----	
1198		----		----	
1257		----		----	
1275		----		----	
1394		----		----	
1491		----		----	
1557	ISO8973	0.51206	E	----	calculation error: iis calculated 0.5114
1603		----		----	
1634	ISO8973	0.5129		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018	ISO8973	0.512		----	
6019	ISO8973	0.512		----	
6052		----		----	
6065	D2598	0.5119		----	
6193		----	W	----	first reported: 511.9 kg/m ³
6215	D2598	0.5116		----	
7014		----		----	
		normality	suspect		OK
		n	24		43
		outliers	1		1
		mean (n)	0.51169		0.51169
		st.dev. (n)	0.000462		0.000289
		R(calc.)	0.00129		0.00081
comp	R(iis17S03P)	0.00101			0.00063

Calc. by iis from ALL rep. composition results (acc. to D2598:16)






Determination of Absolute Vapor Pressure at 100F on sample #18210; results in psi

lab	method	value	mark	z(targ)	remarks
92		----		----	
150		----		----	
158		----		----	
171		----		----	
311	ISO8973	183	E	----	calculation error: iis calculated: 185.6 (ISO8973)
317	ISO8973	185.4		----	
323		----		----	
333		----		----	
334		----		----	
335		----		----	
336		----		----	
337		----		----	
347		----		----	
352		----		----	
381	D2598	183.34	E	----	calculation error: iis calculated: 182.0 (D2598)
444		----		----	
445		----		----	
511		----		----	
529		----		----	
704	ISO8973	185.8		----	
707	ISO8973	185.7		----	
754	ISO8973	185.6		----	
868	D2598	181.6		----	
994	IP432	185.29		----	
1006	D2598	182.1		----	
1026	ISO8973	178.98	G(0.01),E	----	calculation error: iis calculated: 184.8 (ISO8973)
1040		----		----	
1095		----		----	
1109	ISO8973	185.73		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275		----		----	
1394		----		----	
1491		----		----	
1557		----		----	
1603		----		----	
1634		----		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018		----		----	
6019		----		----	
6052		----		----	
6065		----		----	
6193		----		----	
6215	D2598	181.7	C	----	first reported: 167
7014		----		----	

Evaluated over ISO8973/IP432 test results only		iis calculated from ALL reported composition test results	
normality	unknown		suspect
n	7		44
outliers	1		0
mean (n)	185.217		185.552
st.dev. (n)	0.9947		0.5252
R(calc.)	2.785		1.470
comp R(iis17S03P)	----		0.872
Evaluated over D2598 test results only		iis calculated from ALL reported composition test results	
normality	unknown		suspect
n	4		44
outliers	0		0
mean (n)	182.185		181.695
st.dev. (n)	0.7997		0.5691
R(calc.)	2.239		1.593
comp R(iis17S03P)	----		1.007

Reported test results







Determination of Relative Vapor Pressure at 100F on sample #18210; results in psi

lab	method	value	mark	z(targ)	remarks
92		----		----	
150		----		----	
158		----		----	
171		----		----	
311	ISO8973	169	E	----	calculation error: iis calculated: 170.9 (ISO8973)
317	ISO8973	170.7		----	
323	D2598	166.37		----	
333		----		----	
334		----		----	
335		----		----	
336		----		----	
337		----		----	
347		----		----	
352		----		----	
381	D2598	168.61	E	----	calculation error: iis calculated: 167.3 (D2598)
444	D2598	166.66		----	
445		171		----	
511		----		----	
529	D2598	167.713		----	
704	ISO8973	171.1		----	
707	ISO8973	171.0		----	
754	ISO8973	170.9		----	
868	D2598	166.9		----	
994	IP432	170.34		----	
1006	D2598	167.4		----	
1026	ISO8973	164	G(0.01),E	----	calculation error: iis calculated: 170.1 (ISO8973)
1040		----		----	
1095		----		----	
1109	ISO8973	171.04		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275		----		----	
1394		----		----	
1491		----		----	
1557		----		----	
1603		----		----	
1634		----		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018		----		----	
6019		----		----	
6052		----		----	
6065	D2598	166.63	C	----	first reported as Absolute Vapor Pressure
6193		----		----	
6215	D2598	167	C	----	first reported as Absolute Vapor Pressure
7014		----		----	



Evaluated over ISO8973/IP432 test results only		iis calculated from ALL reported composition test results	
normality	unknown		suspect
n	7		44
outliers	1		0
mean (n)	170.583		170.856
st.dev. (n)	0.7449		0.5252
R(calc.)	2.086		1.470
comp R(iis17S03P)	----		0.872
Evaluated over D2598 test results only		iis calculated from ALL reported composition test results	
normality	unknown		suspect
n	8		44
outliers	0		0
mean (n)	167.160		166.998
st.dev. (n)	0.7284		0.5691
R(calc.)	2.040		1.593
comp R(iis17S03P)	----		1.007

Reported test results





Determination of Absolute Vapor Pressure at 40°C on sample #18210; results in kPa

lab	method	value	mark	z(targ)	remarks
92					
150					
158					
171					
311	ISO8973	1332	C,G(0.01),E		first reported: 193, calculation error: iis calculated: 1315
317	ISO8973	1313	C		first reported: 190.4
323					
333					
334	ISO8973	1315			
335					
336	ISO8973	1318			
337					
347					
352	ISO8973	1312			
381	ISO8973	1318			
444					
445					
511					
529					
704	ISO8973	1316.2			
707	ISO8973	1316.0			
754	ISO8973	1315			
868					
994	IP432	1313.33			
1006					
1026	ISO8973	1298	G(0.05),E		calculation error: iis calculated: 1310
1040					
1095	ISO8973	1308			
1109	ISO8973	1316.1			
1197					
1198					
1257					
1275	EN589	1316.0			
1394					
1491					
1557	ISO8973	1321.9			
1603					
1634					
1786					
1882					
2124					
6018	ISO8973	1318			
6019	ISO8973	1316			
6052					
6065					
6193	ISO8973	1315			
6215					
7014					
	normality	not OK			<u>Calc. by iis from ALL rep. composition results (ISO8973/IP432)</u>
	n	16			suspect
	outliers	2			44
	mean (n)	1315.47			0
	st.dev. (n)	3.071			1314.84
	R(calc.)	8.605			3.712
comp	R(iis17S03P)	3.91			10.39



Determination of Relative Vapor Pressure at 40°C on sample #18210; results in kPa

lab	method	value	mark	z(targ)	remarks
92		----		----	
150		----		----	
158		----		----	
171		----		----	
311	ISO8973	1230	ex,C,E	----	fr.: 178, calc. error: iis calc. 1214, excluded for outlier in AVP
317	ISO8973	1212	C	----	first reported: 175.8
323		----		----	
333		----		----	
334	ISO8973	1214		----	
335		----		----	
336	ISO8973	1217		----	
337		----		----	
347		----		----	
352		----		----	
381	ISO8973	1217		----	
444	ISO8973	1211.8		----	
445		1213.5		----	
511		----		----	
529		----		----	
704	ISO8973	1214.9		----	
707	ISO8973	1214.7		----	
754	ISO8973	1214		----	
868		----		----	
994	IP432	1212		----	
1006		----		----	
1026	ISO8973	1197	ex,E	----	calculation error: iis calculated: 1208, excluded for outlier in AVP
1040		----		----	
1095	ISO8973	1206		----	
1109	ISO8973	1214.8		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275		----		----	
1394		----		----	
1491	ISO8973	1214	C	----	first reported as Absolute Vapor Pressure
1557	ISO8973	1220.6		----	
1603		----		----	
1634	ISO8973	1205		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018	ISO8973	1218		----	
6019	ISO8973	1215		----	
6052		----		----	
6065	D2598	1149.72	C,G(0.01)	----	first reported as Absolute Vapor Pressure
6193		----		----	
6215		----		----	
7014		----		----	
					<u>Calc. by iis from ALL rep. composition results (ISO8973/IP432)</u>
	normality	suspect			suspect
	n	17			44
	outliers	1 (+2ex)			0
	mean (n)	1213.78			1213.51
	st.dev. (n)	3.855			3.712
	R(calc.)	10.79			10.39
comp	R(iis17S03P)	3.88			----






Determination of Motor Octane Number, MON on sample #18210;

lab	method	value	mark	z(targ)	remarks
92		----		----	
150		----		----	
158		----		----	
171		----		----	
311		----		----	
317	EN589	95.1		----	
323		----		----	
333		----		----	
334	EN589	95.1		----	
335		----		----	
336	EN589	95.1		----	
337		----		----	
347		----		----	
352		----		----	
381	EN589	95.5		----	
444	D2598	96.3		----	
445		----		----	
511		----		----	
529		----		----	
704	EN589	95.10		----	
707	EN589	95.10		----	
754	EN589	95.1		----	
868	D2598	96.5		----	
994	EN589	95.08		----	
1006		----		----	
1026		95.07		----	
1040		----		----	
1095		----		----	
1109	EN589	95.1		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275	EN589	95.1		----	
1394		----		----	
1491	EN589	96.6	E	----	method used is probably D2598 (iis calc: 96.6 / EN589: 95.1)
1557	EN589	95.48		----	
1603		----		----	
1634		----		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018		----		----	
6019		----		----	
6052		----		----	
6065	D2598	95.66		----	
6193		----		----	
6215		----		----	
7014		----		----	



Evaluated over EN589-A1 test results only		iis calculated from ALL reported composition test results	
normality	not OK		OK
n	11		40
outliers	1		4
mean (n)	95.169		95.096
st.dev. (n)	0.1588		0.0174
R(calc.)	0.445		0.049
comp R(iis17S03P)	----		0.038
Evaluated over D2598 test results only		iis calculated from ALL reported composition test results	
normality	unknown		suspect
n	3		43
outliers	0		1
mean (n)	96.153		96.559
st.dev. (n)	(0.4388)		0.0485
R(calc.)	(1.229)		0.136
comp R(iis17S03P)	----		0.064

Reported test results





Determination of Ideal Gross Heating Value at 14.696 psia/60F on sample #18210; in kJ/mol

lab	method	value	mark	z(targ)	remarks
92		----		----	
150		----		----	
158		----		----	
171		----		----	
311		----		----	
317	D3588	2258.2		----	
323		----		----	
333		----		----	
334		----		----	
335		----		----	
336		----		----	
337		----		----	
347		----		----	
352	D3588	2259.815		----	
381	D3588	2256.2		----	
444		----		----	
445		----		----	
511		----		----	
529		----		----	
704		----		----	
707		----		----	
754	D3588	2189.6	G(0.01),E	----	calculation error: iis calculated: 2256.62 (D3588)
868		----		----	
994		----		----	
1006		----		----	
1026		----		----	
1040		----		----	
1095		----		----	
1109	D3588	2256.94		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275		----		----	
1394		----		----	
1491		----		----	
1557		----		----	
1603		----		----	
1634	D3588	2266.63		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018		----		----	
6019		----		----	
6052		----		----	
6065	D3588	9505520	G(0.01),E	----	calculation error: iis calculated: 2258.90 (D3588)
6193		----		----	
6215		----		----	
7014		----		----	
					<u>Calc. by iis from ALL reported composition results (D3588)</u>
	normality	unknown			suspect
	n	5			44
	outliers	2			0
	mean (n)	2259.56			2257.36
	st.dev. (n)	4.185			2.905
	R(calc.)	11.72			8.13
	R(iis17S03P)	(0.92)			3.77



Determination of Ideal Net Heating Value at 14.696 psia/60F on sample #18210; results in kJ/mol



lab	method	value	mark	z(targ)	remarks
92		----		----	
150		----		----	
158		----		----	
171		----		----	
311		----		----	
317	D3588	2078.3		----	
323		----		----	
333		----		----	
334		----		----	
335		----		----	
336		----		----	
337		----		----	
347		----		----	
352	D3588	2079.796		----	
381	D3588	2076.5		----	
444		----		----	
445		----		----	
511		----		----	
529		----		----	
704		----		----	
707		----		----	
754	D3588	2014.9	G(0.01),E	----	calculation error: iis calculated: 2076.82 (D3588)
868		----		----	
994		----		----	
1006		----		----	
1026		----		----	
1040		----		----	
1095		----		----	
1109	D3588	2076.88		----	
1197		----		----	
1198		----		----	
1257		----		----	
1275		----		----	
1394		----		----	
1491		----		----	
1557		----		----	
1603		----		----	
1634	D3588	2086.19		----	
1786		----		----	
1882		----		----	
2124		----		----	
6018		----		----	
6019		----		----	
6052		----		----	
6065	D3588	8749191	G(0.01),E	----	calculation error: iis calculated: 2078.97 (D3588)
6193		----		----	
6215		----		----	
7014		----		----	
					<u>Calc. by iis from ALL reported composition results (D3588)</u>
	normality	unknown			suspect
	n	5			44
	outliers	2			0
	mean (n)	2079.53			2077.53
	st.dev. (n)	3.942			2.710
	R(calc.)	11.04			7.59
	R(iis17S03P)	(1.65)			3.77



Determination of Sulphur, total on sample #18211; results in mg/kg

lab	method	value	mark	z(targ)	remarks
150	D6667	47		-0.79	
158		----		----	
171		----		----	
311	D6667	35		-2.87	
323	D6667	54		0.42	
337		----		----	
347	D6667	37.8		-2.38	
360	D6667	40.6		-1.90	
381	D6667	49.4	C	-0.37	first reported: 96.7
445		----		----	
1006	D6667	60.83		1.60	
1095	D6667	66		2.50	
1557	D6667	51.6		0.01	
1603	In house	40.3		-1.95	
1634	D6667	56.37		0.83	
1741	D6667	47.4		-0.72	
1941	D6667	51.01		-0.10	
6018	D6667	66.0		2.50	
6019	D6667	70.2		3.22	

normality OK
 n 15
 outliers 0
 mean (n) 51.57
 st.dev. (n) 10.800
 R(calc.) 30.24
 st.dev.(D6667:14) 5.782
 R(D6667:14) 16.19



APPENDIX 2

Number of participants per country in the Propane PT iis18S03P

2 labs in AUSTRALIA
1 lab in AZERBAIJAN
1 lab in BELGIUM
1 lab in CANADA
1 lab in CHINA, People's Republic
1 lab in COLOMBIA
1 lab in DENMARK
5 labs in FRANCE
2 labs in GERMANY
1 lab in IRAN, Islamic Republic of
3 labs in MALAYSIA
2 labs in MEXICO
3 labs in NETHERLANDS
1 lab in PERU
6 labs in PORTUGAL
2 labs in RUSSIAN FEDERATION
3 labs in SERBIA
1 lab in SPAIN
1 lab in TAIWAN
2 labs in UKRAINE
2 labs in UNITED ARAB EMIRATES
3 labs in UNITED KINGDOM
3 labs in UNITED STATES OF AMERICA

Number of participants per country in the Sulphur in LPG PT iis18S03S

1 lab in BELGIUM
1 lab in BULGARIA
1 lab in FRANCE
1 lab in GERMANY
1 lab in NETHERLANDS
4 labs in PORTUGAL
4 labs in SERBIA
1 lab in SPAIN
1 lab in TAIWAN
1 lab in UNITED KINGDOM
3 labs in UNITED STATES OF AMERICA

APPENDIX 3

Abbreviations:

C	= final result after checking of first reported suspect test result
D(0.01)	= outlier in Dixon's outlier test
D(0.05)	= straggler in Dixon's outlier test
G(0.01)	= outlier in Grubbs' outlier test
G(0.05)	= straggler in Grubbs' outlier test
DG(0.01)	= outlier in Double Grubbs' outlier test
DG(0.05)	= straggler in Double Grubbs' outlier test
R(0.01)	= outlier in Rosner's outlier test
R(0.05)	= straggler in Rosner's outlier test
E	= probably an error in calculations
ex	= test result excluded from the statistical evaluation
n.a.	= not applicable
n.e.	= not evaluated
fr.	= first reported
SDS	= safety data sheet

Literature:

- 1 iis Interlaboratory Studies, Protocol for the Organization, Statistics and Evaluation, June 2018
- 2 ASTM D2163:14e1
- 3 ASTM D2421:13
- 4 ISO 5725:86
- 5 ISO 5725, parts 1-6, 1994
- 6 M. Thompson and R. Wood, J. AOAC Int, 76, 926, (1993)
- 7 W.J. Youden and E.H. Steiner, Statistical Manual of the AOAC, (1975)
- 8 IP 367:84
- 9 DIN 38402 T41/42
- 10 P.L. Davies, Fr. Z. Anal. Chem, 331, 513, (1988)
- 11 J.N. Miller, Analyst, 118, 455, (1993)
- 12 Analytical Methods Committee Technical Brief, No 4 January 2001
- 13 P.J. Lowthian and M. Thompson, The Royal Society of Chemistry, Analyst, 127, 1359-1364 (2002)
- 14 ISO 17043:2010
- 15 EN 27941:1993 = ISO 7941:88 = IP 405:94
- 16 ASTM D2598:16
- 17 IP 432:2000 = ISO 8973:1997
- 18 ASTM D2598:16
- 19 EN 589:08-A1:12
- 20 Private communication ASTM Subcommittee D02.H
- 21 ASTM D3588:98(2017)
- 22 ISO 6976:95(1996)
- 23 ISO 6976:16
- 24 Bernard Rosner, Percentage Points for a Generalized ESD Many-Outlier Procedure, Technometrics, 25(2), 165-172, (1983)