

## **Instructions to participants for the interlaboratory study Biogasoline E10 RON and MON iis21B03RON**

- \* Please **confirm sample receipt** as soon as you have received this package and checked the contents via the data entry portal [www.kpmd.co.uk/sgs-iis/](http://www.kpmd.co.uk/sgs-iis/). Please give date of receipt and press the "Save Date" button. Please inform the Institute for Interlaboratory Studies (iis) immediately when something is wrong with the package and/or samples via [nl.iis@sgs.com](mailto:nl.iis@sgs.com).
- \* When a bottle has been broken, please do not accept the package from the courier. Please note that we will only send a replacement bottle at our cost when there is proof of the sample being broken upon receipt. This means that the consignee must report a broken bottle immediately. The consignee should take pictures of how the package and bottles looked upon arrival. We need these pictures to claim costs from the forwarders. The consignee should always mark any damage (dents, rips, leakage etc.) on the outside of the packages on the consignment note from the courier when it is delivered. Even minor damages should be reported. Please send copies of consignment notes and the pictures via e-mail to [nl.saman.iis@sgs.com](mailto:nl.saman.iis@sgs.com).
- \* This interlaboratory study concerns **2 identical** samples of Biogasoline E10, 2x 1L glass bottles both labelled #21082 for the determination of RON and/or MON only based on the scope of the latest version of EN228 and ASTM D4814. You can check the test scope in round iis21B03RON via [www.kpmd.co.uk/sgs-iis/](http://www.kpmd.co.uk/sgs-iis/).
- \* Please treat the samples **as if they were routine samples**. Furthermore, each laboratory is advised to perform only those analyzes you normally do (but you are allowed to do all analyzes if you like). It might be wise to start with those tests which are most important to your laboratory, especially if the supplied sample amount seems to be critical.
- \* Please do not apply EN228 correction.
- \* **Reporting of test results:**  
Within a time frame of five weeks test results can be entered or revised. Please report your test results via [www.kpmd.co.uk/sgs-iis/](http://www.kpmd.co.uk/sgs-iis/). It is not necessary to enter all test results in one session. Within the time frame you can add (or delete) test results and/or change test results or units. Please **do not forget** to hit the "Save/Submit" button after entering the test results. Please note that you will get a pop up to say that you have submitted your test results. You can check if your test results have been saved by logging out and logging in again. When your test results are still present it means that everything is OK and that your test results are received in good order.

On the report page is a column, titled "reference method". In case a method is mentioned in this column, it will be used for the calculation of the z-scores. It is of utmost importance to know that it is **not mandatory** to use this 'reference method' as test method. Please select the method that you used from the picklist under "Actual Method Used". When your method is not listed here, please select "Other" and write the method that you used in the comments.

Please report the test results using the indicated units. It is possible to report in the last column the test results rounded in accordance with the test method that was used and in the first result column the same test results but less rounded. Please note that it is not mandatory to report both 'rounded' and 'unrounded' test results. The 'unrounded' test results are preferably used for our statistical evaluations. However the 'rounded' test results will be used in case the 'unrounded' test results are not reported. We suggest to report extra significant figures in order to give more meaningful statistical evaluations. For example, when you use ASTM D2699 for the determination of RON and you found a test result of 95.63, we request you to report 95.63 as 'unrounded' test result and 95.6 as 'rounded' test result in accordance with ASTM D2699.

It is also requested not to report 'less than' test results, which are above the detection limit, because such test results cannot be used for meaningful statistical evaluations.

**The official closing date for reporting test results for this PT is June 25, 2021.**

After the official closing date it is no longer possible to submit or correct test results via the data entry portal. When you cannot report via the portal or for unforeseen reasons cannot report before the closing date, please inform the Institute for Interlaboratory Studies (iis).

- \* **For all communication (e.g. problems with the package/samples, login details for the data entry portal, not reporting in time) or any remarks/questions please contact:**  
ing. R.J. Starink, Institute for Interlaboratory Studies (iis)  
P.O. box 200, 3200 AE Spijkenisse, The Netherlands  
tel.no. +31 181 69 45 41 / fax.no. +31 181 69 45 43  
e-mail: [nl.iis@sgs.com](mailto:nl.iis@sgs.com) / website: [www.iisnl.com](http://www.iisnl.com)